

Application No:	Consultees Name:	Received:	Comment:	Response:
2022/5529/P	THE HEATH & HAMPSTEAD SOCIETY	09/03/2023 12:23:39	OBJ	Objection from: THE HEATH & HAMPSTEAD SOCIETY This ASHP is close to the existing and neighbouring buildings. This application has a Noise Report which includes a requirement for a noise reducing enclosure. No enclosure is shown on the drawings. Please refuse unless clearly shown on the drawing tare the details, size etc of the noise reducing enclosure
