


















-  Fire Alarm Panel
-  Visual Alarm Device (White Flash)
-  Smoke detector as 3 NO
-  Smoke detector Sdr as 4 NO
-  Heat Detector as 1 NO
-  Sounder/Beacon as 1 NO
-  Call Point

FD30: 30 Mins Resistance Door
FD60: 60 Mins Resistance Door

The Basement Floor Fire Escape Proposed

Notes:

1. All works to comply with the building regulations.
2. New studwork partitions to be framed from 75X47 mm SW framing faced both sides with 12.5 mm plasterboard with skim coat of plaster finish.
3. The floor to be leveling and covered with new anti slip vinyl flooring.
4. Make good existing wall using gypsum plaster or similar approved.

-  Direction of escape
-  H₂O Extinguisher
-  CO₂ Extinguisher
-  Foam Extinguisher
-  Wet Chemical Extinguisher
-  New Stud Walls
-  Shelving
-  The Sink
-  Call Point
-  Fire Blanket

TITLE	Restaurant	
CLIENT	Mr Xu	
PROJECT ADDRESS	68-70 Sotumpton Row, London WC1B 4AR	
DRAWING NUMBER	P-06	
ISSUE&DATE	February 2023	
SCALE	1:100	A4
DRAWING BY	-----	