

Application No:	Consultees Name:	Received:	Comment:	Response:
2023/1179/P	David Castle RIBA Dip.TP AA Dip.	14/04/2023 16:37:02	OBJ	<p>Objection from: THE HEATH &amp; HAMPSTEAD SOCIETY</p> <p>We do not object to the proposed dormer on the rear slope of this semi-detached house. However we do object to the dormer being close to the party wall. The dormer should be spaced at least 0.9 meters (3 feet) away from the party wall in order to allow the owners of the adjoining `semi` to build a symmetrical dormer in the future should they wish to do so.</p> <p>David Castle Planning Sub-Committee.</p>

---