

2023/1095/L 4-6 Bedford Place OBJECTION

[REDACTED]

- CoL: Replacement and repair of windows on front and rear elevations.

Observations

- Noted immediately in street view that the proposed works are / have been already carried out. As usual, the standard of enforcement in this area is appalling.
- OW/HC/HGT/AJ explain to committee members the significance of types of glazing, presence of horns, bars, etc.

[REDACTED]

[REDACTED]

- OW notes that he approved the plastering of Georgian houses on Doughty St in PV panels despite vociferous objection from ourselves.
- It is noted that the application is for replacement single glazing 'like for like'. However the proposed glazing is in fact 8mm thick which is consistent with insulated IGUs. The drawings upon close inspection specify 'insulated glass' while the application states it is 'like for like single glazing'. Historic single glazing is approximately 2mm.
- This application is fraudulent and totally misleading, and should be withdrawn.

[REDACTED]

[REDACTED]

[REDACTED]

Actions

- The committee objects to this application.
- The committee recommends that this application is immediately withdrawn and an enforcement officer dispatched to this site to inspect what works have been

carried out.

