



This safety certificate is an important and valuable document which should be retained for future reference

This certificate is not valid if the serial number has been defaced or altered

DCN7C/ 01091176

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with British Standard 7671 - Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

CRN/	Contractor's Reference Number		
DETAILS OF THE CLIENT		ADDRESS OF THE INSTALLATION	
Client and address	Installation flat 11 address 267 Eversholt Street London London Postcode NW1 1BA		
DETAILS OF THE INSTALLATION			
Extent of the installation work covered by this certificate	roof conversation studio flat with an open space kitchen and living facility and self contained shower unit.		The installation is
			New <input checked="" type="checkbox"/>
			An addition <input type="checkbox"/>
			An alteration <input type="checkbox"/>
DESIGN, CONSTRUCTION, INSPECTION AND TESTING			
I, being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my signature adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with BS 7671, 2008 amended to 2015 (date) except for the departures, if any, detailed as follows: Details of departures from BS 7671, as amended (Regulations 120.3, 133.5)		The extent of liability of the signatory is limited to the work described above as the subject of this certificate. For the DESIGN , the CONSTRUCTION and the INSPECTION AND TESTING of the installation Signature [Redacted] Name OZKAN KUH (CAPITALS) Date 12/06/2016 The results of the inspection and testing reviewed by the Qualified Supervisor Signature [Redacted] Name OZKAN KUH (CAPITALS) Date 12/06/2016	
PARTICULARS OF THE APPROVED CONTRACTOR		NEXT INSPECTION <small>§ Enter interval in terms of years, months or weeks, as appropriate</small>	
Trading title	Icon Design & Maintenance Ltd		
Address	Monomark House 27 Old Gloucester Street		
Telephone No	0745422266		Postcode
	WC1N 3AX		
NICEIC Enrolment No (Essential information)	6 0 6 3 7 0		Branch No (if applicable)
			0 0 0
		RECOMMEND that this installation is further inspected and tested after an interval of not more than 10 years	
		COMMENTS ON EXISTING INSTALLATION <small>Note: Enter "NONE" or, where appropriate, the page number(s) of additional page(s) of comments on the existing installation</small>	
		very good	
		<small>In the case of an alteration or additions see Section 632 of BS 7671</small>	
		SCHEDULE OF ADDITIONAL RECORDS* <small>See attached schedule</small>	

* Where the electrical work to which this certificate relates includes the installation of a fire detection/ alarm system (or a part of such a system), this electrical safety certificate should be accompanied by the particular certificate for the system. This certificate is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

Please see the "Notes for Recipients" on the reverse of this page.



This certificate is not valid if the serial number has been defaced or altered
DCN7C/ 01091176

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

SUPPLY CHARACTERISTICS		Nature of supply parameters		Characteristics of primary supply overcurrent protective device(s)	
System type(s) TN-S ✓ TN-C-S N/A TT N/A	Number and type of live conductors 1-phase (2-wire) ✓ 3-phase (3-wire) N/A Other <small>Please state</small>	Number of sources 1	Nominal voltage(s) 400 V U _e (V) 230 V	Nominal frequency, f ^(N) 50 Hz External earth fault loop impedance, Z _e (Ω) 0.15 Ω	BS(EN) 1361 Type 2 Short-circuit capacity 80 kA Confirmation of supply polarity ✓ Rated current 60 A
		Single-phase Prospective fault current, I _p (kA) 1.5	3-phase Prospective fault current, I _p (kA) 3		

PARTICULARS OF INSTALLATION AT THE ORIGIN		Main Switch/Switch-Fuse/Circuit-Breaker/RCD	
Means of earthing Distributor's facility ✓ Installation earth electrode N/A	Details of installation earth electrode (where applicable) Type (eg rods, tape etc) N/A Location N/A Electrode resistance, R _s N/A Ω Method of measurement Method 2: Zs Loop	Protective measure(s) for fault protection ADS Maximum demand (Load) 47 Amps Number of smoke alarms 1	Measured Z _s 0.18 Ω Type BSI(EN) 60947-3 Voltage rating 230 V No of poles 2 Rated current, I _n 100 A Supply conductors copper RCD operating current, I _{Δn} N/A mA Supply conductors 16 mm ² RCD operating time (at I _{Δn}) ² N/A ms Rated time delay ³ N/A ms <small>* applicable only where an RCD is used as a main circuit-breaker</small>
Earthing conductor Conductor material copper Conductor csa 16 mm ² Continuity/connection verified ✓	Main protective bonding conductors and bonding of extraneous-conductive-parts (✓) Continuity/connection verified ✓ Conductor material copper Conductor csa 16 mm ² Location (where not obvious) Immersion heater cabinet	Water installation pipes ✓ Oil installation pipes N/A Gas installation pipes N/A Structural steel N/A	

SCHEDULE OF ITEMS INSPECTED		3.2 Accessibility of:	
1.0 CONDITION/ADEQUACY OF DISTRIBUTOR'S/SUPPLY INTAKE EQUIPMENT (the Distributor should be notified of any unsatisfactory equipment)		a) Earthing conductor connections	✓
1.1 Service cable		b) All protective bonding connections	✓
1.2 Service head			
1.3 Distributor's earthing arrangement			
1.4 Meter tails - Distributor/Consumer			
1.5 Metering equipment			
1.6 Means of main isolation (where present)			
2.0 PARALLEL OR SWITCHED ALTERNATIVE SOURCES OF SUPPLY		4.0 BASIC PROTECTION	
2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply		4.1 Presence and adequacy of measures to provide basic protection (prevention of contact with live parts) within the installation:	
2.2 Adequate arrangements where a generating set operates in parallel with the public supply		a) Insulation of live parts e.g. conductors completely covered with durable insulating materials	
2.3 Presence of alternative/additional supply warning notices(s)		b) Barriers or enclosures e.g. correct IP rating	
3.0 AUTOMATIC DISCONNECTION OF SUPPLY		5.0 ADDITIONAL PROTECTION	
3.1 Presence and adequacy of protective earthing/ bonding arrangements as follows:		5.1 Presence and effectiveness of additional protection methods	
a) Distributor's earthing arrangement or installation earth electrode arrangement		a) RCD(s) not exceeding 30 mA operating current	
b) Earthing conductor and connections		b) Supplementary bonding	
c) Main protective bonding conductors and connections			
d) Earthing/bonding labels at all appropriate locations			
		6.0 OTHER METHODS OF PROTECTION	
		6.1 Basic and fault protection	
		a) SELV	
		b) PELV	
		c) Double insulation/Reinforced insulation	
		d) Electrical separation for one item of equipment	

¹ All boxes must be completed. ✓ indicates that an inspection was carried out and that the result was satisfactory. N/A indicates that an inspection was not applicable to the particular installation.
² Where a smoke alarm has been installed, separate certification is required on the appropriate form.
 This certificate is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

DCN7C/ 01091176

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

CIRCUIT DETAILS										TEST RESULTS																				
Circuit number	Circuit designation			Type of wiring		Circuit conductor size		Overcurrent protective devices			Circuit impedances					Insulation resistance					RCD									
	* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.			Live (mm ²)	CPC (mm ²)	BS EN60898-1 (A) (MVA)	BS EN60898-1 (B) (MVA)	Type	Rating (A)	Response (s)	BS EN60898-1 (A) (MVA)	BS EN60898-1 (B) (MVA)	Min. Z _s (Ω)	Max. Z _s (Ω)	Z _e (Ω)	Z _{sc} (Ω)	Z _{sn} (Ω)	Z _s (Ω)	R _s (Ω)	X _s (Ω)	R _e (Ω)	X _e (Ω)	R _{ln} (MΩ)	R _{ln} (MΩ)	R _{ln} (MΩ)	R _{ln} (MΩ)	Priority	Max. measured earth loop impedance Z _s (Ω)	Operating time at I _{Δn} (ms)	Test before operation (ms)
1	Shower	A	C	1	10	4	0.4	61009	B	32	10	30	1.10	N/A	N/A	N/A	0.06	N/A	N/A	500	500	500	✓	0.21	28.1	28.7	✓			
2	Cooker	A	C	1	6	2.5	0.4	61009	B	32	10	30	1.10	N/A	N/A	N/A	0.27	N/A	N/A	500	500	500	✓	0.26	28.7	18.5	✓			
3	Sockets	A	C	9	2.5	1.5	0.4	61009	B	32	10	30	1.10	0.31	0.29	0.51	0.80	N/A	N/A	500	500	500	✓	0.32	16.2	18.7	✓			
4	ROOM HEATER	A	C	1	2.5	1.5	0.4	61009	B	20	10	30	2.18	N/A	N/A	N/A	0.15	N/A	N/A	500	500	500	✓	0.35	18.9	18.9	✓			
5	Immersion heater	A	C	1	2.5	1.5	0.4	61009	B	20	10	30	2.18	N/A	N/A	N/A	0.06	N/A	N/A	500	500	500	✓	0.38	18.7	19.1	✓			
6	THOWEL RAIL	A	C	1	1.5	1	0.4	61009	B	6	10	30	5.82	N/A	N/A	N/A	0.56	N/A	N/A	500	500	500	✓	0.81	18.9	18.9	✓			
7	Lights general	A	C	12	1.5	1	0.4	61009	B	6	6	30	5.82																	

Location of consumer unit	right top of the entry door	Designation of consumer unit	10 Way RCBO Template	Prospective fault current at consumer unit	1.5 kA
---------------------------	-----------------------------	------------------------------	----------------------	--	--------

TEST INSTRUMENTS		Test instruments (serial numbers) used				
Multi-function	2380049	Insulation resistance	Continuity	Earth electrode resistance	Earth fault loop impedance	RCD

Original (To the person ordering the work)

A: Approved contractor
 B: Competent person
 C: Competent person
 D: Competent person
 E: Competent person
 F: Competent person
 G: Competent person
 H: Other (please state)

This certificate is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)