



This certificate is not valid if the serial number has been defaced or altered

24993536

DCN18C

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671:2018 - Requirements for Electrical Installations

Original (to the person ordering the work)

## PART 1: DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR		DETAILS OF THE INSTALLATION	
Registration No: 606370000		Occupier: EMPTY	
Trading Title: Icon Design & Maintenance Ltd		Address: 267 Eversholt Street, FLAT-8 London	
Address: Monomark House, 27 Old Gloucester Street, LONDON			
Postcode: WC1N 3AX	Tel No: 08006890714	Postcode: NW1 1BA	Tel No: N/A

## PART 2: DETAILS OF THE ELECTRICAL WORK COVERED BY THIS INSTALLATION CERTIFICATE

Date works completed: 12/06/2016	Description and extent of the installation covered by this certificate: ONE BEDROOM FLAT WITH OPEN LOUNGE KITCHEN COMBINED FACILITY AND SHOWER ROOM
The installation is -	
New: ( <input checked="" type="checkbox"/> )	
An addition: ( <input type="checkbox"/> ) N/A	
An alteration: ( <input type="checkbox"/> ) N/A	
Replacement of a consumer unit: ( <input type="checkbox"/> ) N/A	Where necessary, continue on a separate numbered page: Page No(s) ( N/A )

## PART 3: NEXT INSPECTION OF THE ELECTRICAL INSTALLATION

I RECOMMEND that this installation is further inspected and tested after an interval of not more than:  years ~~00000~~\* (delete as appropriate)

## PART 4: DECLARATION FOR THE ELECTRICAL INSTALLATION WORK

**DESIGN, CONSTRUCTION, INSPECTION & TESTING**

I, being the person responsible for the design, construction, inspection and testing of the electrical installation, particulars of which are described in PART 2, having exercised reasonable skill and care when carrying out the design and additionally where this certificate applies to an addition or alteration, having confirmed that the safety of the existing installation is not impaired, hereby CERTIFY that the design, construction, inspection and testing for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671: 2018, amended to N/A (date) except for the following departures, if any, identified None (details on attached page(s) N/A ) (Regulations 120.3, 133.1.3 and 133.5) (538.4) N/A Page No(s) N/A

Name (capital): OZKAN KUJ Signature: [Redacted] Date: 12/06/2016

**REVIEWED BY QUALIFIED SUPERVISOR**

Name (capital): OZKAN KUJ Signature: [Redacted] Date: 12/06/2016

\*The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.



This certificate is not valid if the serial number has been defaced or altered

24993536

DCN18C

## DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671:2018 - Requirements for Electrical Installations

Original to the person ordering the work

### PART 5 : COMMENTS ON THE EXISTING INSTALLATION (in the case of an addition or alteration see Regulation 644.1.2)

THIS INSTALLATION WAS COMPLETED JUNE 2016, FOR SOME REASON AFTER DISCUSSING WITH THE NICEIC WE HAVENT HAD THE CHANCE TO RECOVER MORE THAN 3 CERTIFICATE AND THERE PERSON FOR THE WORK AGREED TO REISSUE THE CERTIFICATES WITH THE NEW EXISTING SOFTWARE BUT IN ACCORDANCE TO BS7671.2008 AMENDED TO 2015

### PART 6 : SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

<b>System type and earthing arrangements</b> TN-C-S: (N/A) TN-S: (✓) TE: (N/A) Other (state): N/A <b>Supply protective device</b> (BS EN) 1361 Type: (II) Rated current: (60) A	<b>Number and type of live conductors</b> AC 1-phase, 2-wire: (✓) Other (state): N/A Confirmation of supply polarity: (✓) Other sources of supply (as detailed on attached schedule) Page No: (N/A)	<b>Nature of supply parameters</b> Nominal line voltage to Earth, $U_0$ : (230) V <sup>(1) By enquiry, measurement, or by calculation</sup> Nominal frequency, $f$ : (50) Hz Prospective fault current, $I_{pf}^{(1)}$ : (3.2) kA External loop impedance, $Z_0^{(1)}$ : (0.16) Ω
--	---	---

### PART 7 : PARTICULARS OF INSTALLATION REFERRED TO IN THIS CERTIFICATE

Maximum demand (load): (45) A <b>Means of Earthing</b> Distributor's facility: (✓) Installation earth electrode: (N/A) <b>Where an earth electrode is used insert</b> Type - rod(s), tape, etc: (None) Location: (N/A) Electrode resistance to Earth: (N/A) Ω	<b>Main protective conductors</b> Earthing conductor: (material) COPPER (material) csa 16 mm <sup>2</sup> Connection / continuity verified: (✓) <b>Main protective bonding conductors:</b> (material) Copper (material) csa 16 mm <sup>2</sup> Connection / continuity verified: (✓)	<b>Main protective bonding connections</b> Water installation pipes: (✓) Gas installation pipes: (N/A) Structural steel: (N/A) Oil installation pipes: (N/A) Lightning protection: (N/A) Other (state): (N/A)	<b>Main switch / Switch-fuse / Circuit-breaker / RCD</b> Type: (BS EN 5419) Location: (MAIN SWITCH) No. of poles: (2) Current rating: (60) A Rating / setting of device: (60) A Voltage rating: (230) V <b>Where an RCD is used as the main switch</b> RCD rated residual operating current, $I_{\Delta n}$ : (N/A) mA Measured operating time: (N/A) ms Rated time delay: (N/A) ms
--	--	---	---

### PART 8 : SCHEDULES AND ADDITIONAL PAGES

<b>Schedule of Inspections</b> Page No(s): (3 & 4)	<b>Schedule of Circuit Details and Test Results for the installation</b> Page No(s): (5)	<b>Additional pages, including data sheets for additional sources</b> Page No(s): (None)	<b>Special installations or locations (indicated in Item 11.1 on page 4)</b> Page No(s): (None)	<b>Continuation sheets</b> Page No(s): (None)
---	---	---	--	--

The pages identified are an essential part of this certificate.

\*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current,  $I_{pf}$ , and external earth fault loop impedance,  $Z_0$ , must be recorded.

This certificate is based on the model forms shown in Appendix 6 of BS 7671. Enter a (✓) or value in the respective fields, as appropriate. Where an item is not applicable insert N/A.  
 Published by Certsure LLP Certsure LLP operates the NICEIC & ELECSA brands © Copyright Certsure LLP (July 2018)  
 Warwick House, Houghton Hall Park, Houghton Regis, Dunstable, LU5 5ZX



This certificate is not valid if the serial number has been defaced or altered

24993536

DCN18C

## DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

**Small installations up to 100 A single phase supply**

*Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations*

Original (to the person ordering the work)

### PART 9: SCHEDULE OF ITEMS INSPECTED

<p><b>1. External condition of intake equipment (visual inspection only)</b> (If inadequacies are identified with the intake equipment, it is recommended the person ordering the report informs the appropriate authority)</p> <p>1.1 Service cable: (.....) <input checked="" type="checkbox"/></p> <p>1.2 Service head: (.....) <input checked="" type="checkbox"/></p> <p>1.3 Earthing arrangement: (.....) <input checked="" type="checkbox"/></p> <p>1.4 Meter tails:</p> <p style="margin-left: 20px;">a) Cutout fuse to meter (.....) <input checked="" type="checkbox"/></p> <p style="margin-left: 20px;">b) Meter to consumer unit (.....) <input checked="" type="checkbox"/></p> <p>1.5 Metering equipment: (.....) <input checked="" type="checkbox"/></p> <p>1.6 Isolator (where present): (.....) <input checked="" type="checkbox"/></p> <p><b>2. Presence of adequate arrangements for other sources</b></p> <p>2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply: (.....) <input type="checkbox"/> N/A</p> <p>2.2 Adequate arrangements where generating set operates in parallel with the public supply: (.....) <input type="checkbox"/> N/A</p> <p>2.3 Presence of alternative / additional supply warning notices: (.....) <input type="checkbox"/> N/A</p> <p><b>3. Automatic disconnection of supply</b></p> <p>3.1 Presence and adequacy of earthing and protective bonding arrangements:</p> <p style="margin-left: 20px;">a) Installation earth electrode (where applicable) (.....) <input type="checkbox"/> N/A</p> <p style="margin-left: 20px;">b) Earthing conductor and connections, including accessibility (.....) <input checked="" type="checkbox"/></p> <p style="margin-left: 20px;">c) Main protective bonding conductors and connections, including accessibility (.....) <input checked="" type="checkbox"/></p> <p style="margin-left: 20px;">d) Provision of safety electrical earthing/bonding labels at all appropriate locations (.....) <input checked="" type="checkbox"/></p> <p style="margin-left: 20px;">e) RCD(s) provided for fault protection (.....) <input checked="" type="checkbox"/></p> <p><b>4. Basic protection</b></p> <p>4.1 Presence and adequacy of measures to provide basic protection (prevention of contact with live parts) within the installation:</p> <p style="margin-left: 20px;">a) Insulation of live parts e.g. conductors completely covered with durable insulating material (.....) <input checked="" type="checkbox"/></p> <p style="margin-left: 20px;">b) Barriers or enclosures e.g. correct IP rating (.....) <input checked="" type="checkbox"/></p>	<p><b>5. Additional protection</b></p> <p>5.1 Presence and effectiveness of additional protection methods:</p> <p style="margin-left: 20px;">a) RCD(s) not exceeding 30 mA operating current (.....) <input checked="" type="checkbox"/></p> <p style="margin-left: 20px;">b) Supplementary bonding (.....) <input checked="" type="checkbox"/></p> <p><b>6. Other methods of protection</b></p> <p>6.1 Presence and effectiveness of methods which give both basic and fault protection:</p> <p style="margin-left: 20px;">a) SELV system including the source and associated circuits (.....) <input type="checkbox"/> N/A</p> <p style="margin-left: 20px;">b) PELV system including the source and associated circuits (.....) <input type="checkbox"/> N/A</p> <p style="margin-left: 20px;">c) Double or reinforced insulation i.e. Class II or equivalent equipment and associated circuits (.....) <input type="checkbox"/> N/A</p> <p style="margin-left: 20px;">d) Electrical separation for one item of equipment e.g. shaver supply unit (.....) <input type="checkbox"/> N/A</p> <p><b>7. Consumer unit(s) / distribution board(s)</b></p> <p>7.1 Adequacy of access and working space for items of electrical equipment including switchgear: (.....) <input checked="" type="checkbox"/></p> <p>7.2 Components are suitable according to assembly manufacturer's instructions or literature: (.....) <input checked="" type="checkbox"/></p> <p>7.3 Presence of linked main switch(es): (.....) <input checked="" type="checkbox"/></p> <p>7.4 Isolators, for every circuit or group of circuits and all items of equipment: (.....) <input checked="" type="checkbox"/></p> <p>7.5 Suitability of enclosure(s) for IP and fire ratings: (.....) <input checked="" type="checkbox"/></p> <p>7.6 Protection against mechanical damage where cables enter equipment: (.....) <input checked="" type="checkbox"/></p> <p>7.7 Confirmation that ALL conductor connections are correctly located in terminals and are tight and secure: (.....) <input checked="" type="checkbox"/></p> <p>7.8 Avoidance of heating effects where cables enter ferromagnetic enclosures e.g. steel: (.....) <input checked="" type="checkbox"/></p> <p>7.9 Selection of correct type and ratings of circuit protective devices for overcurrent and fault protection: (.....) <input checked="" type="checkbox"/></p> <p>7.10 Confirmation overvoltage protection (SPDs) provided where specified: (.....) <input type="checkbox"/> N/A</p> <p>7.11 Indication of SPDs continued functionality confirmed: (.....) <input type="checkbox"/> N/A</p> <p>7.12 Adequacy of AFDD(s), where specified: (.....) <input type="checkbox"/> N/A</p>	<p>7.13 Presence of appropriate circuit charts, warning and other notices:</p> <p style="margin-left: 20px;">a) Provision of circuit charts/schedules or equivalent forms of information (.....) <input checked="" type="checkbox"/></p> <p style="margin-left: 20px;">b) Warning notice of method of isolation where live parts not capable of being isolated by a single device (.....) <input type="checkbox"/> N/A</p> <p style="margin-left: 20px;">c) Periodic inspection and testing notice (.....) <input checked="" type="checkbox"/></p> <p style="margin-left: 20px;">d) Presence of RCD six-monthly notice, where required (.....) <input checked="" type="checkbox"/></p> <p style="margin-left: 20px;">e) Warning notice of non-standard (mixed) colours of conductors present (.....) <input type="checkbox"/> N/A</p> <p>7.14 Presence of labels to indicate the purpose of switchgear and protective devices: (.....) <input type="checkbox"/> N/A</p> <p><b>8. Circuits</b></p> <p>8.1 Adequacy of conductors for current-carrying capacity with regard to type and nature of the installation: (.....) <input checked="" type="checkbox"/></p> <p>8.2 Cable installation methods suitable for the location(s) and external influences: (.....) <input checked="" type="checkbox"/></p> <p>8.3 Segregation/separation of Band I (ELV) and Band II (LV) circuits, and electrical and non-electrical services: (.....) <input type="checkbox"/> N/A</p> <p>8.4 Cables correctly erected and supported throughout, with protection against abrasion: (.....) <input checked="" type="checkbox"/></p> <p>8.5 Provision of fire barriers, and sealing arrangements where necessary: (.....) <input checked="" type="checkbox"/></p> <p>8.6 Non-sheathed cables enclosed throughout in conduit, ducting or trunking: (.....) <input checked="" type="checkbox"/></p> <p>8.7 Conductors correctly identified by colour, lettering or numbering: (.....) <input checked="" type="checkbox"/></p> <p>8.8 Presence, adequacy and correct termination of protective conductors: (.....) <input checked="" type="checkbox"/></p> <p>8.9 Cables and conductors correctly connected, enclosed and with no undue mechanical strain: (.....) <input checked="" type="checkbox"/></p> <p>8.10 No basic insulation of a conductor visible outside enclosure: (.....) <input checked="" type="checkbox"/></p> <p>8.11 Single-pole devices for switching or protection in line conductors only: (.....) <input checked="" type="checkbox"/></p> <p>8.12 Accessories not damaged, securely fixed, correctly connected, suitable for external influences: (.....) <input checked="" type="checkbox"/></p> <p>8.13 Cables concealed under floors, above ceilings or in walls / partitions, adequately protected against damage: (.....) <input checked="" type="checkbox"/></p>
--	--	--





This certificate is not valid if the serial number has been defaced or altered

24993536 **DCN18C**

## DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

**Small installations up to 100 A single phase supply**

*Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations*

PART 10: SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS										Circuits/equipment vulnerable to damage when testing: <u>N/A</u>																																																																																																								
Circuit number	Circuit description	CODES for Type of wiring		Type of cable (see Code)	Reference Method (BS 7671)	Number of points served	Circuit conductor size		Circuit conductor size (BS 7671)	Min. disconnection time (BS 7671)	Protective device				RCD	Circuit impedances (Ω)					Insulation resistance			RCD operating time	Test buttons																																																																																									
		(A)	(B)				(C)	(D)			(E)	(F)	(G)	(H)		(I)	(J)	(K)	(L)	(M)	(N)	(O)	(P)		(Q)	(R)	(S)	(T)	(U)	(V)	(W)	(X)	(Y)	(Z)																																																																																
							Live (mm <sup>2</sup> )	TPC (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I <sub>n</sub> (mA)	IC <sub>1</sub> (Ω)	IC <sub>2</sub> (Ω)	IC <sub>3</sub> (Ω)	IC <sub>4</sub> (Ω)	IC <sub>5</sub> (Ω)	IC <sub>6</sub> (Ω)	IC <sub>7</sub> (Ω)	IC <sub>8</sub> (Ω)	IC <sub>9</sub> (Ω)	IC <sub>10</sub> (Ω)	IC <sub>11</sub> (Ω)	IC <sub>12</sub> (Ω)	IC <sub>13</sub> (Ω)	IC <sub>14</sub> (Ω)	IC <sub>15</sub> (Ω)	IC <sub>16</sub> (Ω)	IC <sub>17</sub> (Ω)	IC <sub>18</sub> (Ω)	IC <sub>19</sub> (Ω)	IC <sub>20</sub> (Ω)	IC <sub>21</sub> (Ω)	IC <sub>22</sub> (Ω)	IC <sub>23</sub> (Ω)	IC <sub>24</sub> (Ω)	IC <sub>25</sub> (Ω)	IC <sub>26</sub> (Ω)	IC <sub>27</sub> (Ω)	IC <sub>28</sub> (Ω)	IC <sub>29</sub> (Ω)	IC <sub>30</sub> (Ω)	IC <sub>31</sub> (Ω)	IC <sub>32</sub> (Ω)	IC <sub>33</sub> (Ω)	IC <sub>34</sub> (Ω)	IC <sub>35</sub> (Ω)	IC <sub>36</sub> (Ω)	IC <sub>37</sub> (Ω)	IC <sub>38</sub> (Ω)	IC <sub>39</sub> (Ω)	IC <sub>40</sub> (Ω)	IC <sub>41</sub> (Ω)	IC <sub>42</sub> (Ω)	IC <sub>43</sub> (Ω)	IC <sub>44</sub> (Ω)	IC <sub>45</sub> (Ω)	IC <sub>46</sub> (Ω)	IC <sub>47</sub> (Ω)	IC <sub>48</sub> (Ω)	IC <sub>49</sub> (Ω)	IC <sub>50</sub> (Ω)	IC <sub>51</sub> (Ω)	IC <sub>52</sub> (Ω)	IC <sub>53</sub> (Ω)	IC <sub>54</sub> (Ω)	IC <sub>55</sub> (Ω)	IC <sub>56</sub> (Ω)	IC <sub>57</sub> (Ω)	IC <sub>58</sub> (Ω)	IC <sub>59</sub> (Ω)	IC <sub>60</sub> (Ω)	IC <sub>61</sub> (Ω)	IC <sub>62</sub> (Ω)	IC <sub>63</sub> (Ω)	IC <sub>64</sub> (Ω)	IC <sub>65</sub> (Ω)	IC <sub>66</sub> (Ω)	IC <sub>67</sub> (Ω)	IC <sub>68</sub> (Ω)	IC <sub>69</sub> (Ω)	IC <sub>70</sub> (Ω)	IC <sub>71</sub> (Ω)	IC <sub>72</sub> (Ω)	IC <sub>73</sub> (Ω)	IC <sub>74</sub> (Ω)	IC <sub>75</sub> (Ω)	IC <sub>76</sub> (Ω)	IC <sub>77</sub> (Ω)	IC <sub>78</sub> (Ω)	IC <sub>79</sub> (Ω)	IC <sub>80</sub> (Ω)	IC <sub>81</sub> (Ω)	IC <sub>82</sub> (Ω)	IC <sub>83</sub> (Ω)	IC <sub>84</sub> (Ω)	IC <sub>85</sub> (Ω)	IC <sub>86</sub> (Ω)	IC <sub>87</sub> (Ω)	IC <sub>88</sub> (Ω)	IC <sub>89</sub> (Ω)	IC <sub>90</sub> (Ω)	IC <sub>91</sub> (Ω)	IC <sub>92</sub> (Ω)	IC <sub>93</sub> (Ω)	IC <sub>94</sub> (Ω)	IC <sub>95</sub> (Ω)	IC <sub>96</sub> (Ω)	IC <sub>97</sub> (Ω)	IC <sub>98</sub> (Ω)	IC <sub>99</sub> (Ω)	IC <sub>100</sub> (Ω)
1	SHOWER UNIT	A	A	1	6	6	5	1009	B	40	6	30	1.09	N/A	N/A	N/A	0.09	N/A	N/A	500	500	✓	0.21	19.7	✓	N/A																																																																																								
2	COOKER HOB	A	A	1	6	2.5	0.4	1009	B	32	6	30	1.37	N/A	N/A	N/A	0.11	N/A	N/A	500	500	✓	0.26	19.1	✓	N/A																																																																																								
3	ROOM HEATHER	A	A	1	2.5	1.5	0.4	1009	B	20	6	30	2.19	N/A	N/A	N/A	0.20	N/A	N/A	500	500	✓	0.31	25.9	✓	N/A																																																																																								
4	IMMERSION HEATHER	A	A	1	2.5	1.5	0.4	1009	B	20	6	30	2.19	N/A	N/A	N/A	0.14	N/A	N/A	500	500	✓	0.27	13.3	✓	N/A																																																																																								
5	SOCKETS GENERAL	A	A	5	2.5	1.5	0.4	1009	B	20	6	30	2.19	N/A	N/A	N/A	0.20	N/A	N/A	500	500	✓	0.25	18.7	✓	N/A																																																																																								
6	LOUNGE HEATHER	A	A	1	2.5	1.5	0.4	1009	B	20	6	30	2.19	N/A	N/A	N/A	0.21	N/A	N/A	500	500	✓	0.31	21.5	✓	N/A																																																																																								
7	OWEN	A	A	1	2.5	1.5	0.4	1009	B	20	6	30	2.19	N/A	N/A	N/A	0.14	N/A	N/A	500	500	✓	0.24	28.1	✓	N/A																																																																																								
8	KITCHEN SOCKETS	A	A	3	2.5	1.25	0.4	1009	B	20	6	30	2.19	N/A	N/A	N/A	0.23	N/A	N/A	500	500	✓	0.25	13.8	✓	N/A																																																																																								
9	LIGHTS	A	A	15	1.5	1	0.4	1009	B	6	6	30	7.28	N/A	N/A	N/A	0.47	N/A	N/A	500	500	✓	0.86	24.5	✓	N/A																																																																																								
10	TOWEL RAIL	A	A	1	1.5	1	0.4	1009	B	6	6	30	7.28	N/A	N/A	N/A	0.38	N/A	N/A	500	500	✓	0.55	25.9	✓	N/A																																																																																								

Location of consumer unit: ABOVE THE ENTRY DOOR Designation: DB FLAT-9 Prospective fault current at consumer unit (where applicable): 3.4 kA

TESTED BY Name (capital): OZKAN KUH Position: QS Signature: [Signature] Date: 12/09/2016

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: <u>2380049</u>	Continuity: <u>N/A</u>	Insulation resistance: <u>N/A</u>	Earth fault loop impedance: <u>N/A</u>	Earth electrode resistance: <u>N/A</u>	RCD: <u>N/A</u>
--------------------------------	------------------------	-----------------------------------	--	--	-----------------

This certificate is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the NICEIC & ELECSA brands. Warwick House, Houghton Hall Park, Houghton Ragle, Dunstable, LU5 5ZX. © Copyright Certsure LLP (July 2016). \*\* Where figure is not taken from BS 7671, state source: ( N/A )

Original (to the person ordering the work)

## NOTES FOR RECIPIENT

### THIS CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE USE

If you were the person ordering the work, but not the owner or user of the installation, you should pass this certificate, or a full copy of it including these notes, immediately to the owner or user of the installation.

This safety certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected, tested and verified in accordance with the national standard for the safety of electrical installations, *BS 7671: 2018 (as amended) - Requirements for Electrical Installations*.

Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested every six months. For safety reasons it is important that this instruction is followed.

Also for safety reasons, the complete electrical installation will need to be inspected and tested at appropriate intervals by a skilled person or persons competent in such work. NICEIC® recommends that you engage the services of a NICEIC Approved Contractor for this purpose. The maximum interval recommended before the next inspection is stated in PART 3. There should be a notice at or near the consumer unit indicating the date when the next inspection is due.

Only an NICEIC Approved Contractor is authorised to issue this NICEIC Domestic Electrical Installation Certificate.

The Domestic Electrical Installation Certificate consists of at least five pages, and is only valid if accompanied by the *Schedule of Items Inspected* and the *Schedule of Circuit Details and Test Results*. The certificate has a printed serial number which is traceable to the contractor to which it was supplied.

For installations having more than one consumer unit or more circuits than can be recorded on Page 5, one or more additional *Schedule of Circuit Details and Test Results*, should form part of the certificate.

This certificate is intended to be issued for either the initial certification of a new electrical installation, or for new work associated with an addition or alteration to an existing electrical installation, including the replacement of a consumer unit, in a domestic or similar premises.

This certificate should not have been issued for reporting on the condition of an existing electrical installation. An Electrical Installation Condition Report should be issued for such an inspection.

You should have received the certificate marked "Original" and the contractor should have retained the certificate marked "Duplicate".

The "Original" certificate should be kept in a safe place and shown to any person inspecting or undertaking work on the electrical installation in the future. If you later vacate the property, this certificate will demonstrate to the new owner or user that the electrical installation work complied with the requirements of *BS 7671: 2018* at the time the certificate was issued.

The *Construction (Design and Management) Regulations* require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety documentation.

Page 1 of this certificate provides details of the electrical installation, together with the names and signatures of the persons certifying the installation work and reviewing the results of inspection and testing.

Certification provides an assurance that the electrical installation work has been fully inspected and tested, and that the work has been carried out in accordance with the requirements of *BS 7671: 2018* (except for any departures appended to the certificate).

Where the electrical work to which this certificate relates includes the provision of a mains powered fire detection and alarm system (such as one or more smoke or heat detectors), this electrical safety certificate must be accompanied by a separate certificate for that system in accordance with British Standard *BS 5839-6*.

Where a number of sources are available to supply the installation, and where the data given for the primary source may differ from other sources, an additional page should have been provided which gives the relevant information relating to each additional source, and to the associated earthing arrangements and main switchgear.

Should the person ordering the work (e.g. the client, as identified on Page 1 of this certificate) have reason to believe that any element of the electrical work for which the contractor has accepted responsibility (as indicated by the signatures on this certificate) does not comply with the requirements of *BS 7671: 2018*, the person should in the first instance raise the specific concerns in writing with the contractor. If the concerns remain unresolved, the client may make a formal complaint to NICEIC, for which purpose a standard complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application and from the website. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

\* NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).

For further information about electrical safety and how NICEIC can help you, visit [www.niceic.com](http://www.niceic.com)