



This certificate is not valid if the serial number has been defaced or altered

25633907

DCN18C

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR	DETAILS OF THE CLIENT	DETAILS OF THE INSTALLATION
Registration No: 606370000	Contractor Reference Number (CRN): 606370	Occupier: EMPTY
Trading Title: Icon Design & Maintenance Ltd	Name: HASAN YAMAN	Address: 267 Eversholt Street, flat -8, London
Address: Monomark House, 27 Old Gloucester Street, LONDON	Address: 13 Firs Park Avenue, London	
Postcode: WC1N 3AX	Postcode: N21 2PR	Postcode: NW1 1BA
Tel No: 06006690714	Tel No: N/A	Tel No: N/A

PART 2 : DETAILS OF THE ELECTRICAL WORK COVERED BY THIS INSTALLATION CERTIFICATE

Date works completed: 16/02/2016	Description and extent of the installation covered by this certificate:
The installation is -	SELF CONTAINED STUDIO FLAT
New: { } ✓	
An addition: { } N/A	
An alteration: { } N/A	
Replacement of a consumer unit: { } N/A	

Where necessary, continue on a separate numbered page. Page No(s) (N/A)

PART 3 : NEXT INSPECTION OF THE ELECTRICAL INSTALLATION

I RECOMMEND that this installation is further inspected and tested after an interval of not more than: 10 years/X00000* (delete as appropriate)

PART 4 : DECLARATION FOR THE ELECTRICAL INSTALLATION WORK

DESIGN, CONSTRUCTION, INSPECTION & TESTING

I, being the person responsible for the design, construction, inspection and testing of the electrical installation, particulars of which are described in PART 2, having exercised reasonable skill and care when carrying out the design and additionally where this certificate applies to an addition or alteration, having confirmed that the safety of the existing installation is not impaired, hereby CERTIFY that the design, construction, inspection and testing for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671: 2018, amended to N/A (date) except for the following departures, if any, identified: None

details on attached page(s) (N/A) (Regulations 120.3, 133.1.3 and 133.5). • Where selectivity is required, details of the verification appended (536.4): (N/A) Page No(s) (N/A)

Name (capital): OZKAN KUJ Signature: [Redacted] Date: 16/02/2016

REVIEWED BY QUALIFIED SUPERVISOR

Name (capital): OZKAN KUJ Signature: [Redacted] Date: 16/02/2016

*The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.



This certificate is not valid if the serial number has been defaced or altered

25633507

DCN18C

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

Original (to the person ordering the work)

PART 5: COMMENTS ON THE EXISTING INSTALLATION (in the case of an addition or alteration see Regulation 644.1.2)

THIS INSTALLATION WAS COMPLETED JUNE 2016, FOR SOME REASON AFTER DISCUSSING WITH THE NICEIC WE HAVENT HAD THE CHANCE TO RECOVER MORE THAN 3 CERTIFICATE AND THEREFORE THE NICEIC AND I AS THE RESPONSIBLE PERSON FOR THE WORK AGREED TO REISSUE THE CERTIFICATES WITH THE NEW EXISTING SOFTWARE BUT IN ACCORDANCE TO BS7671,2008 AMENDED TO 2015

PART 6: SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type and earthing arrangements TN-C-S: (N/A) TN-S: (✓) TT: (N/A) Other (state): N/A	Number and type of live conductors AC 1-phase, 2-wire: (✓) Other (state): N/A	Nature of supply parameters Nominal line voltage to Earth, U_0 : (230) V Nominal frequency, f : (50) Hz Prospective fault current, I_{pf} : (4.1) kA External loop impedance, Z_e : (0.06) Ω
Supply protective device (BS EN) 1361 Type: (II) Rated current: (60) A	Confirmation of supply polarity: (✓) Other sources of supply (as detailed on attached schedule) Page No: (N/A)	

PART 7: PARTICULARS OF INSTALLATION REFERRED TO IN THIS CERTIFICATE

Maximum demand (load): (45) A Means of Earthing Distributor's facility: (✓) Installation earth electrode: (N/A) Where an earth electrode is used insert Type – rod(s), tape, etc: (None) Location: (N/A) Electrode resistance to Earth: (N/A) Ω	Main protective conductors Earthing conductor: (material) Copper csa 16 mm ² Connection / continuity verified: (✓) Main protective bonding conductors: (material) Copper csa 16 mm ² Connection / continuity verified: (✓)	Main protective bonding connections Water installation pipes: (✓) Gas installation pipes: (N/A) Structural steel: (N/A) Oil installation pipes: (N/A) Lightning protection: (N/A) Other (state):	Main switch / Switch-fuse / Circuit-breaker / RCD Type: (BS EN) 5419 Location: (MAIN SWITCH) No. of poles: (2) Rating / setting of device: (60) A Current rating: (60) A Voltage rating: (230) V Where an RCD is used as the main switch RCD rated residual operating current, $I_{\Delta n}$: (N/A) mA Measured operating time: (N/A) ms Rated time delay: (N/A) ms
--	---	---	--

PART 8: SCHEDULES AND ADDITIONAL PAGES

Schedule of Inspections Page No(s): (3 & 4)	Schedule of Circuit Details and Test Results for the installation Page No(s): (5)	Additional pages, including data sheets for additional sources Page No(s): (6)	Special installations or locations (indicated in item 11.1 on page 4) Page No(s): (None)	Continuation sheets Page No(s): (None)
---	---	--	--	--

The pages identified are an essential part of this certificate.

*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current, I_{pf} , and external earth fault loop impedance, Z_e , must be recorded.

This certificate is based on the model forms shown in Appendix 6 of BS 7671. Enter a (✓) or value in the respective fields, as appropriate. Where an item is not applicable insert N/A.
Published by Certsure LLP Certsure LLP operates the NICEIC & ELECSA brands © Copyright Certsure LLP (July 2019)
Warwick House, Houghton Hall Park, Houghton Regis, Dunstable, LU5 5ZX



This certificate is not valid if the serial number has been defaced or altered

25633967

DCN18C

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

PART 9: SCHEDULE OF ITEMS INSPECTED

1. External condition of intake equipment (visual inspection only)

(If inadequacies are identified with the intake equipment, it is recommended the person ordering the report informs the appropriate authority)

- 1.1 Service cable: (.....) ✓
- 1.2 Service head: (.....) ✓
- 1.3 Earthing arrangement: (.....) ✓
- 1.4 Meter tails:
 - a) Cutout fuse to meter (.....) ✓
 - b) Meter to consumer unit (.....) ✓
- 1.5 Metering equipment: (.....) ✓
- 1.6 Isolator (where present): (.....) ✓

2. Presence of adequate arrangements for other sources

- 2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply: N/A (.....)
- 2.2 Adequate arrangements where generating set operates in parallel with the public supply: N/A (.....)
- 2.3 Presence of alternative / additional supply warning notices: N/A (.....)

3. Automatic disconnection of supply

- 3.1 Presence and adequacy of earthing and protective bonding arrangements:
 - a) Installation earth electrode (where applicable) (.....) ✓
 - b) Earthing conductor and connections, including accessibility (.....) ✓
 - c) Main protective bonding conductors and connections, including accessibility (.....) ✓
 - d) Provision of safety electrical earthing/bonding labels at all appropriate locations (.....) ✓
 - e) RCD(s) provided for fault protection (.....) ✓

4. Basic protection

- 4.1 Presence and adequacy of measures to provide basic protection (prevention of contact with live parts) within the installation:
 - a) Insulation of live parts e.g. conductors completely covered with durable insulating material (.....) ✓
 - b) Barriers or enclosures e.g. correct IP rating (.....) ✓

5. Additional protection

- 5.1 Presence and effectiveness of additional protection methods:
 - a) RCD(s) not exceeding 30 mA operating current (.....) ✓
 - b) Supplementary bonding (.....) ✓

6. Other methods of protection

- 6.1 Presence and effectiveness of methods which give both basic and fault protection:
 - a) SELV system including the source and associated circuits N/A (.....)
 - b) PELV system including the source and associated circuits N/A (.....)
 - c) Double or reinforced insulation i.e. Class II or equivalent equipment and associated circuits N/A (.....)
 - d) Electrical separation for one item of equipment e.g. shaver supply unit N/A (.....)

7. Consumer unit(s) / distribution board(s)

- 7.1 Adequacy of access and working space for items of electrical equipment including switchgear: (.....) ✓
- 7.2 Components are suitable according to assembly manufacturer's instructions or literature: (.....) ✓
- 7.3 Presence of linked main switch(es): (.....) ✓
- 7.4 Isolators, for every circuit or group of circuits and all items of equipment: (.....) ✓
- 7.5 Suitability of enclosure(s) for IP and fire ratings: (.....) ✓
- 7.6 Protection against mechanical damage where cables enter equipment: (.....) ✓
- 7.7 Confirmation that ALL conductor connections are correctly located in terminals and are tight and secure: (.....) ✓
- 7.8 Avoidance of heating effects where cables enter ferromagnetic enclosures e.g. steel: (.....) ✓
- 7.9 Selection of correct type and ratings of circuit protective devices for overcurrent and fault protection: (.....) ✓
- 7.10 Confirmation overvoltage protection (SPDs) provided where specified: N/A (.....)
- 7.11 Indication of SPDs continued functionality confirmed: N/A (.....)
- 7.12 Adequacy of AFDD(s), where specified: N/A (.....)

7.13 Presence of appropriate circuit charts, warning and other notices:

- a) Provision of circuit charts/schedules or equivalent forms of information (.....) ✓
- b) Warning notice of method of isolation where live parts not capable of being isolated by a single device N/A (.....)
- c) Periodic inspection and testing notice (.....) ✓
- d) Presence of RCD six-monthly notice, where required (.....) ✓
- e) Warning notice of non-standard (mixed) colours of conductors present N/A (.....)
- 7.14 Presence of labels to indicate the purpose of switchgear and protective devices: N/A (.....)

8. Circuits

- 8.1 Adequacy of conductors for current-carrying capacity with regard to type and nature of the installation: (.....) ✓
- 8.2 Cable installation methods suitable for the location(s) and external influences: (.....) ✓
- 8.3 Segregation/separation of Band I (ELV) and Band II (LV) circuits, and electrical and non-electrical services: N/A (.....)
- 8.4 Cables correctly erected and supported throughout, with protection against abrasion: (.....) ✓
- 8.5 Provision of fire barriers, and sealing arrangements where necessary: (.....) ✓
- 8.6 Non-sheathed cables enclosed throughout in conduit, ducting or trunking: (.....) ✓
- 8.7 Conductors correctly identified by colour, lettering or numbering: (.....) ✓
- 8.8 Presence, adequacy and correct termination of protective conductors: (.....) ✓
- 8.9 Cables and conductors correctly connected, enclosed and with no undue mechanical strain: (.....) ✓
- 8.10 No basic insulation of a conductor visible outside enclosure: (.....) ✓
- 8.11 Single-pole devices for switching or protection in line conductors only: (.....) ✓
- 8.12 Accessories not damaged, securely fixed, correctly connected, suitable for external influences: (.....) ✓
- 8.13 Cables concealed under floors, above ceilings or in walls / partitions, adequately protected against damage: (.....) ✓



This certificate is not valid if the serial number has been defaced or altered

25633907

DCN18C

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671:2018 - Requirements for Electrical Installations

PART 9: SCHEDULE OF ITEMS INSPECTED

8.14 Cables installed in walls / partitions, installed in prescribed zones: (.....) ✓	9.4 Security of fixings: (.....) ✓	11. Other Part 7 special installations or locations
8.15 Provision of additional protection by RCD not exceeding 30 mA: (.....) ✓	9.5 Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: (.....) ✓	11.1 List below any other special installations or locations which are part of the installation to be verified, and confirm that the additional requirements given in the respective section of Part 7 are fulfilled: N/A (.....)
a) For all socket-outlets with a rated current not exceeding 32 A (.....) ✓	9.6 Recessed luminaires (downlighters): (.....) ✓	(.....) (.....)
b) For supplies to mobile equipment with a current rating not exceeding 32 A for use outdoors (.....) ✓	a) Correct type of lamps fitted (.....) ✓	(.....) (.....)
c) For cables concealed in walls/partitions at a depth of less than 50 mm (.....) ✓	b) Installed to minimise build-up of heat (.....) ✓	(.....) (.....)
d) For cables concealed in walls/partitions containing metal parts regardless of depth (.....) ✓	9.7 Adequacy of working space / accessibility to equipment: (.....) ✓	(.....) (.....)
e) For circuits supplying luminaires within domestic (household) premises (.....) ✓	10. Location(s) containing a bath or shower	(.....) (.....)
8.16 Presence of appropriate devices for isolation and switching correctly located including: (.....) ✓	10.1 Additional protection by RCD not exceeding 30 mA: (.....) ✓	(.....) (.....)
a) Means of switching off for mechanical maintenance (.....) ✓	a) For low voltage circuits serving the location (.....) ✓	(.....) (.....)
b) Emergency switches N/A (.....)	b) For low voltage circuits passing through Zone 1 and/or Zone 2 not serving the location N/A (.....)	(.....) (.....)
c) Functional switches, for control of parts of the installation and current-using equipment N/A (.....)	10.2 Where used as a protective measure, requirements for SELV or PELV are met: N/A (.....)	(.....) (.....)
9. Current-using equipment (permanently connected)	10.3 Shaver sockets comply with BS EN 61559-2-5: N/A (.....)	(.....) (.....)
9.1 Suitability of equipment in terms of IP and fire ratings: (.....) ✓	10.4 Presence of supplementary protective equipotential bonding unless not required by BS 7671:2018: ✓	(.....) (.....)
9.2 Enclosure not damaged / deteriorated so as to impair safety: (.....) ✓	10.5 Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from Zone 1: N/A (.....)	(.....) (.....)
9.3 Suitability for the environment and external influences: (.....) ✓	10.6 Suitability of equipment for external influences for installed location in terms of IP rating: (.....) ✓	(.....) (.....)
	10.7 Suitability of equipment for installation in a particular zone: (.....) ✓	(.....) (.....)

Details must be appended on a separate numbered page.

SCHEDULE OF ITEMS INSPECTED BY

Name (capital letters): OZKAN KUH

Date: 16/02/2018

Where the electrical work to which this certificate relates includes the installation of a fire detection / alarm system (or part of such a system), this electrical safety certificate should be accompanied by the particular certificate for the system.

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

25633907

DCN18C

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 10: SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS										Circuits/equipment vulnerable to damage when testing:																
CODES for Type of wiring		Thermoplastic insulated / sheathed cables		Thermoplastic cables in flexible conduit		Thermoplastic cables in non-metallic conduit		Thermoplastic cables in rigid conduit		Thermoplastic cables in non-metallic trunking		Thermoplastic / FEA cables		Thermosetting / FEA cables		Mineral-insulated cables		Other - state N/A								
Circuit number	Circuit description <small>* Where this consumer unit is remote from the origin of the installation, record details of the circuit supplying this consumer unit on the first line.</small>	Type of wiring	Reference Method (BS 7671)	Number of points served	Circuit conductor size		Max. disconnection time (s) (BS 7671)	Protective device				RCD Type	Operating current, I _{OA} (mA)	Maximum permitted Z _s for 30 mA RCD (Ω)	Circuit impedances (Ω)					Insulation resistance			RCD operating time (ms)	Test buttons		
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)				Ring final circuits only (measured end to end)	All circuits (complete at least one column)	Live / Live	Live / Earth	Test voltage (V)	Priority	Max. measured earth fault loop impedance (Ω)	RCD		AFDD		
1	SHOWER UNIT	A	A	1	6	6	5	B1009	B	40	10	30	1.09	N/A	N/A	N/A	0.08	N/A	N/A	500	500	✓	0.16	21.7	✓	N/A
2	COOKER HOB	A	A	1	6	2.5	5	B1009	B	32	10	30	1.37	N/A	N/A	N/A	0.08	N/A	N/A	500	500	✓	0.24	29.1	✓	N/A
3	KITCHEN SOCKETS	A	A	5	2.5	1.25	5	B1009	B	32	10	30	1.37	0.17	0.17	0.28	0.11	N/A	N/A	500	500	✓	0.41	29.1	✓	N/A
4	SOCKETS	A	A	4	2.5	1.5	5	B1009	B	20	10	30	N/A	N/A	N/A	N/A	0.28	N/A	N/A	500	500	✓	0.27	28.9	✓	N/A
5	ROOM HEATER	A	A	1	2.5	1.5	5	B1009	B	16	10	30	2.73	N/A	N/A	N/A	0.27	N/A	N/A	500	500	✓	0.37	18.4	✓	N/A
6	IMMERSION HEATER	A	A	1	2.5	1.5	5	B1009	B	16	10	30	2.73	N/A	N/A	N/A	0.22	N/A	N/A	500	500	✓	0.27	19.9	✓	N/A
7	LIGHTS	A	A	10	1.5	1	5	B1009	B	6	10	30	7.28	N/A	N/A	N/A	0.56	N/A	N/A	500	500	✓	0.63	17.4	✓	N/A
8	TOWEL RAIL	A	A	1	1.5	1	5	B1009	B	6	10	30	7.28	N/A	N/A	N/A	0.49	N/A	N/A	500	500	✓	0.69	19.1	✓	N/A
9	BLANK																									
10	BLANK																									

Location of consumer unit: ABOVE THE ENTRY DOOR Designation: DB FLAT-8 Prospective fault current at consumer unit (where applicable): 4.1 kA

TESTED BY Name (capital): OZKAN KUH Position: QS Signature: [Redacted] Date: 16/02/2016

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-Function: 2380049	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
-------------------------	-----------------	----------------------------	---------------------------------	---------------------------------	----------

This certificate is based on the model forms shown in Appendix 6 of BS 7671
Published by Certsure LLP
Warwick House, Houghton Hall Park, Houghton Regis, Dunstable, LU5 5DX

© Copyright Certsure LLP (July 2018)
** Where figure is not taken from BS 7671, state source: (N/A)

Original to be kept by the person ordering the work