

This drawing shall not be scaled.  
Work from the dimensions shown in the drawing or given in relevant specifications



2No. NEW EXTERNAL CONDENSERS ON SCAFFOLDING - SEE DRAWING 1717921-HLEA-XX-03-DR-M-100004 Proposed Mechanical and Electrical Works (L3) T2 FOR DETAILS.  
REQUIRES NEW TEMPORARY REFRIGERANT PIPEWORK TO INTERNAL CASSETTES AND A/C UNITS ON FLOORS 2 AND 4.

NEW AHU ON TEMPORARY SCAFFOLDING TO CONNECT TO EXISTING DUCTWORK IN LEVEL 3 RISER OVER ROOF B/3/X04  
SEE DRAWING 1717921-HLEA-XX-03-DR-M-100004 Proposed Mechanical and Electrical Works (L3) T2 FOR DETAILS.

TEMPORARY SCAFFOLDING OVER WALKWAY

CDM Regulations:

In addition to any information included in this drawing or the model from which it is derived, refer also to the project CDM Risk Register for information on residual risks.

General Notes:

- The drawing does not necessarily show all the information needed to interpret the design intent or the construction details.
- The drawing contains information from more than one source and must be read in conjunction with all relevant specifications.
- Any apparent drafting errors and differences between other drawings and specifications shall be brought to our attention.

Project Notes:

T1	TENDER ISSUE	MJ/ND	GS	SM	01.06.23
Index	Description	Designed	Reviewed	Authorised	Date

REVISIONS:



ARCHITECT:  
NEX

CLIENT:  
BRITISH MUSEUM

PROJECT TITLE:  
WATER INGRESS PROTECTION WORKS

DRAWING TITLE:  
SECTION DRAWING FOR  
TEMPORARY LEVEL 2 PLANT

TENDER

PERSON RESPONSIBLE FOR:		
Design: MJ/ND	Review: GS	Authorising Issue: SM
Project No: 17/17921	Date: 01.06.23	Scale @ A1: 1:50
DRAWING NUMBER: 17921-HLEA-XX-XX-GA-M-100-002		Revision: T1