

Technical Note



Edmund House
12-22 Newhall Street
Birmingham
B3 3AS

0121 389 1472

info@airandacoustics.co.uk
airandacoustics.co.uk

Victoria House

Job Number: 100555	Date: 28 March 2023	Client: Oxford Victoria House Limited
Prepared By: CW	Approved By: SG	

1. Introduction

- 1.1. Planning permission (ref. 2022/3480/P), recently approved in November 2022, granted permission for new roof level plant (including fume stacks and replacement of a diesel generator) to support lab enabled space at levels 1 to 9 of the building. Condition 7 of the permission required approval of an air quality assessment (AQA), which has been submitted to the Council and is currently pending determination.
- 1.2. This technical note has been prepared to respond to comments made by the council on the AQA, submitted to discharge condition 7.

2. Air Quality

- 2.1. The following comments have been made in respect to the AQA.

Comment 1:

"Figure 3.3 indicates that the fume cupboard flues are quite close to air inlets RC, RG and RH and the prevailing wind direction from 2 flues are towards inlet RD. Relocation of these inlets is recommended or further details including the distance and cross-sectional diagrams of the exhausts / flues and inlets (to show location and relative heights) are required to ensure that there is no recirculation of emissions."

- 2.2. We understand that a detailed wind tunnel survey was carried out to obtain accurate concentration estimates at building air intakes and other sensitive locations due to emissions from the proposed laboratory extract sources located on the Victoria House. The CCP (2022) *Final Air Quality Report. Victoria House* report¹, which was appended to the KJ Tait's MEP report, has now been updated and is appended to this TN. The CPP (2023)² report concluded that all of proposed inlets modelled will meet the ASHRAW criterion (as outlined on page 3). Standard 62.1 of ASHRAW:

"specifies minimum ventilation rates and other measures intended to provide indoor air quality (IAQ) that's acceptable to human occupants and that minimizes adverse health effects. The standard provides procedures and methods for meeting minimum ventilation and IAQ requirements to engineers, design professionals, owners, and jurisdictional authorities where model codes have been adopted."

¹ CPP, 2022. *Final Air Quality Report. Victoria House. London, England. CPP Project 16452.*

² CPP, 2023. *Final Air Quality Report. Victoria House. London, England. CPP Project 16452.*

- 2.3. It is, however, noted that the CCP report summaries that the ASHRAE criterion is not met at some rooftop air intakes for less than 1% of wind conditions; this is typically considered an acceptable risk of exceedance.
- 2.4. On this basis, the air inlets modelled in line with drawing no. KJT-ZZ-R-DR-M-5701 meet the ASHRAW criterion *“to provide indoor air quality (IAQ) that’s acceptable to human occupants and that minimizes adverse health effects.”*

Comment 2:

“Filtration should be installed to air inlets A and C as a minimum. Details of filtration to be installed are required.”

- 2.5. We understand that the client will be providing filtration at these proposed air inlets, as outlined in drawing no. 21593-CWA-VH-ZZ-DR-A-3000, in the form of the AAC Nitrosorb Swiftpack System³. This System uses carbon filter technology to deliver a high efficiency and sustainable range of standard and customised NO_x filter units.
- 2.6. The Swiftpack solution is suitable for indoor air projects in new build and retrofit schemes and is designed for use with all types of MVHRs.

³ AAC Eurovent. AAC Nitrosorb® Swiftpack. Accessible at: <https://www.aaceurovent.co.uk/product/aac-nitrosorb-swiftpack-system/>

Appendices

**AIR QUALITY REPORT**

CPP PROJECT 16452
24 MARCH 20233

VICTORIA HOUSE
London, England

PREPARED FOR:

Oxford Victoria House Limited
8 Sackville St
London, UK W1S 3DG

PREPARED BY:

Jordan Beardy-Singh, Project Consultant

jbeardysingh@cppwind.com

Greg Gross, PE, Senior Engineer

ggross@cppwind.com

Brad C. Cochran, PE, Principal

bcochran@cppwind.com

CPP, Inc.

7365 Greendale Road

Windsor, Colorado 80550 USA

Tel: +1-970-221-3371

www.cppwind.com

EXECUTIVE SUMMARY

This report documents the wind-tunnel study conducted by CPP, Inc. on behalf of Oxford Victoria House Limited for the Victoria House, located in London, England, which is currently planned to be converted from office space to laboratory research space. The objective of the study was to obtain accurate concentration estimates at building air intakes and other sensitive locations due to emissions from the proposed laboratory extract sources located on the Victoria House. The laboratory extract sources are understood discharge an even mix of air from laboratory research spaces and office areas. As such, they may periodically emit chemicals or other contaminants that may enter nearby buildings through air intakes, or be present at other sensitive locations, and impact staff or the general public. If adverse impacts were found, mitigation measures were evaluated.

To meet the objectives of the study, a 1:240 scale model of Victoria House and nearby surroundings within a 415 m radius was constructed and placed in CPP's boundary-layer wind tunnel. Concentration measurements were obtained in the wind tunnel to define the impact of emissions from roof level laboratory extract sources at building air intake and other sensitive locations. Additional analysis for a proposed rooftop standby diesel generator was conducted using CPP's enhanced version of the ASHRAE Handbook model (ASHRAE, 2019).

The conclusions are summarized below and discussion for the proposed extracts are presented Table ES-1.

Conclusions

- Laboratory extracts are expected to meet the recommended ASHRAE criterion during full flow operation ($3.6 \text{ m}^3/\text{s}$ at 20.8 m/s).
- A screening level assessment that does not take into account local site conditions was conducted for a typical 700 kW generator. Estimates indicate that health limits would be met at distances greater than 4.4 m from the flue, while odors were estimated to extend up to 187 m downwind from the flue.
 - It is understood that an oxidizing extract filter will be added to the generator; assuming an 80% reduction of odor, the extent of odors would be reduced to a 37.5 m radius.

Table ES-1

Summary of Results for Laboratory Extracts on Bloomsbury Square Fume Extracts

Source Description	Stack Base Height (m) description	Design Description	Volume Flow Rate and Efflux Velocity m³/s (m/s)	Stack Height Above Base (m)	ASHRAE ¹ Design criterion met/not met (exceeded) as follows:
Bloomsbury Square Fume Extracts <i>EF-N1 & EF-N2 and EF-S1 & EF-S2</i>	35.5 Main Roof	Initial Proposed	6.4 (16.1)	4.0	met ²
		Updated Proposed	3.9 (20.8)	4.0	met ²
Discussion Both the initial and updated proposed designs meet the recommended ASHRAE criterion at all intakes evaluated.					

¹ ASHRAE recommended performance criterion for laboratory fume hood extract. See Section 2.5.1.

² ASHRAE criterion is not met at some rooftop air intakes for less than 1% of wind conditions, which is typically considered an acceptable risk of exceedance.

TABLE OF CONTENTS

EXECUTIVE SUMMARY.....	2
1. Introduction.....	5
2. Project Specific Information	6
2.1. Description of Site	6
2.2. Extract Sources.....	6
2.3. Receptor Locations.....	6
2.4. Meteorology.....	7
2.5. Concentration Design Criteria.....	7
2.5.1. Laboratory Extract	8
2.5.2. Combustion Sources.....	9
3. Numerical Modelling Methodology	10
3.1. Concentration Predictions	10
3.2. Simplified ASHRAE Separation Distance Procedure.....	10
4. Results	11
4.1. Concentration Measurements	11
REFERENCES	12
FIGURES	14
TABLES.....	22

1. INTRODUCTION

This report documents the wind-tunnel study conducted by CPP, Inc. on behalf of Oxford Victoria House Limited for the Victoria House, located in London, England, which is currently planned to be converted from office space to laboratory research space. The objective of the study was to obtain accurate concentration estimates at building air intakes and other sensitive locations due to emissions from the proposed laboratory extract sources located on the Victoria House. The laboratory extract sources are understood discharge an even mix of air from laboratory research spaces and office areas. As such, they may periodically emit chemicals or other contaminants that may enter nearby buildings through air intakes, or be present at other sensitive locations, and impact staff or the general public. If adverse impacts were found, mitigation measures were evaluated.

To meet the objectives of the study, a 1:240 scale model of Victoria House and nearby surroundings within a 415 m radius was constructed and placed in CPP's boundary-layer wind tunnel. Concentration measurement tests were conducted for a variety of meteorological conditions and source/receptor combinations. The concentration measurements were converted to full-scale normalized concentrations (C/m). Additional analysis for a proposed rooftop standby diesel generator was conducted using a simplified ASHRAE separation distance procedure (ASHRAE, 2019). The results provide estimated separation distances required to meet the recommended odour and health criteria (i.e., a design concentration). The design concentration was specified such that health and odour effects due to any expected chemical release would be minimal at sensitive locations.

Included in this report are a description of various site-specific issues, a discussion of the experimental methods, and the results of the study. The conclusions are summarized in an executive summary, which is located at the beginning of the report.

2. PROJECT SPECIFIC INFORMATION

2.1. DESCRIPTION OF SITE

The existing Victoria House is located in London, England. Figure 1 presents a detailed view of the area modelled on the turntable. Figure 2 is a close-up plan view of Victoria House showing source and surrounding receptor locations. Photographs of the model in the wind tunnel are shown in Figure 3. All testing was carried out in CPP's closed-circuit wind tunnel shown in Figure 4.

It was determined that a target surface roughness length of 0.7 m was appropriate for use in the wind-tunnel modelling based on aerial photos and previous experience in the area.

2.2. EXTRACT SOURCES

Victoria House is planned to be equipped with laboratory extract stacks located on the roof. The laboratory extracts will discharge an even mix of air from laboratory research and office areas. In addition, three (3) existing standby diesel generators will be replaced with a single unit with an estimated capacity of 700 kW. Note, it is understood that there are existing boilers and cooling towers with extract discharged at the roof level. Based on our experience, air quality impacts from these extracts will be the same as existing conditions. New air intakes are expected to see similar impacts as existing air intakes.

Extract discharges were simulated by installing stacks constructed of brass tubes at the appropriate locations. Trips were installed within the stacks as required to ensure that the stack flow was fully turbulent upon exit. The stacks were supplied with a tracer gas (ethane) and inert gas (nitrogen) mixture with a density similar to room temperature air. Precision mass flow controllers were used to monitor and regulate the discharge momentum.

An updated design of the laboratory extracts was evaluated using a numerical analysis informed by previously collected wind tunnel data, see "Simulated Runs" in Table 4.

All of the extract locations are shown in Figure 2. The full-scale extract parameters for each source are listed in Table 1.

2.3. RECEPTOR LOCATIONS

The emissions from the extract sources described above have the potential for causing health or odour problems at sensitive locations such as air intakes, plazas, entrances, and nearby buildings. The various receptor locations where concentrations were measured during the study are identified in Figure 2. Table 2 provides a list of abbreviated receptor identifications and their approximate elevations. Proposed intakes on the central penthouse structure at both Level 8 (receptor 46) and Level 9 (receptor 45) were initially evaluated during this wind tunnel study. Following review of the results and subsequent discussion, these intake locations were discounted as a viable strategy and are not reflected in the above-mentioned recommendations. An alternate location along the north façade of the penthouse structure was considered at Level 9 (receptor 47). Based on CPP's experience and further review of the initial results, air quality impacts from the laboratory extracts to this location are expected to meet the recommended ASHRAE criterion.

The receptor locations were evaluated by installing a small diameter brass tube at the specified location. This brass tube was then connected to the analysis instrumentation to determine the amount of tracer gas present at the receptor location.

It should be noted that not all receptors were sampled for each source. Only those receptors of most interest or those likely to give the highest concentration for a particular source were evaluated.

2.4. METEOROLOGY

The meteorological information of primary interest for this evaluation is the wind speed frequency distribution. This information is used to specify a reasonable upper limit wind speed to be used for testing. This information is also used in conjunction with the wind-tunnel measured concentrations to determine the percent time a certain concentration is predicted to be exceeded.

Figure 5 shows the wind speed and direction distribution, in the form of a wind rose, at the Heathrow Airport anemometer. The anemometer is located approximately 22 kilometers west of Victoria House. The data was collected during the period from 2005 to 2022. The wind rose indicates that the most frequent winds are from the south-southwest through west. The strongest winds, greater than 16 m/s (35.8 mph), occur primarily from the west-southwest through west.

Figure 6 shows the cumulative frequency distribution of wind speed at the Heathrow Airport anemometer. The wind speed distribution was used to determine the wind speed at the anemometer that is exceeded 1% of the time (i.e., the 1% wind speed). The figure shows that the 1% wind speed is approximately 12.3 m/s (27.5 mph) at the anemometer. The likelihood of specific wind conditions at the project site was considered in the wind tunnel testing and subsequent analysis.

2.5. CONCENTRATION DESIGN CRITERIA

Developing concentration acceptance criteria can be as important as predicting extract concentrations. Concentration predictions from wind tunnels or numerical methods by themselves are not useful for examining source designs unless some maximum acceptable concentration, or design criterion, is specified. This criterion will vary with source type and each source type may have a criterion that varies depending upon such things as emission type, emission quantity, and number of units emitting.

An air quality “acceptability question” can be written:

$$C_{\max} < C_{\text{health/odour}} \quad ? \quad \text{Equation 1}$$

where C_{\max} is the maximum concentration expected at a sensitive location (air intakes, operable windows, pedestrian areas), C_{health} is the health limit concentration and C_{odour} is the odour threshold concentration of any emitted chemical. When a large number of potential chemicals are emitted from a pollutant source, a variety of mass emission rates, health limits, and odour thresholds need to be examined. It then becomes operationally simpler to recast the acceptability question by normalizing (dividing) Equation 1 by the mass emission rate, m :

$$\left(\frac{C}{m}\right)_{\max} < \left(\frac{C}{m}\right)_{\text{health / odour}} \quad ? \quad \text{Equation 2}$$

The left side of Equation 2 $(C/m)_{\max}$, is only dependent on external factors such as stack design, receptor location, and atmospheric conditions. The right side of the equation is related to the emissions and is defined as the ratio of the health limit, or odour threshold, to the emission rate. Therefore, a highly toxic chemical with a low emission rate may be of less concern than a less toxic chemical emitted at a very high emission rate. Three types of information are needed to develop normalized health limits and odour thresholds:

1. a list of the toxic or odourous substances that may be emitted,

2. the health limits and odour thresholds for each emitted substance, and
3. the maximum potential emission rate for each substance.

It should be noted that the normalized concentration design criteria discussed below are derived from occupational exposure limits, odour thresholds and estimated mass emission rates. The occupational exposure limits are based on a mixture of guidelines, recommendations, and regulatory limits from the ACGIH, OSHA or NIOSH. The limits provided by ACGIH and NIOSH were developed as guidelines to assist in the control of health hazards, and are not intended for use as legal standards. The limits provided by OSHA are regulatory limits on the amount or concentration of an airborne substance that may be present in the workplace.

The mass emission rates for the laboratory extracts are based on an assumed accidental release scenario. Therefore, no safety factor has been applied per ANSI/ASSP Laboratory Ventilation Standard Z9.5-2022 (Z9.5-2022). The odour thresholds were obtained from published information with no safety factor applied. CPP recommends that the user employ an Industrial Hygienist to review both the design criteria development procedure described in this report and the user's anticipated laboratory procedures to determine the appropriateness of the established design criteria, discussed below. CPP further recommends that this document be reviewed each time the user experiences either a program change or a change in laboratory procedures. Failure to do so may nullify the recommendations presented in this report. A detailed explanation of the calculation is presented in an internal CPP document "CPP Simulation and Analysis Techniques for Air Quality Assessments" (September 2018). This document is available on request.

The following paragraphs discuss the specific design criteria used in this study as well as potential mitigation measures. The sources of concern for this evaluation and the design criterion for each source type are summarized in Table 3. The table also summarizes the basis from which each design criterion was developed.

2.5.1. LABORATORY EXTRACT

Design criteria specific for the chemicals used in a laboratory facility can be developed using chemical-specific information. However, Z9.5-2022 states "toxic and hazardous substances may be used at some point during the lifetime of the facility." This implies that one needs to assume that the chemical utilization will change over time and specifying the criteria based on current chemical utilization may not be appropriate.

No proposed chemical inventory was provided for this project. Therefore, the normalized health limit (HL/m) and normalized odour threshold (OT/m) design criteria were set at $400 \mu\text{g}/\text{m}^3$ per g/s, which corresponds to the ASHRAE example criterion discussed in Chapter 16 of the 2019 ASHRAE Handbook HVAC Applications (ASHRAE, 2019). This criterion assumes a 7.5 L/s chemical emission rate (i.e., due to a liquid spill or lecture bottle fracture) and a concentration of 3 mg/kg or less at an intake. Chapter 16 (ASHRAE, 2019) includes the following disclaimers regarding this criterion: 1) laboratories using extremely hazardous substances should conduct a chemical specific analysis based on published health limits; 2) a more lenient limit may be justified for laboratories with low levels of chemical usage; and 3) project specific requirements must be developed in consultation with the safety officer.

The ASHRAE criterion may be put into perspective by considering the "as installed" chemical hood containment requirements outlined in Z9.5-2022 (i.e., a concentration at a mannequin outside the chemical hood of 0.10 ppm or less for "as installed" with a 4 L/m accidental release in the hood as measured using the ANSI/ASHRAE 110-2016 test method). The "as installed" requirement is equivalent to a design criterion of 1500

$\mu\text{g}/\text{m}^3$ per g/s. Hence, the criterion for a mannequin (i.e., worker outside the chemical hood) is 1.9 to 3.8 times less restrictive than that for the air intake or other outdoor locations. This seems reasonable (i.e., that the air intake has more strict criteria) since the worker at the chemical hood can shut the hood or walk away to avoid adverse exposure. Also, the ANSI/ASHRAE 110-2016 test is not necessarily a "worst-case" exposure scenario for the worker.

For reference purposes, CPP has provided the following information in Table 6 for chemicals with published occupational exposure values (SEPA, 2010; ACGIH, 2018a and 2018b), workplace environmental exposure levels (TERA, 2019), and odour thresholds (Ruth, 1986; SEPA, 2010; AIHA, 2019):

- the normalized health limit and odour threshold associated with a 1 L spill or 1-minute lecture bottle release; and
- the limiting value (i.e., lowest value of the normalized health limit or odour threshold) associated with a 1 L spill or 1-minute lecture bottle release; and
- the maximum allowable fume hood volume (liquid) or release rate (gas) for each of the criteria discussed above.

The facility owner should review the table to determine whether they will be using chemicals in a manner that could create a problem. Also, a detailed hazard assessment should be carried as outlined in Z9.5-2022, which states:

"The first step in a hazard assessment is to identify what chemicals can be released including normally uncharacterized by-products. After characterizing the inherent hazard potential (largely based on physical properties, toxicity, and routes of entry), the next step is to ascertain at least qualitatively, the release "picture". At what points within the control zone will chemicals be evolved and at what release rate? Will the chemical release have velocity? How has the maximum credible accidental release been accounted for? Finally, how many employees are/could be exposed and what means are available for emergency response?"

2.5.2. COMBUSTION SOURCES

Standby Diesel Generator. The normalized health limit (HL/m) design criteria for the diesel emergency generator were based on information obtained from the U.S. Environmental Protection Agency (EPA, 1996a) and the U.S. Code of Federal Regulations (CFR, 2002). The normalized odour threshold (OT/m) design criteria were based on a 20% objection level to an exhaust dilution of 1:2000 (Vanderheyden, 1994). These filters typically reduce unburned hydrocarbons (the odourous exhaust components), by about 80%. If these filters are installed, the 1:2000 dilution requirement stated above is reduced to a 1:400 dilution requirement. The normalized concentration design criteria (HL/m and OT/m) for the diesel emergency generator are listed in Table 2. Normalized criteria for a single unit are computed in Table 7.

3. NUMERICAL MODELLING METHODOLOGY

3.1. CONCENTRATION PREDICTIONS

Numerically predicted exhaust concentrations were calculated using CPP's simplified ASHRAE procedure for calculating exhaust/intake separation distances (Petersen, 2016), as described in the following section. The predicted concentrations are used to estimate the area of impact from the proposed diesel standby generators. In order to quantify results for specific source/receptor combinations, additional analysis using a detailed numerical model or wind tunnel testing is required. A summary of the estimated separation distances required to meet health and odor criteria are summarized in Table 5.

3.2. SIMPLIFIED ASHRAE SEPERATION DISTANCE PROCEDURE

The simplified separation distance procedure is a variation of the separation distance equations and tables from ASHRAE Standard 62.1 (ANSI/ASHRAE, 2019). The simplification procedure was developed by CPP, through ASHRAE sponsored research (Petersen, 2016). In the development of the new procedure, several case-studies were compared against the current Standard 62.1 concentration predications. Modifications to Standard 62.1 equations were made to better-predict dilution versus distance, with a higher frequency of producing conservative dilution estimates (i.e., not over-predicting dilution). The exhaust stack operating parameters listed in Table 1 were used. The exhaust stack distance and height above/below the receptor location are used as inputs, along with several other factors, including turbulence, wind speed, and stack orientation (capped/un-capped).

4. RESULTS

4.1. CONCENTRATION MEASUREMENTS

Normalized concentrations (C/m) due to emissions from the various sources were measured and evaluated following CPP's standard data collection procedures, which are available upon request. A compilation of the maximum steady-state C/m values for each source/receptor combination tested is presented in Table 4. The conclusions derived from these results are presented in the tables included in the Executive Summary at the front of this report. C/m values versus wind speed and wind direction for each test are archived at CPP and available upon request.

In addition to presenting the maximum measured steady-state normalized concentration for each source/receptor combination evaluated, the table also indicates the percent time that the design criterion may be exceeded, if applicable. The percent time exceeded is calculated by determining the wind conditions that are predicted to result in an exceedance of the design criteria. The summation of the frequency that these wind conditions are expected to occur is then the percent time exceeded presented in Table 4. This value does not take into consideration the probability of the emission event associated with the specified design criteria. Therefore, to determine the probability of exceeding (i.e., not meeting) the design criteria, the value listed in Table 4 should be multiplied by the frequency of occurrence of the emission event. For example, if an laboratory extract is expected to operate for 8,760 hours per year, and the percent time exceeded for the ASHRAE criterion indicated in Table 4 is 10.0%, wind conditions that could result in an exceedance of the criterion are expected to be present at the specified receptor location 87.6 hours per year ($8,760 \text{ hours/yr} \times 0.10$).

REFERENCES

- ACGIH, *Guide to Occupational Exposure Values - 2018*, American Conference of Governmental Industrial Hygienists, 2018a.
- ACGIH, *Threshold Limit Values for Chemical Substances and Physical Agents*, American Conference of Governmental Industrial Hygienists, 2018b.
- ACGIH, *Odour Thresholds for Chemicals with Established Occupational Health Standards*, American Conference of Governmental Industrial Hygienists, 1989.
- AIHA, *Odour Thresholds for Chemicals with Established Health Standards*, Third Edition, American Industrial Hygiene Association, 2019.
- ANSI/ASSP, *American National Standard for Laboratory Ventilation; Standard Z9.5-2022*. American National Standards Institute/American Society of Safety Professionals, 2022.
- ANSI/ASHRAE 110-2016, *American National Standard Method of Testing Performance of Laboratory Fume Hoods*. American National Standards Institute/American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., 1791 Tullie Circle, N.E., Atlanta, GA, 30329, 2016.
- ASHRAE, *ASHRAE Handbook-HVAC Applications*. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., 1791 Tullie Circle, N.E., Atlanta, GA, 30329, 2019.
- CFR, Code of Federal Regulations, Title 40, Part 89, Table 1, "Emission Standards (g/kW-hr)," July 2002.
- CPP, *Simulation and Analysis Techniques for Air Quality Assessments*, September 2018
- EPA, *Guideline for Use of Fluid Modelling of Atmospheric Diffusion*. U.S. Environmental Protection Agency, Office of Air Quality, Planning and Standards, Research Triangle Park, North Carolina, EPA-600/8-81-009, April 1981a.
- EPA, *Guideline for Use of Fluid Modelling to Determine Good Engineering Practice Stack Height*. U.S. Environmental Protection Agency, Office of Air Quality, Planning and Standards, Research Triangle Park, North Carolina, EPA-450/4-81-003, July 1981b.
- EPA, *Compilation of Air Pollutant Emission Factors, Volume I, Stationary Point and Area Sources*, AP-42, Fifth Edition, United States Environmental Protection Agency, Office of Air Quality Planning and Standards, Research Triangle Park, NC, USA, January 1995, Revised October 1996a.
- EPA, *Memorandum: Additional Clarification Regarding Application of Appendix W Modelling Guidance for the 1-hour NO₂ National Ambient Air Quality Standard*, United States Environmental Protection Agency, Air Quality Modelling Group, Research Triangle Park, NC, USA, March 2011.
- Petersen, R.L., J.J. Carter and J.W. LeCompte, "Exhaust Contamination of Hidden vs. Visible Air Intakes," ASHRAE Transactions, Volume 110, Part 1, 2004.
- Ruth, J.H., "Odour Thresholds and Irritation Levels of Several Chemical Substances: A Review," Journal of American Industrial Hygiene Association, Vol. 47, p. A-142, 1986.
- SEPA, "Odour Guidance 2010," Scottish Environmental Protection Agency, Natural Scotland, Scottish Government, Version 1, January 2010.
- Toxicology Excellence for Risk Assessment (TERA), Workplace Environmental Exposure Levels (WEEL): <https://www.tera.org/OARS/WEELs.pdf>; accessed 2019.

Turner, D.B., *Workbook of Atmospheric Dispersion Estimates, Second Edition*. Lewis Publishers, Boca Raton, Florida, 1994.

FIGURES




Figure 1: Plan view of the area modelled on the turntable with building heights




Figure 2: Close up of Victoria House with building tier heights and source and receptor locations




Figure 3: Photographs of the model in the wind tunnel: View from the northeast (top); View from the southeast (bottom).




Figure 3: Photographs of the model in the wind tunnel: View from the southwest (top); View from the northwest (bottom).




Figure 4: Rendering of the wind tunnel used for testing and photograph of the wind-tunnel configuration. Note spires and trip at entrance to test section, and roughness elements on approach fetch to develop a turbulent boundary-layer flow.





Figure 5: Wind rose for the Heathrow Airport anemometer



Joint Probability Distribution of Wind Speed and Wind Direction at the Heathrow Airport (#377209) Anemometer

Category: Maximum Wind Speed (m/s):	1 4.0	2 8.0	3 12.0	4 16.0	5 >16	Totals by Direction (%)
N	3.097	1.349	0.041	0.000	0.000	4.487
NNE	1.814	2.136	0.034	0.000	0.000	3.983
NE	3.428	2.331	0.123	0.002	0.000	5.884
ENE	2.515	2.554	0.300	0.003	0.000	5.372
E	1.888	2.456	0.188	0.003	0.000	4.535
ESE	1.004	1.330	0.135	0.001	0.000	2.469
SE	1.332	1.167	0.131	0.000	0.000	2.629
SSE	1.555	1.707	0.300	0.011	0.000	3.573
S	1.898	2.873	0.786	0.081	0.006	5.644
SSW	2.721	5.683	1.664	0.187	0.010	10.264
SW	2.187	7.630	2.682	0.330	0.023	12.851
WSW	1.696	6.208	2.582	0.272	0.029	10.787
W	3.464	6.291	1.668	0.272	0.030	11.726
WNW	3.891	2.872	0.406	0.047	0.003	7.219
NW	2.864	1.746	0.080	0.001	0.000	4.690
NNW	1.586	1.153	0.035	0.000	0.000	2.773
Calm	1.110					
Totals by Category (%):	38.048	49.485	11.153	1.210	0.101	100
Time Exceeded (%):	61.949	12.463	1.310	0.100	0.000	

Figure 6: Percent time indicated wind speed is exceeded at the Heathrow Airport anemometer

TABLES

Table 1: Full-Scale Extract and Modelling Information

Source Description	Source ID	Initial Height Above Base (m)	Exit Diameter (m)	Exit Temp. (K)	Mass Flow (kg/s)	Volume Flow Rate (m ³ /s)	Exit Velocity (m/s)	Source Orientation	Base Height Above Grade (m)	Comment
Bloomsbury Square Fume Extracts										
Bloomsbury North Fume Stack 1	EF-N1	4.00	0.71	298.2	7.70	6.40	16.10	Vertical	35.5	Main Roof
Bloomsbury North Fume Stack 2	EF-N2	4.00	0.71	298.2	7.70	6.40	16.10	Vertical	35.5	Main Roof
Bloomsbury South Fume Stack 1	EF-S1	4.00	0.71	298.2	7.70	6.40	16.10	Vertical	35.5	Main Roof
Bloomsbury South Fume Stack 2	EF-S2	4.00	0.71	298.2	7.70	6.40	16.10	Vertical	35.5	Main Roof
Updated Fume Extract Design										
Bloomsbury North Fume Stack 1	EF-N1-2	4.00	0.47	298.2	4.33	3.60	20.77	Vertical	35.5	Main Roof
Bloomsbury North Fume Stack 2	EF-N2-2	4.00	0.47	298.2	4.33	3.60	20.77	Vertical	35.5	Main Roof
Bloomsbury South Fume Stack 1	EF-S1-2	4.00	0.47	298.2	4.33	3.60	20.77	Vertical	35.5	Main Roof
Bloomsbury South Fume Stack 2	EF-S2-2	4.00	0.47	298.2	4.33	3.60	20.77	Vertical	35.5	Main Roof
Equipment Sources										
700 kW Standby Diesel Generator	DG-1	4.00	0.30	714.3	1.39	2.77	37.93	Vertical	35.5	Main Roof

Site Parameters:

Scale Reduction:	240	
Grade Elevation (m):	24	78 ft msl
Typical Building Height (m):	40	
Ambient Temperature (°K):	298	Assumed Equal to Indoor Temperature
Anemometer Height (m):	10	Heathrow Airport
Anemometer Surface Roughness (m):	0.03	Heathrow Airport
Site Anemometer Height (m):	10	
Site Surface Roughness (m):	0.70	
1 Percent Wind Speed (m/s):	12.3	Heathrow Airport (Period of Record: 2005 to 2022)

Table 2: Receptor Identifications

Receptor Number	Receptor Identification	Receptor Elevation (m)
1	- North Roof SW Intake	37
2	- North Roof NW Intake	37
3	- North Roof N Intake 1	37
4	- North Roof N Intake 2	37
5	- North Roof NE Intake	37
6	- North Roof SE Intake	37
7	- South Roof NE Intake	37
8	- South Roof SE Intake	37
9	- South Roof S Intake 1	37
10	- South Roof S Intake 2	37
11	- South Roof SW Intake	37
12	- South Roof NW Intake	37
13	- Ammenity Terrace Pedestrian	29
14	- NW Façade Intake 1	16
15	- NW Façade Intake 2	16
16	- NE Façade Intake 1	16
17	- NE Façade Intake 2	16
18	- SE Façade Intake 1	16
19	- SE Façade Intake 2	16
20	- SW Façade Intake 1	16
21	- SW Façade Intake 2	16
22	- Bloomsbury Square Building 1	13.5
23	- Bloomsbury Place Building 1	12.5
24	- Bloomsbury Place Building 2	12.5
25	- South Hampton Building 1	18
26	- South Hampton Building 2	15.5
27	- Old Gloucester Building 1	20.5
28	- South Hampton Building 3	19.5
29	- South Hampton Building 4	14.5
30	- Old Gloucester Building 2	13.5

Table 2: Receptor Identifications

Receptor Number	Receptor Identification	Receptor Elevation (m)
31	- Old Gloucester Building 3	15.5
32	- South Hampton Building 5	18.5
33	- NYX Hotel Terrace 1	35.5
34	- NYX Hotel Terrace 2	35.5
35	- NYX Hotel Terrace 3	35.5
36	- Theobalds Building 1	20
37	- Theobalds Building 2	20
38	- Theobalds Building 3	13
39	- Theobalds Building 4	14
40	- Bloomsbury Square Building 2	14.5
41	- Bloomsbury Square Building 3	14.5
42	- Bloomsbury Square Building 4	14.5
43	- Bloomsbury Square Park	1.5
44	- Bloomsbury Square Building 5	13.5
45	- Level 9 N Intake (Removed)	44
46	- Level 8 N Intake (Removed)	39.5
47	- Level 8 and 9 Intake	44

Table 3: Summary of Normalized Concentration Criteria

Source Type	Design Criteria Type (µg/m³) / (g/s)	Basis for Design Criteria ⁽¹⁾
Victoria House Laboratory Fume Extracts	Health/Odor 400	ASHRAE (2019) example criterion for an accidental spill in a fume hood
Equipment Sources 700 kW Standby Diesel Generator	Health (ACGIH) 4,580 Health (OSHA) 36,161 Odour (Standard) 181 Odour (Filtered) 903	Health limit associated with NO2 emissions Health limit associated with NO2 emissions 1:2000 odor dilution threshold for diesel exhaust 1:400 odor dilution threshold for filtered diesel exhaust

Note:

1) See Section 2 for detailed discussion.

Table 4: Test Plan, Normalized Concentration Results and Percent Time the Design Criteria may be Exceeded for Each Source/Receptor Combination Evaluated in the Wind Tunnel

Run #	Source ID	Stack Height Above Base (m)	Receptor Identification	Wind Direction (Deg.)	Wind Speed (m/s)	(1) Max Normalized WT-Measured Concentration (µg/m³)/(g/s)	(2) Design Criteria (µg/m³)/(g/s)	(3) Design Criteria Achieved?	(4) Approximate Percent Time Design Criteria May Be Exceeded
Bloomsbury Square Fume Extracts									
Bloomsbury North Fume Stack 1									
Source Base Height: 35.5 m (Main Roof)									
(6.4 m³/s @ 16.1 m/s)							ASHRAE		
101	EF-N1	4.0	2 - North Roof NW Intake	120	12.3	673	400	No	0.2%
102	EF-N1	4.0	3 - North Roof N Intake 1	170	14.1	154	400	Yes	-
103	EF-N1	4.0	5 - North Roof NE Intake	200	12.3	203	400	Yes	-
104	EF-N1	4.0	6 - North Roof SE Intake	270	16.2	184	400	Yes	-
175	EF-N1	4.0	7 - South Roof NE Intake	300	12.3	227	400	Yes	-
106	EF-N1	4.0	8 - South Roof SE Intake	300	9.3	297	400	Yes	-
107	EF-N1	4.0	45 - Level 9 N Intake (Removed)	340	9.3	1,141	400	No	1.8%
108	EF-N1	4.0	10 - South Roof S Intake 2	320	9.3	150	400	Yes	-
109	EF-N1	4.0	11 - South Roof SW Intake	330	12.3	385	400	Yes	-
110	EF-N1	4.0	12 - South Roof NW Intake	320	14.1	499	400	No	0.1%
111	EF-N1	4.0	15 - NW Façade Intake 2	30	12.3	39	400	Yes	-
112	EF-N1	4.0	16 - NE Façade Intake 1	210	16.2	1	400	Yes	-
113	EF-N1	4.0	23 - Bloomsbury Place Building 1	110	21.4	4	400	Yes	-
114	EF-N1	4.0	43 - Bloomsbury Square Park	50	5.3	41	400	Yes	-
115	EF-N1	4.0	46 - Level 8 N Intake (Removed)	305	16.2	982	400	No	1.0%
116	EF-N1	4.0	1 - North Roof SW Intake	320	16.2	282	400	Yes	-
Location Sensitivity Testing									
(6.4 m³/s @ 16.1 m/s)									
141	EF-N2	4.0	2 - North Roof NW Intake	120	12.3	644	400	No	0.4%
142	EF-N2	4.0	12 - South Roof NW Intake	320	12.3	464	400	No	0.0%
143	EF-N2	4.0	45 - Level 9 N Intake (Removed)	340	12.3	1,148	400	No	2.1%
Simulated Runs - Desktop Evaluation of Updated Design									
(3.6 m³/s @ 20.77 m/s)									
101B	EF-N1-2	4.0	2 - North Roof NW Intake	120	12.3	673	400	No	0.2%
141B	EF-N2-2	4.0	2 - North Roof NW Intake	120	12.3	644	400	No	0.4%

Table 4: Test Plan, Normalized Concentration Results and Percent Time the Design Criteria may be Exceeded for Each Source/Receptor Combination Evaluated in the Wind Tunnel

Run #	Source ID	Stack Height Above Base (m)	Receptor Identification	Wind Direction (Deg.)	Wind Speed (m/s)	(1) Max Normalized WT-Measured Concentration ($\mu\text{g}/\text{m}^3$)/(g/s)	(2) Design Criteria ($\mu\text{g}/\text{m}^3$)/(g/s)	(3) Design Criteria Achieved?	(4) Approximate Percent Time Design Criteria May Be Exceeded
Bloomsbury Square Fume Extracts									
Bloomsbury South Fume Stack 1									
Source Base Height: 35.5 m (Main Roof)									
(6.4 m ³ /s @ 16.1 m/s)							ASHRAE		
201	EF-S1	4.0	1 - North Roof SW Intake	150	14.1	489	400	No	0.0%
202	EF-S1	4.0	2 - North Roof NW Intake	140	7.0	420	400	No	0.2%
203	EF-S1	4.0	11 - South Roof SW Intake	350	12.3	601	400	No	0.3%
204	EF-S1	4.0	12 - South Roof NW Intake	10	14.1	417	400	No	0.0%
205	EF-S1	4.0	34 - NYX Hotel Terrace 2	240	7.0	272	400	Yes	-
206	EF-S1	-4.0	45 - Level 9 N Intake (Removed)	160	7.0	597	400	No	1.5%
207	EF-S1	-4.0	46 - Level 8 N Intake (Removed)	160	12.3	526	400	No	1.0%
208	EF-S1	4.0	8 - South Roof SE Intake	260	12.3	226	400	Yes	-
209	EF-S1	4.0	9 - South Roof S Intake 1	300	12.3	146	400	Yes	-
Simulated Runs - Desktop Evaluation of Updated Design									
(3.6 m ³ /s @ 20.77 m/s)									
203B	EF-S1-2	4.0	11 - South Roof SW Intake	350	12.3	601	400	No	0.3%

Notes:

- 1) The maximum normalized concentration (C/m) measured in the wind tunnel for the specific source/receptor pair.
- 2) The maximum acceptable C/m for each specific source, based on criteria discussed in Section 2.
- 3) "Yes" if (1) < (2) or "No" if (1) > (2).
- 4) Approximate percentage of time for which the prescribed emission scenario may produce concentrations greater than (2), based on a curve fit to all data collected for the specific source/receptor pair and the local wind frequency distribution.

Table 5: Predicted Normalized Concentrations as a Function of String Line Distance for the Proposed Generator

Run #	Source ID	Description of Air Quality Impact Scenario Evaluated	Volume Flow Rate Q_e (m ³ /s)	Exit Diameter d_e (m)	Exit Velocity V_e (m/s)	String Line Distance S (m)	PREDICTED MAX Concentration C/m ($\mu\text{g}/\text{m}^3$)/(g/s)
700 kW Standby Diesel Generator (5862 cfm @ 7464 fpm)							
901	DG-1	Seperation distance to meet Health (ACGIH/OSHA)	2.77	0.30	37.93	4.4	4,580.0
902	DG-1	Seperation distance to meet Odor (Standard)	2.77	0.30	37.93	187	181
903	DG-1	Seperation Distance to meet Odor (Filtered)	2.77	0.30	37.93	37.5	903.0

Table 6: Chemical Fume Hood Normalized Health Limits and Odour Thresholds in Order of Toxicity and Volatility

Substance	CAS#	1 min Lecture Bottle Release / 1 Liter Spill		Limiting Value		Max Volume (mL) for Liquid	
		Health Limit (µg/m³)/(g/s)	Odor Threshold (µg/m³)/(g/s)	Per 1 Liter Spill or 1 min Release (µg/m³)/(g/s)	ASHRAE	gas (g/s)	liquid (mL)
		Gas	Liquid	Gas	Liquid		
Arsine	7784-42-1	0.3		3888.4		0.3	-
Methyl mercaptan	74-93-1	264.3		0.3		0.003	-
Ethyl mercaptan	75-08-1		437.2		0.3	-	0.7
Ethyl acrylate	140-88-5		193981.8		3.1	-	7.8
Nickel carbonyl (as Ni)	13463-39-3		3.6		360.5	-	9.0
Perchloromethyl mercaptan	594-42-3		1741.8		5.7	-	14.3
Sulfur pentafluoride	5714-22-7		6.5		6.5	-	16.2
Chromyl chloride	14977-61-8		6.9		6.9	-	17.2
Chlorine trifluoride	7790-91-2	10.0			10.0	0.95	-
Butyl mercaptan	109-79-5		5263.3		10.8	-	26.9
Osmium tetroxide	20816-12-0		15.5		15.5	-	38.8
Picric acid	88-89-1				20.1	-	50.4
Pentaborane	19624-22-7		21.9		1828.7	-	54.9
Hydrogen sulfide	7783-06-4	3964.8		22.1		0.21	-
Carbon disulfide	75-15-0		12253.0		25.8	-	65
Acetic anhydride	108-24-7		452071.9		27.3	-	-
Chlorine	7782-50-5	191.6		30.6		0.58	-
Acetaldehyde	75-07-0	3737845.4	12758.3	10017.4	34.1	0.001	85.3
Hydrogen selenide	7783-07-5	126.9		36.6		0.35	-
Chloromethyl ether(bis-)	542-88-1		37.7		37.7	-	94.3
Hydrogen fluoride	7664-39-3	607.9	1396.8		40.5	0.38	101
Isopropylamine	75-31-0		8149.5		49.1	-	123
Isopropyl ether	108-20-3		986753.6		53.8	-	135
Methyl isocyanate	624-83-9		65.5		65.5	-	164
Diethylamine	109-89-7		29597.6		104.0	-	260
Cresol (all isomers)	1319-77-3		2559512.3		105.5	-	264
Phosgene	75-44-5	105.7		373.8		105.7	-
Amyl acetate(sec-)	626-38-0		19750987.8		108.4	-	271
Tungsten hexafluoride	7783-82-6	132.2	409.0		132.2	25.0	1,022
Dimethylhydrazine(1,1-)	57-14-7		146.8		22079.3	-	367
Butyl acetate(n-)	123-86-4		5031407.0		165.8	-	-
Diborane	19287-45-7	240.3		2265.5		240.3	0.75
Phosphine	7803-51-2	264.3		685.7		264.3	2.5
Ethylamine	75-04-7	16560.0		287.2		287.2	1.2
Nitrogen dioxide	10102-44-0	297.5		739.2		297.5	4.5
Methyl hydrazine	60-34-4		320.4		12139.2	-	801
Benzyl mercaptan	100-53-8				320.7	-	802
Bromine pentafluoride	7789-30-2		335.7		335.7	-	839
Tetramethyl lead (as Pb)	75-74-1		337.8		337.8	-	845
Butadiene	106-99-0	4652.0		350.2		350.2	2.5
Butylamine	109-73-9		23069.0		367.6	-	-
Bromine	7726-95-6		436.6		953.5	-	919
Dimethylamine	124-40-3	9118.9		479.8		479.8	-
Ethyl ether	60-29-7		430364.0		487.9	-	-
Acrolein	107-02-8		540.7		968.9	-	-
Acetic acid	64-19-7		516651.6		548.1	-	-
Triethylamine	121-44-8		34967.1		558.2	-	-
Methyl styrene(alpha-)	98-83-9		18743772.3		565.2	-	-
Morpholine	110-91-8		1854740.4		690.8	-	-
Diisopropylamine	108-18-9		78187.2		699.7	-	-
Tetranitromethane	509-14-8		706.5		706.5	-	-
Mesityl oxide	141-79-7		1044501.9		711.7	-	-
Methyl methacrylate	80-62-6		2835791.4		800.7	-	-
Fluorine	7782-41-4	819.4		1585.9		819.4	-
Hydrogen bromide	10035-10-6	1308.4	53793.6		881.1	36224.8	-
Sulfur dioxide	7446-09-5	1718.1		933.6		933.6	-
Nitric oxide	10102-43-9	129285.6		944.2		944.2	-
Hydrogen chloride	7647-01-0	1850.2	4440.7		944.3	944.3	-
Methylene chloride	75-09-2		162165.3		981.8	981.8	-
Boron trifluoride	7637-07-2	986.8		1585.9		986.8	-
Germane tetrahydride	7785-65-2	1080.0				1,080.0	-
Ethyl alcohol	64-17-5		25364403.4		1138.7	1,138.7	-
Hydrazine	302-01-2		1153.9		139411.6	1,153.9	-
Ethylene oxide	75-21-8	1321.6		199823.8		1,321.6	-
Dibromo-3-chloropropane(1,2-)	96-12-8		1420.4		8158.6	1,420.4	-
Propyl acetate(n-)	109-60-4		2348473.6		1695.5	1,695.5	-
Tributyl phosphate	126-73-8		1801.5			1,801.5	-
Xylylene	1300-73-8		571244.3		1828.0	1,828.0	-
Phosphorus trichloride	7719-12-2		1881.2			1,881.2	-
Butyl alcohol(n-)	71-36-3		3114476.3		1883.9	1,883.9	-
Iron carbonyl	13463-40-6		1883.9			1,883.9	-
Fluorene	406-90-6		1985.8			1,985.8	-
Chloroprene(beta-)	126-99-8		1997.4			1,997.4	-
Methylamine	74-89-5	6696.0		2102.6		2,102.6	-
Cumene	98-82-8		11289536.2		2411.4	2,411.4	-
Dichloropropane (-1,2)	78-87-5		1037501.0		2449.1	2,449.1	-

Table 6: Chemical Fume Hood Normalized Health Limits and Odour Thresholds in Order of Toxicity and Volatility

Substance	CAS#	1 min Lecture Bottle Release / 1 Liter Spill Health Limit (µg/m³)/(g/s)		Odor Threshold (µg/m³)/(g/s)		Limiting Value Per 1 Liter Spill or 1 min Release (µg/m³)/(g/s)	Max Volume (mL) for Liquid Max Release Rate (g/s) for Gas ASHRAE	
		Gas	Liquid	Gas	Liquid		gas (g/s)	liquid (mL)
Allyl chloride	107-05-1		2454.3		4206.5	2,454.3		
Methyl (n-amy) ketone	110-43-0		18834454.7		2532.8	2,532.8		
Halothane	151-67-7		2635.8			2,635.8		
Toluene	108-88-3		2806478.0		3014.3	3,014.3		
Ethyl acetate	141-78-6		5947095.3		3106.0	3,106.0		
Enflurane	13838-16-9		3293.8			3,293.8		
Xylenes (o-,m-,p-isomers)	1330-20-7		6287488.4		3349.2	3,349.2		
Chloroacetaldehyde	107-20-0		3527.9		3527.9	3,527.9		
Ethyleneimine	151-56-4		3534.0		5354.6	3,534.0		
Styrene, monomer	100-42-5		7530337.5		3767.9	3,767.9		
Nitrogen trifluoride	7783-54-2	3832.6				3,832.6		
Hydrogen cyanide	74-90-8	29610.5		3915.8		3,915.8		
Thionyl chloride	7719-09-7		3959.5			3,959.5		
Ethylene dibromide	106-93-4		4094.1		314424.5	4,094.1		
Nitric acid	7697-37-2		30526.8		4180.1	4,180.1		
Chloroform	67-66-3		4725.8		452145.7	4,725.8		
Methyl iodide	74-88-4		4879.1			4,879.1		
Benzene	71-43-2		5043.1		43456.2	5,043.1		
Ethylmorpholine(n-)	100-74-3		921528.1		5337.8	5,337.8		
Methyl chloride	74-87-3	54713.7		5550.7		5,550.7		
Chloropicrin	76-06-2		5643.2		18204.3	5,643.2		
Phenyl ether (vapor)	101-84-8		37966601.1		5651.8	5,651.8		
Phosphorus oxychloride	10025-87-3		6249.0			6,249.0		
Methyl bromide	74-83-9	7048.5		49840.1		7,048.5		
Boron tribromide	10294-33-4		7056.9			7,056.9		
Cyclohexanone	108-94-1		5640310.3		7159.0	7,159.0		
Acrylonitrile	107-13-1		45032.8		7263.4	7,263.4		
Formic acid	64-18-6		108940.9		7478.1	7,478.1		
Acetone cyanohydrin	75-86-5		7612.4			7,612.4		
Cyanogen	460-19-5	7929.5				7,929.5		
Propyl alcohol(n-)	71-23-8		4490946.1		7930.5	7,930.5		
Carbon tetrachloride	56-23-5		8310.7		168519.5	8,310.7		
Ammonia	7664-41-7	8458.1			78402.4	8,458.1		
Tetrachloroethane(1,1,2,2-)	79-34-5		126456.3		8791.7	8,791.7		
Trichloroethylene	79-01-6		650450.4		8835.0	8,835.0		
Trimethylamine	75-50-3	9515.4				9,515.4		
Acetylene	74-86-2	39781.2		9731.1		9,731.1		
Allyl alcohol	107-18-6		88789.5		10417.1	10,417.1		
Dichloroethylene(1,2-)	540-59-0		1015984.0		11039.8	11,039.8		
Ethylene dichloride	107-06-2		11655.7		153070.2	11,655.7		
Silane	7803-62-5	11880.0				11,880.0		
Amyl acetate(n-)	628-63-7		22333809.3		12283.3	12,283.3		
Pyridine	110-86-1		262584.6		12434.0	12,434.0		
Dioxane	123-91-1		13007.4		101083.1	13,007.4		
Sulfur monochloride	10025-67-9		13018.0			13,018.0		
Nitrobenzene	98-95-3		1124854.7		13941.2	13,941.2		
Ethyl bromide	74-96-4		13974.0		188437.2	13,974.0		
Benzyl chloride	100-44-7		364585.6		15448.3	15,448.3		
Butyl alcohol(sec-)	78-92-2		236181.2		15699.5	15,699.5		
Chloroacetone	78-95-5		15801.3			15,801.3		
Vinyl acetate	108-05-4		17890.1			17,890.1		
Methyl cellosolve	109-86-4		18195.7		150715.2	18,195.7		
Pentyl mercaptan	110-66-7		18420.2			18,420.2		
Methoxyflurane	76-38-0		18882.2			18,882.2		
Propyleneimine	75-55-8		20353.0			20,353.0		
Dichloromono fluoromethane	75-43-4	21145.4				21,145.4		
Furfural	98-01-1		2276607.7		21853.7	21,853.7		
Methylacrylonitrile	126-98-7		22776.0			22,776.0		
Acrylic acid	79-10-7		26387.9			26,387.9		
Glutaraldehyde	111-30-8		28404.0			28,404.0		
Phenyl mercaptan	108-98-5		29971.8			29,971.8		
Formaldehyde (Formalin)	50-00-0		113852.8		30143.0	30,143.0		
Dichloropropene(1,3-)	542-75-6		32077.9			32,077.9		
Tetraethyl lead (as Pb)	78-00-2		32102.7			32,102.7		
Dichloroethylene(1,1-)	75-35-4		33866.1			33,866.1		
Propargyl alcohol	107-19-7		34105.8			34,105.8		
Methyl acrylate	96-33-3		34639.1		115463.5	34,639.1		
Diisobutyl ketone	108-83-8		14109694.0		35938.2	35,938.2		
Nitrous oxide	10024-97-2	36475.8				36,475.8		
Isopropyl acetate	108-21-4		2774295.8		36781.7	36,781.7		
Propylene oxide	75-56-9		51415.0		38102.2	38,102.2		
Chlorobenzene	108-90-7		942806.8		40818.7	40,818.7		
Pentane(n-)	109-66-0		575358.5		44977.8	44,977.8		
Phenylhydrazine	100-63-0		51237.6			51,237.6		
Dichlorobenzene(o-)	95-50-1		18839403.8		52750.3	52,750.3		
Hexyl acetate(sec-)	108-84-9		18885130.5		57258.9	57,258.9		

Table 6: Chemical Fume Hood Normalized Health Limits and Odour Thresholds in Order of Toxicity and Volatility

Substance	CAS#	1 min Lecture Bottle Release / 1 Liter Spill Health Limit (µg/m³)/(g/s)		Odor Threshold (µg/m³)/(g/s)		Limiting Value Per 1 Liter Spill or 1 min Release (µg/m³)/(g/s)	Max Volume (mL) for Liquid Max Release Rate (g/s) for Gas ASHRAE	
		Gas	Liquid	Gas	Liquid		gas (g/s)	liquid (mL)
Methyl cellosolve acetate	110-49-6		58623.9		62170.0	58,623.9		
Cyclohexanol	108-93-0		55277292.6		60286.1	60,286.1		
Ethylene chlorohydrin	107-07-3		68804.8			68,804.8		
Acetone	67-64-1		1421616.4		87822.8	87,822.8		
Tetrahydrofuran	109-99-9		712921.0		88488.1	88,488.1		
Sulfuric acid	7664-93-9		282303.0		94101.0	94,101.0		
Diacetone alcohol	123-42-2		56722494.1		101732.8	101,732.8		
Chlorodiphenyl (42% chlorine)	53469-21-9		107340.8			107,340.8		
Diethylaminoethanol(2-)	100-37-8		108021.2			108,021.2		
Bromoform	75-25-2		109548.7		38707224.4	109,548.7		
Crotonaldehyde	4170-30-3		118518.9			118,518.9		
Methyl formate	107-31-3		118748.9		1583143.2	118,748.9		
Ethylene glycol dinitrate	628-96-6		121384.7			121,384.7		
Benzoyl chloride	98-88-4		122558.9			122,558.9		
Ethoxyethyl acetate(2-)	110-80-5		138315.9			138,315.9		
Vinyl chloride	75-01-4	166292.6				166,292.6		
Epichlorohydrin	106-89-8		175030.2		485521.1	175,030.2		
Isophorone	78-59-1		4675771.0		178974.3	178,974.3		
Methyl (tert-) butyl ether	1634-04-4		188822.2			188,822.2		
Propiolactone(beta-)	57-57-8		192052.2			192,052.2		
Butyl alcohol(tert-)	75-65-0		1334775.6		192879.6	192,879.6		
Propionitrile	107-12-0		193133.2			193,133.2		
Ethyl chloride	75-00-3	209339.2				209,339.2		
Cyclopentadiene	542-92-7		215964.0			215,964.0		
Hydrogen peroxide	7722-84-1		228067.6			228,067.6		
Carbon monoxide	630-08-0	238655.8				238,655.8		
Dichloroethane(1,1-)	75-34-3		486498.4		243401.2	243,401.2		
Chloropentafluoroethane (Freon 115)	76-15-3	250572.7				250,572.7		
Dichloro-1-nitro-ethane(1,1-)	594-72-9		256603.4			256,603.4		
Hexanone(2-)	591-78-6		276386.5			276,386.5		
Ethoxyethyl acetate(2-)	111-15-9		282804.8			282,804.8		
Acetonitrile	75-05-8		310756.3		5987317.4	310,756.3		
Cyclohexane	110-82-7		3456874.0		322192.3	322,192.3		
Nitropropane(1-)	108-03-2		3496707.5		333928.4	333,928.4		
Butyronitrile (n-)	109-74-0		339121.9			339,121.9		
Methyl aniline	100-61-8		345095.6			345,095.6		
Methyl aniline	100-61-8		345095.6			345,095.6		
Ethylendiamine	107-15-3		1047266.8		369441.0	369,441.0		
Chloro-1-nitropropane(1-)	600-25-9		373434.8			373,434.8		
Hexane(n-)	110-54-3		376962.9			376,962.9		
Methyl acetate	79-20-9		545123.4		392033.8	392,033.8		
Methyl alcohol	67-56-1		1015906.5		409552.3	409,552.3		
Dibutyl phosphate	107-66-4		439167.8			439,167.8		
Isopropyl alcohol	67-63-0		5701786.0		490966.3	490,966.3		
Trichloroethane(1,1,2-)	79-00-5		491685.7			491,685.7		
Propionic acid	79-09-4		539492.0			539,492.0		
Ethyl formate	109-94-4		560605.7			560,605.7		
Isoamyl alcohol	123-51-3		1682089.6		608843.9	608,843.9		
Methyl isobutyl carbinol	108-11-2		4967925.0		614098.1	614,098.1		
Butyl glycidyl ether(n-)	2426-08-6		709009.8			709,009.8		
Toluene-2,4-diisocyanate	584-84-9		741896.2		39223103.4	741,896.2		
Phenol	108-95-2				753576.2	753,576.2		
Ethyl benzene	100-41-4		4719962.5		756237.1	756,237.1		
Cyclohexylamine	108-91-8		799247.4			799,247.4		
Nitromethane	75-52-5		810712.0		1351186.7	810,712.0		
Propyl nitrate(n-)	627-13-4		829539.2		1024724.9	829,539.2		
Nitropropane(2-)	79-46-9		860728.0		1069470.7	860,728.0		
Chlorobromomethane	74-97-5		1404492.8		936328.6	936,328.6		
Nicotine	54-11-5		1067121.0			1,067,121.0		
Dimethyl sulfate	77-78-1		1098093.7			1,098,093.7		
Anisidine (o-,p-isomers)	29191-52-4		1123941.7			1,123,941.7		
Trichloropropane(1,2,3-)	96-18-4		1127296.8			1,127,296.8		
Valeraldehyde (n-)	110-62-3		1260714.0			1,260,714.0		
Tetrachloroethylene	127-18-4		2724214.1		1264931.4	1,264,931.4		
Butyl acrylate (n-)	141-32-2		1304542.1			1,304,542.1		
Methyl chloroform	71-55-6		1314804.0		1469473.5	1,314,804.0		
Ethyl silicate	78-10-4		11300929.0		1356437.1	1,356,437.1		
Butoxyethanol	111-76-2		1408165.6			1,408,165.6		
Butoxyethanol	111-76-2		1408165.6			1,408,165.6		
Chlorodiphenyl (54% chlorine)	11097-69-1		1415844.8			1,415,844.8		
Aniline	62-53-3		3767880.8		1507152.3	1,507,152.3		
Difluorodibromomethane	75-61-6	1544400.0				1,544,400.0		
Butanone(2-)	78-93-3		1595926.5			1,595,926.5		
Trichloro-1,2,2-trifluoroethane(1,1,2-)	76-13-1		1641997.1			1,641,997.1		
Hexone	108-10-1		1727415.4			1,727,415.4		
Allyl glycidyl ether	106-92-3		1778360.5		1778360.5	1,778,360.5		

Table 6: Chemical Fume Hood Normalized Health Limits and Odour Thresholds in Order of Toxicity and Volatility

Substance	CAS#	1 min Lecture Bottle Release / 1 Liter Spill		Limiting Value		Max Volume (mL) for Liquid	
		Health Limit (µg/m³)/(g/s)	Odor Threshold (µg/m³)/(g/s)	Per 1 Liter Spill or 1 min Release (µg/m³)/(g/s)	ASHRAE	gas (g/s)	liquid (mL)
		Gas	Liquid	Gas	Liquid		
Toluidine(m-)	108-44-1		1894484.8			1,894,484.8	
Isopropyl glycidyl ether	4016-14-2		2118487.2		12710923.0	2,118,487.2	
Cyclohexene	110-83-8		2126738.4			2,126,738.4	
Heptane(n-)	142-82-5		4145796.9		2166531.4	2,166,531.4	
Diglycidyl ether	2238-07-5		2205808.3		19694717.2	2,205,808.3	
Nitrotoluene, m-isomer	99-08-1		2221977.8			2,221,977.8	
Nitrotoluene, o-isomer	88-72-2		2221977.8			2,221,977.8	
Nitrotoluene, p-isomer	#N/A		2221977.8			2,221,977.8	
Propane	74-98-6	2283700.4		3404339.6		2,283,700.4	
Trichlorobenzene(1,2,4-)	120-82-1		2358828.7			2,358,828.7	
Glycidol	556-52-5		2533107.4			2,533,107.4	
Dichlorodifluoromethane	75-71-8	2616740.1				2,616,740.1	
Cyclopentane	287-92-3		2654330.2			2,654,330.2	
Butyltoluene(p-tert-)	98-51-1		10671004.2		2667751.0	2,667,751.0	
Dimethylformamide	68-12-2		2841373.8		9471246.1	2,841,373.8	
Ethanolamine	141-43-5		5665696.3		2848872.7	2,848,872.7	
Furfuryl alcohol	98-00-0		5646059.9		3014304.6	3,014,304.6	
Bromotrifluoromethane	75-63-8	3018171.8				3,018,171.8	
Methylal	109-87-5		3418594.5			3,418,594.5	
Phosdrin	7786-34-7		3705699.0			3,705,699.0	
Dimethylaniline	121-69-7		3808295.3			3,808,295.3	
Mercury vapor	7439-97-6		3834873.7			3,834,873.7	
Indene	95-13-6		4297333.0			4,297,333.0	
Butyl acetate(tert-)	540-88-5		4354102.2			4,354,102.2	
Methylcyclohexane	108-87-2		10493600.6		4372333.6	4,372,333.6	
Pyrethrum	8003-34-7		4381949.9			4,381,949.9	
Methacrylic acid	79-41-4		4508313.1			4,508,313.1	
Sulfur hexafluoride	2552-62-4	4733920.7				4,733,920.7	
Nitroethane	79-24-3		7075594.7		4763158.2	4,763,158.2	
Ethyl amyl ketone	541-85-5		5113934.8			5,113,934.8	
Dichloroethylether	111-44-4		5348809.7		40660928.1	5,348,809.7	
Dimethyl acetamide	127-19-5		5564221.2		8605675.6	5,564,221.2	
Octane	111-65-9		14146049.7		5651821.1	5,651,821.1	
Dipropyl ketone	123-19-3		5660249.3			5,660,249.3	
Pentanone(2-)	107-87-9		5903587.6			5,903,587.6	
Isobutyl alcohol	78-83-1		6228952.7			6,228,952.7	
Hexylene glycol	107-41-5		6713476.7			6,713,476.7	
Kerosene	8008-20-6		6923480.9			6,923,480.9	
Toluidine(o-)	95-53-4		7577939.3			7,577,939.3	
Phorate	298-02-2		8453578.6			8,453,578.6	
Diethyl ketone	96-22-0		8461272.1			8,461,272.1	
Dichlorvos	62-73-7		9398390.4			9,398,390.4	
Phosphoric acid	7664-38-2		9419701.9			9,419,701.9	
Butyl acetate(sec-)	105-46-4		9433888.2			9,433,888.2	
Tetraethyl pyrophosphate	107-49-3		9549628.8			9,549,628.8	
Formamide	75-12-7		10257008.7			10,257,008.7	
Chlorotoluene(o-)	95-49-8		10483768.8			10,483,768.8	
Ethylene glycol	107-21-1		10635147.3			10,635,147.3	
Turpentine	8006-64-2		22643855.2		10751210.0	10,751,210.0	
Dichlorotetrafluoroethane	76-14-2	12582000.0				12,582,000.0	
Isobutyl acetate	110-19-0		12833143.5			12,833,143.5	
Fluorotrichloromethane	75-69-4	13440000.0				13,440,000.0	
Nitroglycerin	55-63-0		13549549.2			13,549,549.2	
Ethyl butyl ketone	106-35-4		13943963.3			13,943,963.3	
Phenyl ether-bi-phenyl mix (vapor)	8004-13-5		14597700.7			14,597,700.7	
Vinyl toluene	25013-15-4		37721841.7		18743772.3	18,743,772.3	
Naphtha (coal tar)	8030-30-6		20141035.3			20,141,035.3	
Di-sec octyl phthalate	117-81-7		23639712.8			23,639,712.8	
Triethanolamine	102-71-6		26552179.8			26,552,179.8	
Isoamyl acetate	123-92-2		27917261.7			27,917,261.7	
Methylcyclohexanone(o-)	583-60-8		28302762.1			28,302,762.1	
Methylcyclohexanol	25639-42-3		28372934.0		94980619.4	28,372,934.0	
Dichlorophos	141-66-2		29212999.5			29,212,999.5	
Sulfotep	3689-24-5		33727832.9			33,727,832.9	
Phenyl glycidyl ether	122-60-1		36900631.0			36,900,631.0	
Dibutylphthalate	84-74-2		49755522.0			49,755,522.0	
Acetylene tetrabromide	79-27-6		56076790.6			56,076,790.6	
Disulfoton	298-04-4		56151507.6			56,151,507.6	
Acetophenone	98-86-2		56541760.6			56,541,760.6	
Stoddard solvent	8052-41-3		57695674.1			57,695,674.1	
Diazinon	333-41-5		65070309.1			65,070,309.1	
Dimethylphthalate	131-11-3		71302583.9			71,302,583.9	
Dibrom	300-76-5		109031195.2			109,031,195.2	
Parathion	56-38-2		118837639.8		377111443.5	118,837,639.8	
Dipropylene glycol methyl ether	34590-94-8		140151435.1		174799550.8	140,151,435.1	
Triorthocresyl phosphate	78-30-8		375867583.7			375,867,583.7	

Table 6: Chemical Fume Hood Normalized Health Limits and Odour Thresholds in Order of Toxicity and Volatility

Substance	CAS#	1 min Lecture Bottle Release / 1 Liter Spill Health Limit ($\mu\text{g}/\text{m}^3$)/(g/s)		Odor Threshold ($\mu\text{g}/\text{m}^3$)/(g/s)		Limiting Value Per 1 Liter Spill or 1 min Release ($\mu\text{g}/\text{m}^3$)/(g/s)	Max Volume (mL) for Liquid Max Release Rate (g/s) for Gas ASHRAE	
		Gas	Liquid	Gas	Liquid		gas (g/s)	liquid (mL)
Fenthion	55-38-9		569248172.0			569,248,172.0		
Chlorinated diphenyl oxide	55720-99-5		612318112.0			612,318,112.0		
Thioglycolic acid	68-11-1		1142637454.6			1,142,637,454.6		
Malathion	121-75-5		20954845316.1		9429680392.2	9,429,680,392.2		
Ethion	563-12-2		19231891367.9			19,231,891,367.9		

NOTE: See CPP internal document "Simulation and Analysis Techniques for Air Quality Assessments," April 2010 for a description on how an HL is computed from the OEL.

Table 7: Normalized Health Limits and Odour Thresholds Listed for Combustion Source

Health Limits and Odor Thresholds			
	Health (µg/m³)		Odor (µg/m³)
	TWA	STEL	
Diesel Exhaust (dilution):			2,000
CO - ACGIH ⁽¹⁾		229,000	#N/A
NO - NIOSH ⁽¹⁾	30,000	90,000	657
NO ₂ - NIOSH ⁽¹⁾		1,800	4,472
NO ₂ - ACGIH ⁽¹⁾	380	1,140	4,472
NO ₂ - OSHA ⁽¹⁾		9,000	4,472
SO ₂ - ACGIH ⁽¹⁾		13,000	3,832
PM ₁₀ (Inhalable) OSHA ⁽¹⁾	15,000	45,000	#N/A
PM _{2.5} (Respirable) OSHA ⁽¹⁾	5,000	15,000	#N/A
			700kW Diesel Generator
			Tier 2 (2)
Emissions Data			
Input Data:	Energy Input (MMBTU / hr):		
	% sulfur in fuel:		0.05
	Number of vehicles:		
	Vehicle speed (mph):		
	Length of road (miles):		
Output Data:	ated Engine Power Output (kW):		700.00
	Mass Emission Rate (g/s):		1,391.30
	Mass Emission Rate (lb/hr):		11,042.28
	Volume Flow (m³/s):		2.77
Emission Factors:	CO (g/kWhr-DG):		3.50
	NO _x (g/kWhr-DG):		6.40
	SO ₂ (g/kWhr-DG):		0.25
	PM ₁₀ (g/kWhr-DG):		0.200
	PM _{2.5} (g/kWhr-DG):		0.200
Emission Rates:	NO ₂ /NO _x ambient ratio:		0.20
	CO (g/s):		0.68
	NO _x (g/s):		1.24
	NO (g/s):		1.12
	NO ₂ (g/s):		0.25
	SO ₂ (g/s):		0.05
	PM ₁₀ (g/s):		0.04
	PM _{2.5} (g/s):		0.04
Normalized Health Limits and Odor Thresholds			
Health Limits	CO (µg/m³)/(g/s):		336,490
	NO (µg/m³)/(g/s):		80,357
	NIOSH - NO ₂ (µg/m³)/(g/s):		7,232
	ACGIH - NO ₂ (µg/m³)/(g/s):		4,580
	OSHA - NO ₂ (µg/m³)/(g/s):		36,161
	ACGIH - SO ₂ (µg/m³)/(g/s):		271,777
	OSHA - PM ₁₀ (µg/m³)/(g/s):		1,157,143
	OSHA - PM _{2.5} (µg/m³)/(g/s):		385,714
Health Design Criteria (µg/m³)/(g/s):			4,580
OSHA Health Design Criteria (µg/m³)/(g/s):			36,161
Odor Thresholds	Combined Exhaust (µg/m³)/(g/s):		181
	CO (µg/m³)/(g/s):		#N/A
	NO (µg/m³)/(g/s):		587
	NO ₂ (µg/m³)/(g/s):		17,968
	SO ₂ (µg/m³)/(g/s):		80,111
	PM ₁₀ (µg/m³)/(g/s):		#N/A
	PM _{2.5} (µg/m³)/(g/s):		#N/A
Odor Design Criteria (µg/m³)/(g/s):			181

Notes:

- 1) Only applies to Health Limits, Odor Thresholds are referenced in report text.
- 2) Emission factors for all except SO_x from CFR Title 40, Part 89, Table 1 (CFR, 2002).
SO_x emission factor from AP 42 Table 3.4-1 (EPA, 1996).