



EQUIPMENT SCHEDULE

RADIATORS

| Ref | Room Ref | Room Name | Model | Manufacturer | Conn. Size (mmØ) | Height (mm) | Length (mm) | Depth (mm) | Temp. Difference (DegC) | Output (W) | QTY | Water Flow Rate (l/s) | Finish |
|-------------|----------|-------------|---------------------------|--------------|------------------|-------------|-------------|------------|-------------------------|------------|-----|-----------------------|---------------------|
| R-01 | 0B-B03b | Corridor | Galant Horizontal Type 33 | MHS | 15 | 600 | 900 | 155 | 10 | 855 | 1 | 0.020 | Powder Coat RAL9010 |
| R-02 | 0B-B05a | Corridor | Galant Horizontal Type 33 | MHS | 15 | 600 | 800 | 155 | 10 | 760 | 1 | 0.018 | Powder Coat RAL9010 |
| R-03a | 0B-B06 | Gym | Galant Horizontal Type 33 | MHS | 15 | 600 | 900 | 155 | 10 | 855 | 1 | 0.020 | Powder Coat RAL9010 |
| R-03b & 03c | 0B-B06 | Gym | Galant Horizontal Type 33 | MHS | 15 | 600 | 1200 | 155 | 10 | 1140 | 2 | 0.027 | Powder Coat RAL9010 |
| R-04a & 04b | 0B-B07 | Gym | Galant Horizontal Type 33 | MHS | 15 | 600 | 1200 | 155 | 10 | 1140 | 2 | 0.027 | Powder Coat RAL9010 |
| R-05a & 05b | 0B-B11a | Corridor | Galant Horizontal Type 33 | MHS | 15 | 600 | 800 | 155 | 10 | 760 | 2 | 0.018 | Powder Coat RAL9010 |
| R-06 | 0G-G22 | Cleaner | Galant Horizontal Type 33 | MHS | 15 | 900 | 700 | 155 | 10 | 819 | 1 | 0.020 | Powder Coat RAL9010 |
| R-07 | 0G-G02 | Watch Rm | Galant Horizontal Type 33 | MHS | 15 | 500 | 1400 | 155 | 10 | 1045 | 1 | 0.025 | Powder Coat RAL9010 |
| R-08 | 0G-G03 | Reception | Galant Horizontal Type 33 | MHS | 15 | 600 | 1600 | 155 | 10 | 1362 | 1 | 0.032 | Powder Coat RAL9010 |
| R-09a | 0G-G04 | Station Man | Galant Horizontal Type 33 | MHS | 15 | 600 | 1200 | 155 | 10 | 1140 | 1 | 0.027 | Powder Coat RAL9010 |
| R-09b | 0G-G04a | Station Man | Galant Horizontal Type 33 | MHS | 15 | 600 | 1200 | 155 | 10 | 1140 | 1 | 0.027 | Powder Coat RAL9010 |
| R-10 | 0G-G06 | Acc WC | Ambiguard Style B c/w E33 | MHS | 15 | 865 | 800 | 235 | 10 | 448 | 1 | 0.011 | Powder Coat RAL9010 |
| R-11a | 0G-G07 | Corridor | Galant Horizontal Type 33 | MHS | 15 | 600 | 500 | 155 | 10 | 475 | 1 | 0.011 | Powder Coat RAL9010 |
| R-11b | 0G-G07 | Corridor | Galant Horizontal Type 33 | MHS | 15 | 600 | 1000 | 155 | 10 | 950 | 1 | 0.023 | Powder Coat RAL9010 |
| R-11c | 0G-G07a | Corridor | Galant Horizontal Type 33 | MHS | 15 | 600 | 1600 | 155 | 10 | 1362 | 1 | 0.032 | Powder Coat RAL9010 |
| R-11d | 0G-G07a | Corridor | Galant Horizontal Type 33 | MHS | 15 | 600 | 1000 | 155 | 10 | 950 | 1 | 0.023 | Powder Coat RAL9010 |
| R-12 | 0G-G10 | BA Room | Galant Horizontal Type 33 | MHS | 15 | 600 | 1400 | 155 | 10 | 1330 | 1 | 0.032 | Powder Coat RAL9010 |
| R-13a | 0G-G13 | Rec Room | Galant Horizontal Type 33 | MHS | 15 | 900 | 500 | 155 | 10 | 585 | 1 | 0.014 | Powder Coat RAL9010 |
| R-13b | 0G-G13 | Rec Room | Galant Horizontal Type 33 | MHS | 15 | 350 | 1200 | 155 | 10 | 767 | 1 | 0.018 | Powder Coat RAL9010 |



EQUIPMENT SCHEDULE

RADIATORS

| Ref | Room Ref | Room Name | Model | Manufacturer | Conn. Size (mmØ) | Height (mm) | Length (mm) | Depth (mm) | Temp. Difference (DegC) | Output (W) | QTY | Water Flow Rate (l/s) | Finish |
|------------------|----------|--------------|---------------------------|--------------|------------------|-------------|-------------|------------|-------------------------|------------|-----|-----------------------|---------------------|
| R-13c | 0G-G13 | Rec Room | Galant Horizontal Type 33 | MHS | 15 | 350 | 1200 | 155 | 10 | 767 | 1 | 0.018 | Powder Coat RAL9010 |
| R-14 | 0G-G14 | Mess | Galant Horizontal Type 33 | MHS | 15 | 500 | 1800 | 155 | 10 | 1343 | 1 | 0.032 | Powder Coat RAL9010 |
| R-15a, 15b & 15c | 0G-G17 | Fire Gear St | Galant Horizontal Type 33 | MHS | 15 | 600 | 1600 | 155 | 10 | 1519 | 3 | 0.036 | Powder Coat RAL9010 |
| R-16 | 0G-G18 | Male WC | Galant Horizontal Type 33 | MHS | 15 | 600 | 1000 | 155 | 10 | 950 | 1 | 0.023 | Powder Coat RAL9010 |
| R-17 | 01-101a | Corridor | Galant Horizontal Type 33 | MHS | 15 | 600 | 1000 | 155 | 10 | 950 | 1 | 0.023 | Powder Coat RAL9010 |
| R-18 | 01-102 | Uni Dorm | Galant Horizontal Type 33 | MHS | 15 | 350 | 1400 | 155 | 10 | 999 | 1 | 0.024 | Powder Coat RAL9010 |
| R-19 | 01-103 | Unisex Dorm | Galant Horizontal Type 33 | MHS | 15 | 350 | 1600 | 155 | 10 | 1141 | 1 | 0.027 | Powder Coat RAL9010 |
| R-20 | 01-104 | Unisex Dorm | Galant Horizontal Type 33 | MHS | 15 | 350 | 1400 | 155 | 10 | 999 | 1 | 0.024 | Powder Coat RAL9010 |
| R-21 | 01-105 | Unisex Dorm | Galant Horizontal Type 33 | MHS | 15 | 350 | 1600 | 155 | 10 | 1141 | 1 | 0.027 | Powder Coat RAL9010 |
| R-22 | 01-106 | Unisex Dorm | Galant Horizontal Type 33 | MHS | 15 | 350 | 1600 | 155 | 10 | 1141 | 1 | 0.027 | Powder Coat RAL9010 |
| R-23 | 01-107 | WC Lobby | Galant Horizontal Type 33 | MHS | 15 | 600 | 600 | 155 | 10 | 570 | 1 | 0.014 | Powder Coat RAL9010 |
| R-24 | 01-108 | Uni Shr | Galant Horizontal Type 33 | MHS | 15 | 600 | 800 | 155 | 10 | 760 | 1 | 0.018 | Powder Coat RAL9010 |
| R-25a | 01-109 | Male Dorm | Galant Horizontal Type 33 | MHS | 15 | 600 | 1000 | 155 | 10 | 950 | 1 | 0.023 | Powder Coat RAL9010 |
| R-25b | 01-109 | Male Dorm | Galant Horizontal Type 33 | MHS | 15 | 350 | 1400 | 155 | 10 | 999 | 1 | 0.024 | Powder Coat RAL9010 |
| R-26a | 01-109a | Male Dorm | Galant Horizontal Type 33 | MHS | 15 | 350 | 1800 | 155 | 10 | 1284 | 1 | 0.031 | Powder Coat RAL9010 |
| R-26b | 01-109a | Male Dorm | Galant Horizontal Type 33 | MHS | 15 | 350 | 1800 | 155 | 10 | 1284 | 1 | 0.031 | Powder Coat RAL9010 |
| R-27a | 01-109b | Unisex Dorm | Galant Horizontal Type 33 | MHS | 15 | 350 | 1600 | 155 | 10 | 1141 | 1 | 0.027 | Powder Coat RAL9010 |
| R-27b | 01-109b | Unisex Dorm | Galant Horizontal Type 33 | MHS | 15 | 350 | 1600 | 155 | 10 | 1141 | 1 | 0.027 | Powder Coat RAL9010 |
| R-28 | 01-110a | Uni WC | Galant Horizontal Type 33 | MHS | 15 | 600 | 600 | 155 | 10 | 570 | 1 | 0.014 | Powder Coat RAL9010 |
| R-29 | 02-201a | Corridor | Galant Horizontal Type 33 | MHS | 15 | 600 | 500 | 155 | 10 | 475 | 1 | 0.011 | Powder Coat RAL9010 |
| R-30a | 02-202 | Fem Dorm | Galant Horizontal Type 33 | MHS | 15 | 350 | 1000 | 155 | 10 | 713 | 1 | 0.017 | Powder Coat RAL9010 |



EQUIPMENT SCHEDULE

RADIATORS

| Ref | Room Ref | Room Name | Model | Manufacturer | Conn. Size (mmØ) | Height (mm) | Length (mm) | Depth (mm) | Temp. Difference (DegC) | Output (W) | QTY | Water Flow Rate (l/s) | Finish |
|-------------|----------|-------------|---------------------------|--------------|------------------|-------------|-------------|------------|-------------------------|------------|-----|-----------------------|---------------------|
| R-30b | 02-202a | Unisex Chg | Galant Horizontal Type 33 | MHS | 15 | 350 | 1200 | 155 | 10 | 856 | 1 | 0.020 | Powder Coat RAL9010 |
| R-31 | 02-203 | Unisex Chg | Galant Horizontal Type 33 | MHS | 15 | 350 | 1600 | 155 | 10 | 1141 | 1 | 0.027 | Powder Coat RAL9010 |
| R-32 | 02-204 | Station Man | Galant Horizontal Type 33 | MHS | 15 | 350 | 1600 | 155 | 10 | 1141 | 1 | 0.027 | Powder Coat RAL9010 |
| R-33 | 02-205 | Uni Shr | Galant Horizontal Type 33 | MHS | 15 | 600 | 600 | 155 | 10 | 570 | 1 | 0.014 | Powder Coat RAL9010 |
| R-34 | 02-206a | Fem WC | Galant Horizontal Type 33 | MHS | 15 | 600 | 800 | 155 | 10 | 760 | 1 | 0.018 | Powder Coat RAL9010 |
| R-35a | 02-207 | Male Shr | Galant Horizontal Type 33 | MHS | 15 | 600 | 600 | 155 | 10 | 570 | 1 | 0.014 | Powder Coat RAL9010 |
| R-35b | 02-207 | Male Shr | Galant Horizontal Type 33 | MHS | 15 | 600 | 1000 | 155 | 10 | 950 | 1 | 0.023 | Powder Coat RAL9010 |
| R-36a | 02-208 | Unisex Chg | Galant Horizontal Type 33 | MHS | 15 | 600 | 1400 | 155 | 10 | 1330 | 1 | 0.032 | Powder Coat RAL9010 |
| R-36b | 02-208 | Unisex Chg | Galant Horizontal Type 33 | MHS | 15 | 350 | 1400 | 155 | 10 | 999 | 1 | 0.024 | Powder Coat RAL9010 |
| R-36c | 02-208 | Unisex Chg | Galant Horizontal Type 33 | MHS | 15 | 350 | 1400 | 155 | 10 | 999 | 1 | 0.024 | Powder Coat RAL9010 |
| R-36d | 02-208 | Unisex Chg | Galant Horizontal Type 33 | MHS | 15 | 350 | 1600 | 155 | 10 | 1141 | 1 | 0.027 | Powder Coat RAL9010 |
| R-36e | 02-208a | Unisex Chg | Galant Horizontal Type 33 | MHS | 15 | 350 | 1600 | 155 | 10 | 1141 | 1 | 0.027 | Powder Coat RAL9010 |
| R-36f | 02-208a | Unisex Chg | Galant Horizontal Type 33 | MHS | 15 | 350 | 1600 | 155 | 10 | 1141 | 1 | 0.027 | Powder Coat RAL9010 |
| R-37 | 02-211 | Unisex Chg | Galant Horizontal Type 33 | MHS | 15 | 350 | 1400 | 155 | 10 | 999 | 1 | 0.024 | Powder Coat RAL9010 |
| R-38a | 03-304 | Lecture | Galant Horizontal Type 33 | MHS | 15 | 350 | 800 | 155 | 10 | 571 | 1 | 0.014 | Powder Coat RAL9010 |
| R-38b | 03-304 | Lecture | Galant Horizontal Type 33 | MHS | 15 | 350 | 1600 | 155 | 10 | 1141 | 1 | 0.027 | Powder Coat RAL9010 |
| R-39a & 39b | 03-305 | Station Man | Galant Horizontal Type 33 | MHS | 15 | 350 | 1600 | 155 | 10 | 1141 | 2 | 0.027 | Powder Coat RAL9010 |

Project Name: LFB - Euston Fire Station



FRANKHAM

Project Number: 522223

Date: November 2022

History: A

EQUIPMENT SCHEDULE

RADIATORS

| Ref | Room Ref | Room Name | Model | Manufacturer | Conn. Size (mmØ) | Height (mm) | Length (mm) | Depth (mm) | Temp. Difference (DegC) | Output (W) | QTY | Water Flow Rate (l/s) | Finish |
|------|----------|--------------|---------------------------|--------------|------------------|-------------|-------------|------------|-------------------------|------------|-----|-----------------------|---------------------|
| R-40 | 03-306 | Gen. Store | Galant Horizontal Type 33 | MHS | 15 | 350 | 800 | 155 | 10 | 571 | 1 | 0.014 | Powder Coat RAL9010 |
| R-41 | 03-307 | Unisex Chg | Galant Horizontal Type 33 | MHS | 15 | 600 | 600 | 155 | 10 | 570 | 1 | 0.014 | Powder Coat RAL9010 |
| R-42 | 03-308 | Kitchen Prep | Galant Horizontal Type 33 | MHS | 15 | 600 | 600 | 155 | 10 | 570 | 1 | 0.014 | Powder Coat RAL9010 |
| R-43 | 03-309 | Uni Shr/WC | Galant Horizontal Type 33 | MHS | 15 | 600 | 1000 | 155 | 10 | 950 | 1 | 0.023 | Powder Coat RAL9010 |
| R-44 | 03-310 | Corridor | Galant Horizontal Type 33 | MHS | 15 | 600 | 1400 | 155 | 10 | 1330 | 1 | 0.032 | Powder Coat RAL9010 |

Notes:

- 1 - All equipment has been selected on MHS Galant Horizontal Range of radiators. Contact Dan Davis on 07881 225 135 or ddavis@mhsradiators.co.uk
- 2 - Finish: powder coat to RAL 9016 colour as agreed with the Client.
- 3 - Maximum pressure drop 2 kPa.
- 4 - Refer to specification for materials and workmanship clauses.