

Project name

1MS (Be Green)

As designed

Date: Tue Apr 25 09:14:42 2023

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.19

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.19

BRUKL compliance module version: v6.1.e.0

Foundation area [m²]: 975.66The CO₂ emission and primary energy rates of the building must not exceed the targets

Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum	3.21
Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum	2.51
Target primary energy rate (TPER), kWh _{PE} /m ² annum	35.15
Building primary energy rate (BPER), kWh _{PE} /m ² annum	27.13
Do the building's emission and primary energy rates exceed the targets?	BER =< TER BPER =< TPER

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U _{a-Limit}	U _{a-Calc}	U _{i-Calc}	First surface with maximum value
Walls*	0.26	0.12	0.12	G1000799:Surf[0]
Floors	0.18	0.18	0.18	G2000190:Surf[1]
Pitched roofs	0.16	-	-	No pitched roofs in building
Flat roofs	0.18	0.18	0.18	G10007CA:Surf[0]
Windows** and roof windows	1.6	1.43	1.45	L0000040:Surf[1]
Rooflights***	2.2	-	-	No roof lights in building
Personnel doors [^]	1.6	-	-	No personnel doors in building
Vehicle access & similar large doors	1.3	-	-	No vehicle access doors in building
High usage entrance doors	3	-	-	No high usage entrance doors in building

U_{a-Limit} = Limiting area-weighted average U-values [W/(m²K)]
U_{a-Calc} = Calculated area-weighted average U-values [W/(m²K)]
U_{i-Calc} = Calculated maximum individual element U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.
** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.
[^] For fire doors, limiting U-value is 1.8 W/m²K
NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m ³ /(h.m ²) at 50 Pa	8	3

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	NO
Whole building electric power factor achieved by power factor correction	>0.95

1- Radiators + Nat Vent

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	3.5	-	0.2	-	-
Standard value	2.5*	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					

2- DX Split

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	3.5	6.7	-	-	-
Standard value	2.5*	5	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					

3- Radiators + Zonal Ext

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	3.5	-	0.2	-	-
Standard value	2.5*	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					

4- Radiators + Zonal HR

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	3.5	-	0.2	-	0.9
Standard value	2.5*	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					

5- VRF + Central HR

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	3.5	4	0	1.5	0.8
Standard value	2.5*	N/A	N/A	2^	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

6- Retail VRF

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	3.5	4	0	1.1	0.9
Standard value	2.5*	N/A	N/A	2^	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

1- DHW

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	3.5	0.002
Standard value	2*	N/A

* Standard shown is for all types except absorption and gas engine heat pumps.

2- Retail DHW

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	1	-
Standard value	1	N/A

Zone-level mechanical ventilation, exhaust, and terminal units

ID	System type in the Approved Documents
A	Local supply or extract ventilation units
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal balanced supply and extract ventilation system
E	Local balanced supply and extract ventilation units
F	Other local ventilation units
G	Fan assisted terminal variable air volume units
H	Fan coil units
I	Kitchen extract with the fan remote from the zone and a grease filter

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

Zone name	ID of system type	SFP [W/(l/s)]									HR efficiency	
		A	B	C	D	E	F	G	H	I	Zone	Standard
	Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1		
G-1 Comms		-	-	0.3	-	-	-	-	-	-	-	N/A
G-1 Comms		-	-	0.3	-	-	-	-	-	-	-	N/A
G-1 Cycle Store		-	-	0.3	-	-	-	-	-	-	-	N/A
G-1 Cycle Store		-	-	0.3	-	-	-	-	-	-	-	N/A
G-2 Drying Room		-	-	-	1.1	-	-	-	-	-	-	N/A
G-2 FM Office		-	-	-	1.1	-	-	-	-	-	-	N/A
G-2 Office Showers		-	-	-	1.1	-	-	-	-	-	-	N/A
G-2 Office Showers		-	-	-	1.1	-	-	-	-	-	-	N/A
G-2 Refuse Store		-	-	0.3	-	-	-	-	-	-	-	N/A
G-2 Refuse Store		-	-	0.3	-	-	-	-	-	-	-	N/A
G-2 Refuse Store		-	-	0.3	-	-	-	-	-	-	-	N/A
G-2 Refuse Store		-	-	0.3	-	-	-	-	-	-	-	N/A
G-2 Shower		-	-	-	1.1	-	-	-	-	-	-	N/A
G-2 Shower		-	-	-	1.1	-	-	-	-	-	-	N/A
G-2 Shower		-	-	-	1.1	-	-	-	-	-	-	N/A
G-2 Shower Vent		-	-	-	1.1	-	-	-	-	-	-	N/A
G-2 Showers		-	-	-	1.1	-	-	-	-	-	-	N/A
G-2 Showers		-	-	-	1.1	-	-	-	-	-	-	N/A
G-2 Staff Room		-	-	-	1.1	-	-	-	-	-	-	N/A
G-2 Unisex Shower		-	-	-	1.1	-	-	-	-	-	-	N/A
G-2 WC		-	-	0.3	-	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I	Zone	Standard
	Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1		
G-2 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
G-2 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
G-2 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
G-2 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
G-2 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
G-2 WC Extract		-	-	0.3	-	-	-	-	-	-	-	N/A
L-00 Cycle Store Entrance		-	-	0.3	-	-	-	-	-	-	-	N/A
L-00 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-00 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-01 Cleaner		-	-	0.3	-	-	-	-	-	-	-	N/A
L-01 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-02 Cleaner		-	-	0.3	-	-	-	-	-	-	-	N/A
L-02 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-03 Cleaner		-	-	0.3	-	-	-	-	-	-	-	N/A
L-03 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-04 Cleaner		-	-	0.3	-	-	-	-	-	-	-	N/A
L-04 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-05 Cleaner		-	-	0.3	-	-	-	-	-	-	-	N/A
L-05 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-06 Cleaner		-	-	0.3	-	-	-	-	-	-	-	N/A
L-06 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-07 Cleaner		-	-	0.3	-	-	-	-	-	-	-	N/A
L-07 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-08 Cleaner		-	-	0.3	-	-	-	-	-	-	-	N/A
L-08 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-09 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-10 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-11 Cleaner		-	-	0.3	-	-	-	-	-	-	-	N/A
L-11 Store		-	-	0.3	-	-	-	-	-	-	-	N/A
L-11 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-11 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-11 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-12 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-13 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-14 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-15 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-16 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-17 WC		-	-	0.3	-	-	-	-	-	-	-	N/A
L-18 WC		-	-	0.3	-	-	-	-	-	-	-	N/A

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
	Standard value	95	80	0.3
G-1 Circulation		110	-	-

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
	Standard value	95	80	0.3
G-1 Comms		140	-	-
G-1 Comms		140	-	-
G-1 Cycle Store		140	-	-
G-1 Cycle Store		140	-	-
G-1 Staircase		110	-	-
G-2 AHU Plant		140	-	-
G-2 AHU Plant		140	-	-
G-2 Basement Ventilation		140	-	-
G-2 Circulation		110	-	-
G-2 Circulation		110	-	-
G-2 Circulation		110	-	-
G-2 Circulation		110	-	-
G-2 Circulation		110	-	-
G-2 Circulation		110	-	-
G-2 Circulation		110	-	-
G-2 Circulation		110	-	-
G-2 Circulation		110	-	-
G-2 Circulation		110	-	-
G-2 Circulation		110	-	-
G-2 Circulation		110	-	-
G-2 Circulation		110	-	-
G-2 Cold Water Storage		140	-	-
G-2 Drying Room		110	-	-
G-2 FM Office		110	-	-
G-2 Heating Plant		140	-	-
G-2 Loading Bay		110	-	-
G-2 Office Showers		110	-	-
G-2 Office Showers		110	-	-
G-2 Refuse Store		140	-	-
G-2 Refuse Store		140	-	-
G-2 Refuse Store		140	-	-
G-2 Refuse Store		140	-	-
G-2 Shower		110	-	-
G-2 Shower		110	-	-
G-2 Shower		110	-	-
G-2 Shower Vent		110	-	-
G-2 Showers		110	-	-
G-2 Showers		110	-	-
G-2 Sprinkler Plant		140	-	-
G-2 Sprinkler Plant		140	-	-
G-2 Staff Room		110	-	-
G-2 Staircase		110	-	-
G-2 Staircase		110	-	-
G-2 Storage		140	-	-
G-2 Switch Room		140	-	-

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
	Standard value	95	80	0.3
G-2 Unisex Shower		110	-	-
G-2 WC		110	-	-
G-2 WC		110	-	-
G-2 WC		110	-	-
G-2 WC		110	-	-
G-2 WC		110	-	-
G-2 WC		110	-	-
G-2 WC Extract		110	-	-
L-00 BOH		110	-	-
L-00 Circulation		110	-	-
L-00 Circulation		110	-	-
L-00 Circulation		110	-	-
L-00 Circulation		110	-	-
L-00 Circulation		110	-	-
L-00 Circulation		110	-	-
L-00 Circulation		110	-	-
L-00 Circulation		110	-	-
L-00 Circulation		110	-	-
L-00 Cycle Store Entrance		110	-	-
L-00 Flexible Class E (cafe/workspace)		110	-	-
L-00 Flexible Class E		110	80	1.5
L-00 Flexible Class E		110	80	1.5
L-00 Flexible Class E		110	80	1.5
L-00 Flexible Class E		110	80	1.5
L-00 Office Lobby		110	80	1.35
L-00 Post Room		110	-	-
L-00 Security & Fire Risk		110	-	-
L-00 WC		110	-	-
L-00 WC		110	-	-
L-01 Circulation		110	-	-
L-01 Circulation		110	-	-
L-01 Circulation		110	-	-
L-01 Circulation		110	-	-
L-01 Circulation		110	-	-
L-01 Circulation		110	-	-
L-01 Cleaner		110	-	-
L-01 Office		140	-	-
L-01 WC		110	-	-
L-02 Cleaner		110	-	-
L-02 Circulation		110	-	-
L-02 Circulation		110	-	-
L-02 Circulation		110	-	-
L-02 Circulation		110	-	-