

241 The Broadway
London
SW19 1SD

2220567 300 Grays Inn Road
Proposed Runoff Volume



Date 01/06/2023
File

Designed by HH
Checked by

Innovyze

Source Control 2020.1.3

Summary of Results for 100 year Return Period

Half Drain Time exceeds 7 days.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Control (l/s)	Max Σ Outflow (l/s)	Max Volume (m³)	Status
360 min Summer	0.183	0.183	0.0	0.0	0.0	36.5	O K
360 min Winter	0.204	0.204	0.0	0.0	0.0	40.9	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)
360 min Summer	10.404	0.0	0.0	364
360 min Winter	10.404	0.0	0.0	364

241 The Broadway
London
SW19 1SD

2220567 300 Grays Inn Road
Proposed Runoff Volume



Date 01/06/2023

Designed by HH

File

Checked by

Innovyze

Source Control 2020.1.3

Rainfall Details

Rainfall Model	FSR	Winter Storms	Yes
Return Period (years)	100	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	20.900	Shortest Storm (mins)	360
Ratio R	0.442	Longest Storm (mins)	360
Summer Storms	Yes	Climate Change %	+0

Time Area Diagram

Total Area (ha) 0.078

Time (mins) Area
From: To: (ha)

0 4 0.078

241 The Broadway
London
SW19 1SD

2220567 300 Grays Inn Road
Proposed Runoff Volume



Date 01/06/2023

Designed by HH

File

Checked by

Innovyze

Source Control 2020.1.3

Model Details

Storage is Online Cover Level (m) 5.000

Cellular Storage Structure

Invert Level (m) 0.000 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00000 Porosity 1.00
Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	200.0	200.0	1.000	200.0	256.6	1.001	0.0	256.6

Pump Outflow Control

Invert Level (m) 0.000

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	0.0000	0.700	0.0000	1.300	0.0000	1.900	0.0000	2.500	0.0000
0.200	0.0000	0.800	0.0000	1.400	0.0000	2.000	0.0000	2.600	0.0000
0.300	0.0000	0.900	0.0000	1.500	0.0000	2.100	0.0000	2.700	0.0000
0.400	0.0000	1.000	0.0000	1.600	0.0000	2.200	0.0000	2.800	0.0000
0.500	0.0000	1.100	0.0000	1.700	0.0000	2.300	0.0000	2.900	0.0000
0.600	0.0000	1.200	0.0000	1.800	0.0000	2.400	0.0000	3.000	0.0000