



Front Elevation As Proposed

External dry riser unit added to comply with building regulations and BS 9990 and to be installed between 400mm-600mm from finished floor level



Rear Elevation As Proposed



NOTES:

ALL DIMENSIONS TO BE CONFIRMED ON SITE.

THIS IS A CAD DRAWING
Any discrepancy found between this drawing and any other document should be referred immediately to the CA. No dimensions are to be scaled from this drawing and all measurements should be checked on site.

CONSTRUCTION ISSUE

(ALL SETTING OUT DIMENSIONS TO BE CONFIRMED ON SITE)

D	Dry riser centralised	19/07/23
C	Dry riser added	13/07/23
B	No. 39 Party Wall noted added	07/07/23
A	Construction issue	31/05/23

DRAWING TITLE
Elevations As Proposed

ADDRESS
37 Grays Inn Road, London

PROJECT NAME Refurbishment	DATE Mar. 2021
	SCALE 1:100@A3

CLIENT Rodell Properties Ltd	DRAWING NO. 20102/P04 Rev. D
---------------------------------	------------------------------------