

SANDY BROWN

Consultants in Acoustics, Noise & Vibration

21325-R02-D

18 August 2023

24 Endell Street, London

Planning noise report

London, Manchester, Edinburgh, Birmingham, Belfast, Leeds

Sandy Brown Ltd

Registered in England & Wales

No. 13227735

post@sandybrown.com

www.sandybrown.com

Registered Office: 55 Charterhouse Street, London EC1M 6HA

SANDY BROWN

Consultants in Acoustics, Noise & Vibration

| Version | Date | Comments | Author | Reviewer |
|---------|-----------|------------------------|---------------|----------------|
| A | 27 Aug 21 | | Serena Joynes | Philip Owen |
| B | 15 Sep 21 | | Philip Owen | Steven Wheeler |
| C | 22 Oct 21 | | Philip Owen | Steven Wheeler |
| D | 18 Aug 23 | Final plant selections | Philip Owen | Edward Farrer |

Disclaimer

This report has been prepared for the sole benefit and use of our client based on their instructions and requirements. Sandy Brown Ltd extends no liability in respect of the information contained in the report to any third party.

Summary

Sandy Brown has been commissioned by Patrizia UK Limited to provide an assessment of noise in relation to the proposed redevelopment of 24 Endell Street, London.

An environmental noise survey has been carried out at the site. The noise survey was carried out between 9 August 2021 and 16 August 2021.

The lowest background sound levels measured during the survey were $L_{A90,15min}$ 44 dB during the weekday (08:00-18:00) and $L_{A90,15min}$ 41 dB during other periods of the day and the night.

Based on the requirements outlined in planning condition 6 (2021/5347/P) the noise from building services plant is to be at least 10 dB below the lowest existing background sound level when assessed at the most affected noise sensitive premise.

On this basis, all plant noise emissions shall not exceed L_{Aeq} 34 dB during the weekday (08:00-18:00 when plant is scheduled to operate) and L_{Aeq} 31 dB at other times at the windows of nearby noise sensitive premises.

The survey presents the predicted of noise emissions from the selected building services plant, which demonstrates that the requirements of planning condition 6 will be met.

Contents

| | | |
|---|--|----|
| 1 | Introduction | 5 |
| 2 | Site description | 5 |
| 3 | Development proposals | 7 |
| 4 | Planning condition 6 | 7 |
| 5 | Survey method | 8 |
| 6 | Measurement results | 10 |
| 7 | Plant noise limits – noise egress | 12 |
| 8 | Assessment | 12 |
| | Appendix A | 17 |
| | Survey details | 17 |
| | Appendix B | 20 |
| | Results of unattended measurements at Location ‘L’ | 20 |
| | Appendix C | 22 |
| | Detailed calculations for individual building services plant items | 22 |

1 Introduction

Sandy Brown has been commissioned by Patrizia UK Limited to provide an assessment of noise in relation to the proposed redevelopment of 24 Endell Street, London.

An environmental noise survey has been carried out to establish:

- background sound levels around the site and by nearby noise sensitive premises
- ambient and maximum noise levels at the site.

The background sound levels measured during the survey are used as the basis for setting limits for noise emission from proposed building services plant. These limits are set in accordance with the requirements of planning condition 6.

This report provides details of the noise survey, including measurement results, and provides an assessment of noise emissions demonstrating compliance with planning condition 6.

2 Site description

2.1 The site and its surroundings

The site location in relation to its surroundings is shown in Figure 1, with the site highlighted in white. The green highlighted buildings contain residential dwellings, with those highlighted red containing office/retail uses.

The 24 Endell Street includes facades on three streets, namely Short's Gardens (north-west), Endell Street (west) and Betterton Street (south-east).




Figure 1 Aerial view of site (courtesy of Google Earth Pro)

2.2 Adjacent premises

The premises adjacent to the development are a mixture of residential, retail and offices. The properties highlighted with green in Figure 1 are predominately residential, which are more sensitive to noise.

The closest property to the proposal location of the roof top plant is Dudley Court, approximately 20 m to the north west of the building, along Short's Garden.

3 Development proposals

The development proposal comprises the change of use of ground and upper floors of the building from members club (sui generis) to use as offices (Class E), enlargement of existing cycle and shower facilities, replacement and reconfiguration of rooftop plant to accommodate additional office space (Class E) and the retention and refurbishment of the basement to allow for continued studio use (sui generis).

The proposed development will require the addition of new building services plant, which in accordance with London Borough of Camden planning policy requires assessing.

3.1 Hours of operation

The proposed office accommodation will be operational during typical working hours (08:00 to 18:00) and occasionally outside these times. The basement studio has the potential to operate 24 hours a day and 7 days a week.

3.2 Potential noise sources

The potential noise sources associated with the scheme can be broadly divided into two categories:

- Building services plant
- Internal activity in commercial units.

The potential impact of these sources is to be assessed once detailed proposed are known in order to minimise impact on existing noise sensitive premises around the development.

4 Planning condition 6

Planning condition 6 of 2021/5347/P is presented below:

Prior to use of the plant equipment, further details shall be submitted to and approved in writing by the Council, of the external noise level emitted from the installation including specified mitigation measures as appropriate. The measures shall ensure that the external noise level emitted from plant, machinery/equipment will be lower than the lowest existing background noise level by at least 10 dBA, by 15 dBA where the source is tonal as assessed according to BS 4142:2014 at the nearest and/or most affected noise sensitive premise, with all machinery operating together at maximum capacity.

Approved details shall be implemented prior to occupation of the development and thereafter be permanently retained.

5 Survey method

5.1 Noise survey method

The survey included unattended and attended noise measurements.

5.1.1 *Unattended measurements*

Unattended noise monitoring was undertaken at the site over 7 days.

Details of the equipment used and the noise indices measured are provided in Appendix A.

The unattended measurements were taken over 15 minute periods between 12:40 on 9 August 2021 and 00:10 on 16 August 2021. The equipment was installed by Matthew Elliott and Serena Joynes and collected by Serena Joynes.

The measurement position used during the survey is indicated in Figure 1, denoted by the letter 'L'. A photograph showing the measurement location is provided in Figure 2. This location was chosen to be reasonably representative of noise levels at the site and outside the nearest noise sensitive premises.

The measurements were made between 1-2 m from the adjacent facade and are facade noise levels.



Figure 2 Photo of monitoring position 'L'

5.1.2 Attended measurements

Attended sample measurements were taken by Matthew Elliott and Serena Joyes at one location around the site. This is indicated in Figure 1 as position '1'. The attended measurements were carried out on 9 August 2021, over 15 minute periods.

At each position the microphone was mounted on a tripod approximately 1.5 m above the ground level and at least 1 m from any other reflective surface. Details of the equipment used and the noise indices measured are provided in Appendix A.

Dominant noise sources occurring during the measurements were noted.



Figure 3 Photo of measurement position '1'

5.2 Weather conditions

Weather conditions during the survey are described in Appendix A.

6 Measurement results

6.1 Observations

6.1.1 Noise

The dominant noise sources observed at the site during the survey were from construction in the distance.

Less significant noise sources included background noise from traffic and an occasional plane flying overhead.

6.2 Noise measurement results

6.2.1 Unattended measurement results

A graph showing the results of the unattended measurements is provided in Appendix B.

Day and night-time ambient noise levels measured during the unattended survey are presented in Table 1.

Table 1 Ambient noise levels measured during the unattended survey

| Date | Day (07:00 – 23:00) | Night (23:00 – 07:00) |
|--------------------------|---------------------|-----------------------|
| | $L_{Aeq,16h}$ (dB) | $L_{Aeq,8h}$ (dB) |
| Monday 9 August 2021 | - | 45 |
| Tuesday 10 August 2021 | 49 | 46 |
| Wednesday 11 August 2021 | 50 | 45 |
| Thursday 12 August 2021 | 50 | 45 |
| Friday 13 August 2021 | 50 | 45 |
| Saturday 14 August 2021 | 49 | 45 |
| Sunday 15 August 2021 | 48 | - |
| Average | 49 | 45 |

Table 2 Minimum background sound levels measured during the unattended survey

| Date | Day (07:00 – 23:00) | Night (23:00 – 07:00) |
|--------------------------|----------------------|-----------------------|
| | $L_{A90,15min}$ (dB) | $L_{A90,15min}$ (dB) |
| Monday 9 August 2021 | 43 | 41 |
| Tuesday 10 August 2021 | 43 | 41 |
| Wednesday 11 August 2021 | 42 | 41 |
| Thursday 12 August 2021 | 43 | 42 |
| Friday 13 August 2021 | 43 | 42 |
| Saturday 14 August 2021 | 42 | 41 |
| Sunday 15 August 2021 | 41 | 42 |

[1] Measurement not made over full period due to monitoring start and end time.

The lowest day and night background noise level was $L_{A90,15min}$ 41 dB.

The lowest background noise level between 08:00 and 18:00, Monday to Friday was $L_{A90,15min}$ 44 dB. This is when all the building services plant will be operating simultaneously.

6.2.2 Attended measurement results

Noise levels and key sources recorded during the attended measurements are summarised in Table 3. All measurements are facade noise levels.

Table 3 Noise levels and key noise sources from attended measurements

| Position | Start time | Sound pressure levels (dB) | | | Noise sources |
|----------|------------|----------------------------|-------------------|-----------------|-------------------------------------|
| | | $L_{Aeq,15min}$ | $L_{AFmax,15min}$ | $L_{A90,15min}$ | |
| 1 | 13:09 | 57 | 75 | 51 | Cars and pedestrians Plant noise |
| 1 | 13:24 | 58 | 77 | 51 | Motorcycle |

The attended measurements indicate that daytime background noise levels at ground floor level can be significantly higher than those measured on the roof top.

7 Plant noise limits – noise egress

Based on the requirements of planning condition 6 and the measurement results, the cumulative noise level from the operation of all new plant should not exceed the limits set out in Table 4.

The limits apply at 1 m from the worst affected windows of the nearest noise sensitive premises and are presented as facade levels. In this case these limits apply at the facade of Dudley Court.

Table 4 Plant noise limits at 1 m from the nearest noise sensitive premises

| Plant operating | Time of day | Maximum sound pressure level at 1 m from noise sensitive premises, $L_{Aeq,15min}$ (dB) |
|-----------------|-----------------------|---|
| All plant | Weekday (08:00-18:00) | 34 |
| Basement plant | Day and night | 31 |

[1] The limits set out in Table 4 do not include any attention catching features. The penalty corrections for attention catching features is 5 dB

8 Assessment

8.1 Description of building services plant

Figure 4 illustrates the location of the proposed building services plant associated with the building. The relevant plant includes:

- 3 x extract fans (EF1, EF2 and EF3)
- 1 x office AHU (AHU)
- 2 x Mitsubishi condensers serving basement (B1 and B2)
- 4 x Dakin condensers (AHU heat pump condensing units)
- 1 x Samsung condenser.

Other building services plant associated with the fit-out of the building has not been included in the assessment.




Figure 4 Proposed location of roof top building services plant

8.2 Selection of building services plant

The assessment of the noise emissions from the selected building services plant has been based on the manufacturer's noise data summarised in Table 5 (AHU and extract fans) and Table 6 (condensing units and heat pumps)

Table 5 Manufacturer's plant sound power level data for AHU and extract fans

| Item | Description | Sound power levels (dB) at Octave band centre frequency (Hz) | | | | | | | | dBA |
|------|-----------------|---|-----|-----|-----|----|----|----|----|-----|
| | | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| AHU | Fresh air inlet | 79 | 71 | 67 | 45 | 22 | 26 | 29 | 42 | 61 |
| | Exhaust | 79 | 68 | 64 | 54 | 34 | 40 | 44 | 54 | 60 |
| EF1 | Exhaust | 73 | 69 | 66 | 65 | 61 | 56 | 52 | 46 | 67 |
| EF2 | Exhaust | 73 | 70 | 66 | 66 | 62 | 57 | 53 | 47 | 66 |
| EF3 | Exhaust | 72 | 68 | 58 | 57 | 54 | 50 | 44 | 42 | 60 |

Table 6 Manufacturer's sound pressure levels at 1 m data for condensing units and heat pumps

| Item | Manufacturer ID | Sound pressure levels (dB) at Octave band centre frequency (Hz) | | | | | | | | dBA |
|---|---|--|-----|-----|-----|----|----|----|----|-----|
| | | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| B1 condensing unit | Mitsubishi - PURY- P500 YNW ^[1] | 73 | 66 | 62 | 53 | 51 | 48 | 45 | 40 | 59 |
| B1 condensing unit | Mitsubishi - PURY- P500 YNW ^[1] | 72 | 65 | 63 | 56 | 53 | 49 | 46 | 40 | 60 |
| AHU Heat pump condensing units | Dakkin RYYQ20U ^[2] | 60 | 57 | 57 | 55 | 49 | 45 | 42 | 38 | 58 |
| Samsung unit | AM060NXMDGR/EU | 65 | 59 | 55 | 56 | 53 | 48 | 44 | 33 | 58 |

^[1] Extrapolated from Low Noise Mode to operating at 70% fan speed on heating

^[2] Quiet Mode Level 1

8.3 Assessment of building services plant

This section provides detailed calculations of the plant noise emissions at the nearest/most affected noise sensitive window, which is identified in Figure 5 relative to the building.




Figure 5 Section of 24 Endell Street and location of nearest noise sensitive window

Appendix C contains the detailed calculations for each item of building services plant on the roof top.

Table 7 includes the combined assessment of building services plant noise.

Table 7 Combined assessment of noise contributions from all roof top building services plant

| | Sound pressure levels (dB) at nearest affected receptor at | | | | | | | | |
|--------------------------------|--|-----|-----|-----|-----|-----|-----|-----|-----|
| | Octave band centre frequency (Hz) | | | | | | | | |
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | dBA |
| AHU 1 intake | 35 | 29 | 24 | 1 | -24 | -23 | -23 | -13 | 18 |
| AHU 1 exhaust | 41 | 32 | 28 | 19 | -1 | 5 | 9 | 19 | 24 |
| EF1 | 26 | 25 | 23 | 21 | 16 | 8 | 1 | -8 | 22 |
| EF2 | 26 | 26 | 23 | 22 | 17 | 9 | 2 | -7 | 22 |
| EF3 | 20 | 19 | 11 | 9 | 4 | -3 | -12 | -17 | 10 |
| B1 condensing unit | 37 | 29 | 22 | 11 | 6 | 0 | -6 | -12 | 18 |
| B2 condensing unit | 36 | 28 | 23 | 14 | 8 | 1 | -5 | -12 | 19 |
| AHU heat pump condensing units | 30 | 26 | 23 | 19 | 10 | 3 | -3 | -8 | 20 |
| Samsung unit | 29 | 22 | 15 | 14 | 8 | 0 | -7 | -19 | 15 |
| Combined | 44 | 37 | 33 | 27 | 21 | 14 | 11 | 19 | 30 |

The assessment of all roof top plant indicates that the sound pressure level at the most affected residential window will be L_{Aeq} 30 dB with all plant operating at their design conditions.

The noise emissions are suitably low that they would comply with all day and night criteria.

Appendix A

Survey details

Equipment

The unattended and attended noise measurements were taken using a Rion NL-52 sound level meter and a B&K 2250 sound level meter, respectively.

Calibration details for the equipment used during the survey are provided in Table A1.

Table A1 Equipment calibration data

| Equipment description | Type/serial number | Manufacturer | Calibration expiry | Calibration certification number |
|-----------------------|--------------------|--------------|--------------------|----------------------------------|
| Sound level meter | NL-52/00264531 | Rion | 23 Jun 22 | TCRT20/1331 |
| Microphone | UC-59/09678 | Rion | 23 Jun 22 | TCRT20/1331 |
| Pre-amp | NH-25/64656 | Rion | 23 Jun 22 | TCRT20/1331 |
| Calibrator | NC-74/34367630 | Rion | 23 Jun 22 | TCRT20/1328 |
| Sound level meter | 2250/3009283 | Brüel & Kjær | 24 Jun 22 | UCRT20/1539 UCRT20/1542 |
| Microphone | 4189/3005042 | Brüel & Kjær | 24 Jun 22 | UCRT20/1539 UCRT20/1542 |
| Pre-amp | ZC0032/23792 | Brüel & Kjær | 24 Jun 22 | UCRT20/1539 UCRT20/1542 |
| Calibrator | 4231/3016124 | Brüel & Kjær | 23 Jun 22 | UCRT20/1526 |

Calibration of the meters used for the measurements is traceable to national standards. Calibration certificates for the sound level meters used in this survey are available upon request.

Calibration checks were carried out on the meters and their measurement chains at the beginning and end of the survey.

Noise indices

Noise indices recorded included the following:

- $L_{Aeq,T}$ The A-weighted equivalent continuous sound pressure level over a period of time, T.
- $L_{AFmax,T}$ The A-weighted maximum sound pressure level that occurred during a given period, T, with a fast time weighting.
- $L_{A90,T}$ The A-weighted sound pressure level exceeded for 90% of the measurement period. Indicative of the background sound level.

Sound pressure level measurements are normally taken with an A-weighting (denoted by a subscript 'A', eg L_{A90}) to approximate the frequency response of the human ear.

A more detailed explanation of these quantities can be found in BS7445: Part 1: 2003 *Description and measurement of environmental noise, Part 1. Guide to quantities and procedures*.

Weather conditions


During the attended noise measurements, the weather was generally clear and dry and no rain occurred.

During the unattended noise measurements, weather reports for the area indicated that temperatures varied between 12 °C at night and 24°C during the day, and the wind speed was less than 6 m/s.

These weather conditions are considered suitable for obtaining representative measurements.

Appendix B

Results of unattended measurements at Location 'L'



Appendix C

Detailed calculations for individual building services plant items

Table 8 AHU intake noise calculation

| | Octave band centre frequency (Hz) | | | | | | | | dBA |
|----------------------------|-----------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| Intake L_w (dB) | 79 | 71 | 67 | 45 | 22 | 26 | 29 | 42 | |
| Duct losses (dB) | -2 | -2 | -3 | -3 | -3 | -3 | -3 | -3 | |
| End reflection loss (dB) | -4 | -2 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Distance attenuation (dB) | -35 | -35 | -35 | -35 | -35 | -35 | -35 | -35 | |
| Screening attenuation (dB) | -6 | -6 | -7 | -9 | -11 | -14 | -17 | -20 | |
| Facade reflection (dB) | +3 | +3 | +3 | +3 | +3 | +3 | +3 | +3 | |
| L_{eq} at receptor (dB) | 35 | 29 | 24 | 1 | -24 | -23 | -23 | -13 | 18 |

Table 9 AHU exhaust noise calculation

| | Octave band centre frequency (Hz) | | | | | | | | dBA |
|----------------------------|-----------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| Exhaust L_w (dB) | 79 | 68 | 64 | 54 | 34 | 40 | 44 | 54 | |
| Duct losses (dB) | -2 | -2 | -3 | -3 | -3 | -3 | -3 | -3 | |
| End reflection loss (dB) | -4 | -2 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Distance attenuation (dB) | -35 | -35 | -35 | -35 | -35 | -35 | -35 | -35 | |
| Screening attenuation (dB) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| Facade reflection (dB) | +3 | +3 | +3 | +3 | +3 | +3 | +3 | +3 | |
| L_{eq} at receptor (dB) | 41 | 32 | 28 | 19 | -1 | 5 | 9 | 19 | 24 |

Table 10 EF1 exhaust noise calculation

| | Octave band centre frequency (Hz) | | | | | | | | dBA |
|----------------------------|-----------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| Exhaust L_w (dB) | 73 | 69 | 66 | 65 | 61 | 56 | 52 | 46 | |
| Duct losses (dB) | 0 | -1 | -2 | -3 | -3 | -3 | -3 | -3 | |
| End reflection loss (dB) | -9 | -5 | -2 | -1 | 0 | 0 | 0 | 0 | |
| Distance attenuation (dB) | -35 | -35 | -35 | -35 | -35 | -35 | -35 | -35 | |
| Screening attenuation (dB) | -6 | -6 | -7 | -8 | -10 | -13 | -16 | -19 | |
| Facade reflection (dB) | +3 | +3 | +3 | +3 | +3 | +3 | +3 | +3 | |
| L_{eq} at receptor (dB) | 26 | 25 | 23 | 21 | 16 | 8 | 1 | -8 | 22 |

Table 11 EF2 exhaust noise calculation

| | Octave band centre frequency (Hz) | | | | | | | | dBA |
|----------------------------|-----------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| Exhaust L_w (dB) | 73 | 70 | 66 | 66 | 62 | 57 | 53 | 47 | |
| Duct losses (dB) | 0 | -1 | -2 | -3 | -3 | -3 | -3 | -3 | |
| End reflection loss (dB) | -9 | -5 | -2 | -1 | 0 | 0 | 0 | 0 | |
| Distance attenuation (dB) | -35 | -35 | -35 | -35 | -35 | -35 | -35 | -35 | |
| Screening attenuation (dB) | -6 | -6 | -7 | -8 | -10 | -13 | -16 | -19 | |
| Facade reflection (dB) | +3 | +3 | +3 | +3 | +3 | +3 | +3 | +3 | |
| L_{eq} at receptor (dB) | 26 | 26 | 23 | 22 | 17 | 9 | 2 | -7 | 22 |

Table 12 EF3 exhaust noise calculation

| | Octave band centre frequency (Hz) | | | | | | | | dBA |
|----------------------------|-----------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| Exhaust L_w (dB) | 72 | 68 | 58 | 57 | 54 | 50 | 44 | 42 | |
| Duct losses (dB) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| End reflection loss (dB) | -9 | -5 | -2 | -1 | 0 | 0 | 0 | 0 | |
| Distance attenuation (dB) | -40 | -40 | -40 | -40 | -40 | -40 | -40 | -40 | |
| Screening attenuation (dB) | -6 | -7 | -8 | -10 | -13 | -16 | -19 | -22 | |
| Facade reflection (dB) | +3 | +3 | +3 | +3 | +3 | +3 | +3 | +3 | |
| L_{eq} at receptor (dB) | 20 | 19 | 11 | 9 | 4 | -3 | -12 | -17 | 10 |

Table 13 B1 condensing unit noise calculation

| | Octave band centre frequency (Hz) | | | | | | | | dBA |
|----------------------------|-----------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| L_{eq} at 1 m (dB) | 72 | 68 | 58 | 57 | 54 | 50 | 44 | 42 | |
| Distance attenuation (dB) | -40 | -40 | -40 | -40 | -40 | -40 | -40 | -40 | |
| Screening attenuation (dB) | -6 | -7 | -8 | -10 | -13 | -16 | -19 | -22 | |
| Facade reflection (dB) | +3 | +3 | +3 | +3 | +3 | +3 | +3 | +3 | |
| L_{eq} at receptor (dB) | 20 | 19 | 11 | 9 | 4 | -3 | -12 | -17 | 10 |

Table 14 B2 condensing unit noise calculation

| | Octave band centre frequency (Hz) | | | | | | | | |
|----------------------------|-----------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | dBA |
| L_{eq} at 1 m (dB) | 72 | 65 | 63 | 56 | 53 | 49 | 46 | 40 | 60 |
| Distance attenuation (dB) | -31 | -31 | -31 | -31 | -31 | -31 | -31 | -31 | |
| Screening attenuation (dB) | -8 | -9 | -12 | -14 | -17 | -20 | -23 | -24 | |
| Facade reflection (dB) | +3 | +3 | +3 | +3 | +3 | +3 | +3 | +3 | |
| L_{eq} at receptor (dB) | 36 | 28 | 23 | 14 | 8 | 1 | -5 | -12 | 19 |

Table 15 AHU heat pump condensing unit calculation

| | Octave band centre frequency (Hz) | | | | | | | | |
|----------------------------|-----------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | dBA |
| L_{eq} at 1 m (dB) | 60 | 57 | 57 | 55 | 49 | 45 | 42 | 38 | 56 |
| No. 4 units (dB) | +6 | +6 | +6 | +6 | +6 | +6 | +6 | +6 | |
| Distance attenuation (dB) | -31 | -31 | -31 | -31 | -31 | -31 | -31 | -31 | |
| Screening attenuation (dB) | -8 | -9 | -12 | -14 | -17 | -20 | -23 | -24 | |
| Facade reflection (dB) | +3 | +3 | +3 | +3 | +3 | +3 | +3 | +3 | |
| L_{eq} at receptor (dB) | 30 | 26 | 23 | 19 | 10 | 3 | -3 | -8 | 20 |

Table 16 Samsung condensing unit noise calculation

| | Octave band centre frequency (Hz) | | | | | | | | |
|----------------------------|-----------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | dBA |
| L_{eq} at 1 m (dB) | 65 | 59 | 55 | 56 | 53 | 48 | 44 | 33 | 58 |
| Distance attenuation (dB) | -31 | -31 | -31 | -31 | -31 | -31 | -31 | -31 | |
| Screening attenuation (dB) | -8 | -9 | -12 | -14 | -17 | -20 | -23 | -24 | |
| Facade reflection (dB) | +3 | +3 | +3 | +3 | +3 | +3 | +3 | +3 | |
| L_{eq} at receptor (dB) | 29 | 22 | 15 | 14 | 8 | 0 | -7 | -19 | 15 |