



Application ref: 2021/6065/P


CONDITION 4

Condition 4. Before the brickwork is commenced, a sample panel of the facing brickwork demonstrating the proposed brick, brick bond and pointing shall be provided on site and approved in writing by the local planning authority. The development shall be carried out in accordance with the approval given. The approved panel shall be retained on site until the work has been completed.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies D1 and D2 of the London Borough of Camden Local Plan 2017.



Existing rear façade



Existing rear façade



Application ref: 2021/6065/P

CONDITION 4

BRICK PANEL NEXT TO EXISTING

Proposed Brick 1 – Main brick



Note: The brick bond and pointing will match existing brickwork as shown at left picture.

Proposed Brick 2



Note: the 5 first rows will follow the original black brick design. The brick bond and pointing will match existing brickwork and panel.



Application ref: 2021/6065/P

CONDITION 4

BRICK PANEL SHOWING PROPOSED BOND AND POINTING

Brick bond: stretcher bond

Pointing: The joint will be slightly recessed for the brick aris to be clearly visible

Panel: The panel will be kept on site till end of the project.

