9. FRAMES, CASINGS, SKIRTINGS, ARCHITRAVES:- Internal door linings shall be 100 x 38 with planted stops. Skirting boards shall be 100 x 19mm. chamfered. Architraves shall be 75x19 chamfered. All new internal doors to have min. undercut of 10mm above the fitted floor finish surface. Window frames with safety glazing to all doors, side panels, and all areas extending below 800mm from floor level and to be in accordance with BS 6206 and or BS EN 12600. New or replacement doors and windows to be UPVC and double or triple glazed, argon filled gaps and finished soft low 'E' coating to achieve U-value of 1.40W/m2K or window energy rate - Band B or better. New rooflights with kerb/upstands can have a value no worse than 2.2W/m2K. New external doors with more than 60% of internal face glazed to have a U value of 1.40W/m2K or doorset energy rate - Band C or better, other external doors to have a U value of 1.40W/m2K or doorset energy rate - Band B or better. Installed either by Fensa registered installer or compliance via certificate from L.A. Building control (fee Payable). All roof lights/lanterns to be glazed. If polycarbonate or uPVC roof lights/lanterns are to be used, ensure rating is class C-s3,d2 which can be regarded as having a BRoof(t4) classification. BRoof(t4) units can be used within 6m of the boundary. However, they are not to be used within 1500mm of a compartment wall line separating property's. Max. area of windows, doors and roof lights should not exceed the sum of the following:

a. 25% of the floor area of the extension and

b. the total area of any windows and doors which no longer exist or are no longer exposed

due to the extension.

When glazing area is more than the sum of a. and b. then SAP calculations must be provided and the new sets of U-values must be followed.

10. ELECTRICAL INSTALLATION and PART P BUILDING **REGULATIONS ELECTRICAL SAFETY:-** Where electrical work is required to comply with Schedule 1 of the Building regulations it will either:

- a. Be installed, by electrician who is registered as Part P approved by an authorised body (a completion certificate/certificate of compliance will need to be obtained from their authorised body (NICEIC, ELECSA, NAPIT etc.).
- b. Any other electrician will require and Electrical Safety Building Notice application.

The proposed electrical installation, earthing and bonding to be installed to current IEE regulations & to comply with Part P requirements of the Building regulations. Smoke alarms must be provided at each landing level. The fire alarm system to be at least a Grade D2 Category LD3 in accordance with BS 5839-6. Smoke alarms to be mains operated and inter linked and conform to BS EN 14604 whilst heat alarms to be to BS 5446-2. The alarms to have a standby power supply, such as battery back-up. Any fixed lighting to achieve lighting levels appropriate to the activity in the space and spaces to not be over-illuminated. Each internal light fitting to have lamps with a minimum luminous efficacy of 75 light source lumens per circuit-watt. Internal light fittings to have local controls to allow for the separate control of lighting in each space or zone.

Controls may be manual, automatic or a combination of both. Fixed external lighting to have both of the following controls.

- a. Automatic controls which switch luminaires off in response to daylight.
- b. If luminous efficacy is 75 light source lumens or less, automatic controls which switch luminaires off after the area lit becomes unoccupied. If luminous efficacy is greater than 75 light source lumens, manual control is acceptable.
- 11. GAS INSTALLATION & HEATING:- The proposed gas installation shall be designed and installed by GASSAFE registered person and a relevant certificate provided to Building Control pre-completion. Extend existing central heating to new areas to client's instructions. Where new or replacement boilers are installed must be a condensing boiler and must have a SEDBUK rating of Class A or B and the condensate outlet must be taken to the foul drainage system. New radiators fitted with thermostatic type valves with pipework insulated to non heated locations.
- 12. NATURAL AND MECHANICAL VENTILATION:- Prior to completion details of commissioning and testing of mechanical systems for extracts to be deposited with building Control to show complaince with F1 (2).
 - a) Habitable room:
 - Rapid ventilation 1/20th of floor area for a hinged or pivot window that opens 30° or more, or for sliding sash windows. 1/10th of floor area - for a hinged or pivot window that opens less than 30°.
 - Background ventilation 8000 mm²

b) Kitchen:

- Rapid ventilation opening window
- Background ventilation 8000 mm²
- Extract ventilation fan rates 30 l/s adjacent to a hob or 60l/s elsewhere
- c) Bathroom (with or without WC):
 - Rapid ventilation opening window
 - Background ventilation 5000 mm²
 - Extract ventilation fan rates 15 l/s

The extract fans to rooms like utility, WC and bathroom having no external opening window to be provided with a 15 minute overrun.

Location of mechanical ventilation devices in rooms:

- a) Cooker hoods should be 650mm to 750mm above the hob surface (or follow manufacturer's instructions).
- b) Mechanical extract fans should be placed as high as practicable and preferably less than 400mm below the ceiling. Refer to Appendix E Approved Document F for further guidance of installation of fans in dwellings.

THE CONTRACTOR SHALL ALLOW FOR MAKING GOOD OF ALL **DISTURBED WORKS.**

Other Notes, Alterations.

All existing foundations, beams and/or lintels accepting additional load, are to be exposed, if necessary, for consideration by the Building Control Surveyor and upgraded if found necessary.

DRAWING CONSTRUCTION STATUS REV. DATE NAME DESCRIPTION Architectural Design Studio 4 ST ANNES, DORIC WAY, EUSTON, LONDON NW1 1LG

+44 07838 135 957

- Linform the Building control department that the works are about to commence on site ofter an approved decision from planning / building control in writing for your proposed works. 3. Verify boundary lines & ground conditions including checking positions and new connections electrical, water & other services drainage ect. within the site prior to the commencement c exocvations. Owner is responsible for establishing own boundary lines as DPL are not respon checking land ownership even if drawings have been approved by the planning and building departments. If uncertain a land search should be carried out by the homeowner/contractor.

- er between written and site dimensions or between or suppliers drawings, should be brought to the

www.discountplansltd.com

OTHER NOTES:

understands that no refunds can be given.

12. All drainage connections is assumed that no refunds can be given.

12. All drainage connections is assumed the checking by builder, Thomes water checking by builder, Thomes water before works commet thames water before works commet.

SITE ADDRESS 61 WESTCROFT CLOSE, CRICKLEWOOD, LONDON, NW2 2RR

DRAWING TITLE SPECS.

DRAWN AT HEAD OFFICE

DRAWN BY SCALE @ A3 22. AUGUST. 2023

REVISION

DRAWING No DPL . 13

www.discountplansltd.com