

Sandhurst

— Fire Protection & Electrical Limited —

Rosewood Ltd Restoration & Conservation
80 - 81 St Martins Lane
London
WC2N 4AA

4th August 2023

Dear Andy,

Re: Centre Point House – Replacement Flat Entrance Doorsets with Adjacent Side Panels, Letterboxes and Electricity Meter Access Panels and Meter Enclosures

Further to the information requested by Nicola, We confirm that Option "B" comprising flat front entrance doorsets with certificated BM TRADA FD30S fire doors and frames supplied by On Wood Products Ltd, and adjacent side panels and electricity meter enclosures will be of 60 minutes fire and smoke resistance built in accordance with British Gypsum's White Book incorporating third-party accredited 60-minute fire and smoke resistant letterboxes and third-party accredited 60-minute fire and smoke resistant access panels fitted in full accordance with the manufacturers' instructions. The flat entrance doorsets will be installed under our FIRAS certification and the British Gypsum wall, access panel and enclosure will be installed by competent trained individuals using British Gypsums installing methodology.

In this arrangement, the finished construction comprising replacement flat entrance doorsets will withstand fire and smoke for 30 minutes and the adjacent side panels, letterboxes, electricity meter access panels and meter enclosures will withstand fire and smoke for 60 minutes.

If you require anything further, please do not hesitate to contact us

Your sincerely



Luke Beach
Contracts Manager

Sandhurst Fire Protection & Electrical Ltd

Passive Fire Protection, Fire Door Installation & Maintenance, Electrical Installation & Certification

Telephone ~ 01708 459599 E-mail ~ info@sandhurstelectrical.co.uk

Address ~ Unit 1 Saxon House, Upminster Trading Park

Warley Street, Upminster, Essex RM14 3PJ

Registered in England & Wales, No: 10575051 VAT Registration No: 365 3489 67

