

# PEAK acoustics



## Noise Impact Assessment

**Client:** Florian Bernollin

**Site:** 30 Fitzjohn's Avenue, London NW3 5NB.

**Reference No.** 1810231NR

**Revision:** 0.0

**Date of Issue:** 02/11/2023

### Project Consultant

T. Brown BSc (Hons) MIOA  
*Acoustic Consultant*  
tom@acousticsurveys.co.uk

### Proofing Consultant

Molly-Sue Bisset  
*Acoustic Consultant*  
molly@acousticsurveys.co.uk

**Email:** sales@acousticsurveys.co.uk | **Office** 0330 043 1764

**Web:** www.acousticsurveys.co.uk

Peak Acoustics Ltd, PO Box 724, Macclesfield, SK10 9DH

## Executive Summary

A Noise Impact Assessment has been undertaken for the proposed A/C unit at 30 Fitzjohn's Avenue, London. The unit is to serve the heating and cooling requirements of Flat 3.

The nearest or most-affected Noise Sensitive Receptor (NSR) is identified as the 1<sup>st</sup> floor flat above the unit.

Using the measured background noise survey data, a representative night-time background sound level of 32dB L<sub>A90</sub> was derived for the assessment.

Measurements of the prevailing background noise climate were undertaken from 27<sup>th</sup> – 31<sup>st</sup> October 2023 at a location representative of the identified Noise Sensitive Receptors (NSRs).

Acoustic modelling software, SoundPLAN, was utilised to calculate external sound propagation from the unit using ISO-9613-2 - *Attenuation of sound during propagation outdoors*. Manufacturers data has been used to model the noise source.

A BS4142:2014 Initial Impact Assessment of the predicted night-time noise impact indicated the potential for a '*significant adverse impact*' at the NSR location, with Rating Levels 23 dB above the representative night-time background sound level.

A further Contextual Assessment was undertaken where noise levels from the unit have been assessed to the existing noise climate along with other relevant factors and deemed appropriate for the proposal to incorporate noise mitigation.

An acoustic enclosure has been recommended and incorporated into the noise model, recalculation including the enclosure indicates a 'Low Impact' in accordance with BS4142, corresponding to achievement '*NOEL – No Observed Effect Level*' in the NPSE.

**Contents**

**EXECUTIVE SUMMARY ..... 2**

*Contents*..... 3

*Tables*..... 4

*Figures*..... 4

**1. INTRODUCTION ..... 5**

*Overview* ..... 5

*Scope & Objectives*..... 5

**2. ENVIRONMENTAL NOISE SURVEY ..... 6**

*Measurement Methodology* ..... 6

*Site Description* ..... 7

*Context and Subjective Noise Climate*..... 8

*Non-Representative Noise Sources* ..... 8

*Noise Sensitive Receptors* ..... 8

**3. ENVIRONMENTAL NOISE SURVEY RESULTS ..... 9**

*Measurement Results* ..... 9

**4. BS4142:2014 INITIAL IMPACT ASSESSMENT ..... 10**

*Noise Modelling* ..... 10

*Source Noise Levels* ..... 10

*Specific Sound Levels*..... 11

*Rating Levels* ..... 11

*Rating Levels Vs Background* ..... 12

**5. BS4142:2014 CONTEXTUAL ASSESSMENT ..... 12**

*Aspects of absolute level*..... 12

*Aspects of character* ..... 13

*Aspects of the receptor*..... 13

*Contextual recommendations*..... 13

**6. MITIGATION ..... 13**

**7. CONCLUSION ..... 14**

**8. UNCERTAINTY ..... 14**

**APPENDIX A - MEASUREMENT DETAILS ..... 15**

**APPENDIX B - EQUIPMENT DETAILS ..... 15**

**APPENDIX C - CALIBRATION DETAILS ..... 15**

**APPENDIX D - METEOROLOGY DETAILS ..... 16**

**APPENDIX E - NOISE SURVEY RESULTS ..... 17**

**APPENDIX F - GRID NOISE MAPS ..... 18**

**APPENDIX G - MANUFACTURER TECHNICAL DATA SHEETS ..... 20**

**APPENDIX H - SITE PLANS ..... 21**

**APPENDIX I - LEGISLATION, POLICY & GUIDANCE ..... 22**

**BS4142:2014+A1:2019 ..... 23**

**BS8233:2014 ..... 24**

**APPENDIX J - ACOUSTIC TERMINOLOGY ..... 25**

**Tables**

TABLE 1: SUBJECTIVE SUMMARY OF NOISE SOURCES ..... 8

TABLE 2: M1 BACKGROUND NOISE SURVEY RESULTS ..... 9

TABLE 3: CALCULATION INPUT PARAMETERS ..... 10

TABLE 4: A/C UNIT NOISE LEVELS ..... 10

TABLE 5: SPECIFIC SOUND LEVELS ..... 11

TABLE 6: RATING LEVELS ..... 12

TABLE 7: NOISE IMPACT ..... 12

TABLE 8: NOISE IMPACT ..... 14

TABLE 9: MEASUREMENT DATES ..... 15

TABLE 10: MEASUREMENT EQUIPMENT DETAILS ..... 15

TABLE 11: CALIBRATION DETAILS ..... 15

**Figures**

FIGURE 1: SITE, SOURCE & NSR LOCATIONS - [HTTPS://GOOGLE.CO.UK/MAPS](https://google.co.uk/maps) ..... 7

FIGURE 2: M1 BACKGROUND STATISTICAL ANALYSIS ..... 9

FIGURE 3: SITE LOCATION MEASUREMENT PICTURES ..... 15

FIGURE 4: METEOROLOGY DATA - [HTTPS://WWW.TIMEANDDATE.COM/WEATHER](https://www.timeanddate.com/weather) ..... 16

FIGURE 5: MEASURED BACKGROUND SOUND LEVELS TIME HISTORY (M1): 27<sup>TH</sup> – 31<sup>ST</sup> OCTOBER 2023 ..... 17

FIGURE 6: 3D NOISE MAP OF NIGHT-TIME INITIAL IMPACT ASSESSMENT ..... 18

FIGURE 7: 3D NOISE MAP OF NIGHT-TIME MITIGATED IMPACT ASSESSMENT ..... 19

FIGURE 8: DATA SOURCED FROM 'WWW.MHI.COM' ..... 20

FIGURE 9: SITE PLANS PROVIDED BY THE CLIENT ..... 21

## 1. Introduction

### Overview

A Noise Impact Assessment has been undertaken at 30 Fitzjohn's Avenue, London, NW3 5NB in relation to the proposed external installation of an air conditioning unit.

Details of the proposed external plant have been provided by the applicant and are listed below:

- 1 x Mitsubishi SCM80ZS-W

Manufacturer technical data sheets with noise level data for the unit have been sourced and are given in **Appendix G**.

The unit is to be installed at ground floor level to the front façade of the site.

The plant equipment is associated with the internal heating & cooling requirements of flat 3 within the site.

An assessment of the proposed plant equipment is to be undertaken to determine whether residents are likely to suffer a loss of amenity. Mitigation will be given should any potential loss of amenity be indicated.

### Scope & Objectives

The scope of the noise assessment can be summarised as follows:

- Baseline sound monitoring survey to evaluate the prevailing background sound levels at the Noise Sensitive Receptor ('NSR') in accordance with BS7445 - *'Description and Measurement of Environmental Noise'*;
- Detailed sound modelling, acoustic calculations and analysis to predict sound levels at the NSR using industry-standard acoustic modelling software 'SoundPLAN'. This software uses ISO-9613-2 - *Attenuation of sound during propagation outdoors*;
- A contextual assessment for the suitability of the site, in accordance with relevant standards in respect of sound from the proposed sources; and
- Recommendation of mitigation measures where necessary, to comply with the requirements of the National Planning Policy Framework (2021), Noise Policy for England (2010) and British Standard BS 4142:2014+A1:2019 – Methods for rating and assessing industrial and commercial sound.
- Local Policy for Camden Council requires an assessment in accordance with the BS4142 standard.
- Further information on the legislation can be found in **Appendix I**.

## 2. Environmental Noise Survey

### Measurement Methodology

To establish the existing environmental noise levels on site, a noise survey was conducted from the 27<sup>th</sup> – 31<sup>st</sup> October 2023. Measurements of  $L_{Aeq,T}$  and  $L_{A90,T}$  were logged in 5-minute intervals in accordance with BS7445 - 'Description and Measurement of Environmental Noise'.

The unattended monitoring location (M1) was positioned to front façade of the site at a height of approximately 1.7 metres. The monitoring location was chosen as it is beside the proposed plant location and nearest NSR.

The monitoring position is deemed representative of sound levels at 'NSR 1' during the typical operational periods of the proposed unit.

Further detail of the measurement along with site pictures is given in **Appendix A**.

Measurements were obtained using Class 1 instrumentation. Full equipment details are given in **Appendix B**.

Equipment was calibrated before and after use and no significant drift occurred during measurements. Up-to-date calibration certification can be provided upon request. Full calibration details are provided in **Appendix C**

Daytime temperatures during the survey were noted as between 13 - 14°C with wind speeds typically between 2 - 3m/s; deemed suitable for conducting environmental noise monitoring. Detailed meteorological information can be found in **Appendix D**.

The site, proposed noise source and NSR locations are shown in **Figure 1**.



Figure 1: Site, Source & NSR Locations - <https://google.co.uk/maps>

-  Site Boundary (Approx.)
-  AC Unit Location (Approx.)
-  Noise Sensitive Receptor (NSR)
-  Background Monitoring Location M1 (Approx)

### Site Description

The site is located on Fitzjohn's Avenue in London. This is a suburban street lined with detached 4-storey dwellings, many of which incorporate several flats. Plots have front and rear gardens with driveways and parking to the front.

Fitzjohn's Avenue is also a bus route with a bus stop on the road outside the site.

**Context and Subjective Noise Climate**




Noise Source	Description	Time of Observation	Photo
Road	Medium road noise from cars, vans, buses, motorbikes etc	Constant during site visits	
Bus Stop	Bus Stop to front of site, regular buses	Intermittent during site visits	
Construction Work	Construction works on-going in flat 3	Intermittent during site visits	

Table 1: Subjective Summary of Noise Sources

**Non-Representative Noise Sources**

During the survey, no noise events occurred which would be deemed as atypical of the site location.

**Noise Sensitive Receptors**

The nearest or most-affected Noise Sensitive Receptor (NSR) was identified as the 1<sup>st</sup> floor window of 30 Fitzjohn’s Avenue above Flat 3. This will be considered as the specific reception point in calculations.



### 3. Environmental Noise Survey Results

#### Measurement Results

The A/C unit is to serve Flat 3 on the ground floor of the site and therefore has the potential to operate at any time of the day or night.

The day and night-time background sound levels from measurement M1 are summarised below.

Measurement	Date(s)	Period	L <sub>Aeq,T</sub>	L <sub>A90,T</sub>
M1	27th October 2023	Daytime (12:55 – 23:00)	58	48
	27th – 28th October 2023	Night-time (23:00 – 07:00)	54	35
	28th October 2023	Daytime (07:00 – 23:00)	59	49
	28th – 29th October 2023	Night-time (23:00 – 07:00)	59	38
	29th October 2023	Daytime (07:00 – 23:00)	60	44
	29th – 30th October 2023	Night-time (23:00 – 07:00)	54	35
	30th October 2023	Daytime (07:00 – 23:00)	61	48
	30th – 31st October 2023	Night-time (23:00 – 07:00)	51	32
	31 <sup>st</sup> October 2023	Daytime (07:00 – 12:55)	59	50

Table 2: M1 Background Noise Survey Results

A full-time history of the survey data is shown in **Appendix E**.

For the derivation of a representative night-time background sound level the sound level data from the whole night-time period from 30<sup>th</sup> – 31<sup>st</sup> October (23:00 – 07:00) has been statistically analysed.

A graph of the statistical analysis for M1 night-time data is given below.




Figure 2: M1 Background Statistical Analysis

From the statistical analysis of M1 measurement, **32 dB L<sub>A90</sub>** has been selected as the representative background sound level for the BS4142:2014 assessment at the NSR locations.

## 4. BS4142:2014 Initial Impact Assessment

### Noise Modelling

External sound propagation from the site has been calculated using industry-standard acoustic modelling software 'SoundPLAN'. This software uses ISO-9613-2 - *Attenuation of sound during propagation outdoors* and the model takes into account the following key factors:

- *Aerial Imagery & Terrain Data sourced from Google Maps/Elevations*
- *Geometric divergence of sound*
- *Atmospheric absorption of sound*
- *Ground absorption*
- *A light downwind correction toward the NSRs*
- *Surrounding structures and objects which may reflect or block sound toward the NSRs*
- *The height of the NSRs (i.e., First/second-floor reception point)*
- *Operational schedule of equipment*

The following input parameters were used in the noise model:

Parameter	Input
Reflection Order	3
Ground Absorption Factors	G = 0.5 (Mixed Ground)
Air pressure	1013.3 mbar
Relative Humidity	70.0 %
Temperature	10.0°C

**Table 3: Calculation Input Parameters**

### Source Noise Levels

Details of the proposed A/C Unit have been provided by the applicant, and include.

- *1 x Mitsubishi – SCM80ZS-W*

Manufacturer technical data sheets with noise level data were sourced and are given in **Appendix G**.

Technical data provides a single figure sound power level for the unit. Octave band data has been adapted from a similar unit to give the same overall output:

Unit	Para.	63	125	250	500	1k	2k	4k	8k	dBA
Mitsubishi – SCM80ZS-W	LwA	66	68	66	62	62	57	59	60	<b>67</b>

**Table 4: A/C Unit Noise Levels**

To account for a worst-case scenario, the source will be modelled to be running at its loudest setting (heating) for the entire 24 hours.

## Specific Sound Levels

The Specific Sound Level is denoted  $L_{A5}$  and is the A-weighted, equivalent noise level at the NSR locations. Specific Sound Levels have been calculated from the noise model and the levels at the worst affected floors of receptors are given below.

Location	Specific Sound Level, dB $L_{A5}$
NSR 1 (1F)	52

Table 5: Specific Sound Levels

## Rating Levels

In accordance with BS4142, the Specific Sound Levels may be corrected for characteristics that make the sound more noticeable at the NSR location such as tonality, impulsivity and intermittency. Section 9.2 of BS4142:2014 gives commentary on these characteristics and appropriate penalties:

### **“Tonality**

*For sound ranging from not tonal to prominently tonal the Joint Nordic Method gives a correction of between 0 dB and +6 dB for tonality. Subjectively, this can be converted to a penalty of 2 dB for a tone which is just perceptible at the noise receptor, 4 dB where it is clearly perceptible, and 6 dB where it is highly perceptible.*

### **Impulsivity**

*A correction of up to +9 dB can be applied for sound that is highly impulsive, considering both the rapidity of the change in sound level and the overall change in sound level. Subjectively, this can be converted to a penalty of 3 dB for impulsivity which is just perceptible at the noise receptor, 6 dB where it is clearly perceptible, and 9 dB where it is highly perceptible.*

### **Other sound characteristics**

*Where the specific sound features characteristics that are neither tonal nor impulsive, though otherwise are readily distinctive against the residual acoustic environment, a penalty of 3 dB can be applied.*

*NOTE 2 Where tonal and impulsive characteristics are present in the specific sound within the same reference period then these two corrections can both be taken into account. If one feature is dominant then it might be appropriate to apply a single correction. Where both features are likely to affect perception and response, the corrections ought normally to be added in a linear fashion.*

### **Intermittency**

*When the specific sound has identifiable on/off conditions, the specific sound level ought to be representative of the time period of length equal to the reference time interval which contains the greatest total amount of on time. This can necessitate measuring the specific sound over a number of shorter sampling periods that are in combination less than the reference time interval in total, and then calculating the specific sound level for the reference time interval allowing for time when the specific sound is not present. If the*

*intermittency is readily distinctive against the residual acoustic environment, a penalty of 3 dB can be applied.”*

Noise from air conditioning condenser units is typically characterised as broadband aerodynamic type noise with no tonal or impulsive elements. No rating will therefore be applied in relation to these elements.

The unit when operational is likely to run for longer periods of time rather than switching on and off multiple times in a short period, it is therefore not considered to be intermittent.

A 3dB rating penalty will be applied as the source is likely to be readily distinguishable against the residual acoustic environment.

The resultant Rating Levels are summarised below:

Location	Specific Sound Level, dB L <sub>As</sub>	Total BS4142 Character Corrections	Rating Level, dB L <sub>Ar</sub>
NSR 1	52	+ 3	55

Table 6: Rating Levels

### Rating Levels Vs Background

The Rating Levels are to be compared to the representative background sound level to determine the noise impact in accordance with BS4142.

*A Sound Rating Level at or below the background noise level is indicative of Low Impact;*

*A Sound Rating Level that exceeds the background noise level by around +5dB is likely an indication of Adverse Impact, depending on the context;*

*A Sound Rating Level that exceeds the background noise level by around +10dB is likely an indication of Significant Adverse Impact, depending on the context;*

The indicated noise impact at the identified Noise Sensitive Receptors is summarised below:

Location	Rating Level, dB L <sub>Ar</sub>	Background Sound Level, dB L <sub>A90</sub>	Difference, dB	Noise Impact
NSR 1	55	32	+23	Significant Adverse Impact

Table 7: Noise Impact

The noise impact at the receptor position is indicative of a ‘significant adverse impact’ in accordance with BS4142:2014.

## 5. BS4142:2014 Contextual Assessment

### Aspects of absolute level

Absolute levels on site, with the inclusion of the A/C unit, have been calculated using SoundPLAN to be approximately 52 dBA, 1 meter away from the condenser unit. As this level exceeds the range of

levels measured on site at night, it is not thought that the unit will benefit from any masking from the existing noise environment.

### Aspects of character

The external plant equipment is assumed to be broadband in nature, with no tonal or impulsive characteristics.

The external plant equipment will serve to control temperatures within Flat 3 and therefore will operate when required in response to demand and meteorological conditions. A + 3 dB penalty has been applied to the Initial Impact Assessment.

In context, the external plant equipment is calculated to be 23dB above the measured background sound level, therefore any characteristics of the noise output could be subjectively more noticeable above the existing noise levels on site.

### Aspects of the receptor

The NSR location is a residential property which is assumed to be accustomed to the current noise climate from the surrounding roads. No similar plant installations were observed nearby and so the A/C unit would be considered a new type of source for the area.

Taking guidance from BS8233:2014 for external amenity spaces, a desirable guideline of 50 dB  $L_{Aeq,16hr}$  and an acceptable guideline of 55 dB  $L_{Aeq,16hr}$  for noisier environments is deemed appropriate.

Calculations from the Initial Impact Assessment display external noise levels in the front garden as 55dB  $L_{ar}$ . This value is at the 'acceptable' limit of BS8233:2014, therefore deemed within the 'acceptable' category.

Guidance is also taken from 'Appendix C' of the *'Acoustics Ventilation And Overheating: Residential Design Guide – January 2020'* to specify an outside-to-inside level difference of approximately 13dB through an open window. When this is applied to the predicted night-time levels at the NSR location, internal levels within the dwellings exceed the guidelines of BS8233:2014.

### Contextual recommendations

After analysis of the existing site use in conjunction with this proposal, it is deemed necessary for mitigation to be incorporated into the proposals in order to achieve a 'Low Impact' in accordance with BS4142. Mitigation will be discussed in the next section.

## 6. Mitigation

To achieve a 'Low Impact' in accordance with BS4142, it is necessary to reduce the noise impact of the A/C unit by ~23dB.

The noise model has been updated and re-calculated based on the incorporation of a 23dB acoustic enclosure fitted around the unit. The resulting noise impact is shown below:

Location	Rating Level, dB L <sub>ar</sub>	Background Sound Level, dB L <sub>A90</sub>	Difference, dB	Noise Impact
NSR 1	32	32	0	Low

Table 8: Noise Impact

An enclosure providing a 23dB reduction in noise output from the unit is calculated to achieve a ‘Low Impact’ in accordance with BS4142.

## 7. Conclusion

A Noise Impact Assessment has been undertaken at 30 Fitzjohn’s Avenue, London in relation to the proposed installation of an external A/C unit.

Measurements of the background noise climate were undertaken from 27<sup>th</sup> – 31<sup>st</sup> October 2023 at a position deemed representative of the identified Noise Sensitive Receptor (NSR).

The nearest or most-affected Noise Sensitive Receptor has been identified as the 1<sup>st</sup> floor flat above the unit.

A BS4142:2014 Initial Impact Assessment of the predicted night-time noise impact indicated the potential for a ‘*significant adverse impact*’ at the NSR, with Rating Levels 23 dB above the representative night-time background sound level.

A further Contextual Assessment was undertaken where noise levels from the site have been assessed to the existing noise climate along with other relevant factors and deemed appropriate for the proposals to incorporate noise mitigation in the form of an acoustic enclosure.

Subsequent recalculation of the noise model shows determined a ‘Low Impact’ in accordance with BS4142, corresponding to achievement ‘*NOEL – No Observed Effect Level*’ in the NPSE.

## 8. Uncertainty

The background monitoring equipment is subject to a 1dB error margin, however, calibration before and after measurements allows the drift within the margin to be monitored and thus demonstrates that minimal drift occurred throughout the measurements.

Uncertainty can arise in the prediction of noise propagation from and around flat reflective surfaces, such as the surrounding structures present on site. This has been reduced to a minimum by utilising an acoustic modelling software that uses the validated method, ISO-9613-2, as described in BS4142.

Uncertainty in the calculated specific sound levels is further reduced by utilising manufacturer-given sound power levels.

## APPENDIX A - Measurement Details

Measurement	Kit	Start Date	Start Time	End Date	End Time
<b>M1</b>	A3	27/10/2023	12:55	31/10/2023	12:55

Table 9: Measurement Dates



Figure 3: Site Location Measurement Pictures

## APPENDIX B - Equipment Details

Kit	Equipment	Make	Model	Class	Serial Number
<b>A3</b>	Sound Meter	Svantek	971	1	41980
<b>A3</b>	Pre-Amp	Svantek	SV18	1	44331
<b>A3</b>	Microphone	ACO	7052E	1	60249
<b>1</b>	Calibrator	Svantek	SV33	1	90273

Table 10: Measurement Equipment Details

## APPENDIX C - Calibration Details

Measurement	Calibrator Ref Level (dB)	Deviation Before (dB)	Deviation After (dB)
<b>M1</b>	113.80	0.61	0.59

Table 11: Calibration Details

## APPENDIX D - Meteorology Details




Figure 4: Meteorology Data - <https://www.timeanddate.com/weather>



## APPENDIX E - Noise Survey Results




Figure 5: Measured Background Sound Levels Time History (M1): 27<sup>th</sup> – 31<sup>st</sup> October 2023

## APPENDIX F - Grid Noise Maps




Figure 6: 3D Noise Map of night-time Initial Impact Assessment




Figure 7: 3D Noise Map of night-time Mitigated Impact Assessment

## APPENDIX G - Manufacturer Technical Data Sheets



Outdoor unit SCM80ZS-W



Producer: **Mitsubishi Heavy Industries**  
Line: **SCM ZS-W**  
Model: **SCM80ZS-W**  
Cooling capacity [kW]: **8.00**  
Heating capacity [kW]: **9.30**  
Power supply: **230V/1Ph/50Hz**

### Data

#### Technical data

Cooling capacity	[kW]	8.00
Minimum cooling capacity	[kW]	1.80
Maximum cooling capacity	[kW]	9.20
Heating capacity	[kW]	9.30
Minimum heating capacity	[kW]	1.10
Maximum heating capacity	[kW]	9.80
Air flow in cooling mode	[m <sup>3</sup> /min]	56.0
Air flow in heating mode	[m <sup>3</sup> /min]	56.0
EER		4.71
COP		4.77

#### Electrical data and ranges

Maximum operating current	[A]	20.0
Power consumption - cooling *	[kW]	1.70
Power consumption - heating *	[kW]	1.95
Power supply		230V/1Ph/50Hz
Outdoor operating temperature range - cooling	[°C]	-15~46
Outdoor operating temperature range - heating	[°C]	-15~24

#### Acoustic data

Sound pressure - cooling	[dB(A)]	54.0
Sound pressure - heating	[dB(A)]	54.0
Sound power - cooling	[dB(A)]	66.0
Sound power - heating	[dB(A)]	67.0

#### Installation restrictions

Maximum refrigerant line length	[m]	70
Refrigerant line chargeless length	[m]	30
Vertical height differences (outdoor is lower)	[m]	20
Vertical height differences (outdoor is higher)	[m]	20
Additional refrigerant charge	[g/m]	20

Figure 8: Data sourced from 'www.mhi.com'

**APPENDIX H - Site Plans**




Figure 9: Site plans provided by the client

## APPENDIX I - Legislation, Policy & Guidance

Guidance for the assessment of noise affecting new residential development is given in the National Planning Policy Framework (NPPF). Section 15 of the NPPF states:

*“174. Planning policies and decisions should contribute to and enhance the natural and local environment by:*

*e) preventing new and existing development from contributing to, being put at unacceptable risk from, or being adversely affected by, unacceptable levels of...noise pollution.”*

Section 185 further states:

*“Planning policies and decisions should also ensure that new development is appropriate for its location taking into account the likely effects (including cumulative effects) of pollution on health, living conditions and the natural environment, as well as the potential sensitivity of the site or the wider area to impacts that could arise from the development. In doing so they should:*

- A. Mitigate and reduce to a minimum potential adverse impact resulting from noise from new development – and avoid noise giving rise to significant adverse impacts on health and the quality of life;*
- B. Identify and protect tranquil areas which have remained relatively undisturbed by noise and are prized for their recreational and amenity value for this reason.”*

Section 187 states:

*“Planning policies and decisions should ensure that new development can be integrated effectively with existing businesses and community facilities (such as places of worship, pubs, music venues and sports clubs). Existing businesses and facilities should not have unreasonable restrictions placed on them as a result of development permitted after they were established. Where the operation of an existing business or community facility could have a significant adverse effect on new development (including changes of use) in its vicinity, the applicant (or ‘agent of change’) should be required to provide suitable mitigation before the development has been completed.”*

To avoid and mitigate adverse noise effects on health arising from and impacting new development, the NPPF makes reference to NPSE. The Noise Policy Statement for England (NPSE) was published in March 2010 and covers all forms of noise other than occupational noise.

The Noise Policy Statement for England (NPSE) states the following aims in paragraph 2.2.

**NOEL – No Observed Effect Level.**

*This is the level below which no effect can be detected. In simple terms, below this level, there is no detectable effect on health and quality of life due to the noise.*

**LOAEL – Lowest Observed Adverse Effect Level.**

*This is the level above which adverse effects on health and quality of life can be detected.*

**SOAEL – Significant Observed Adverse Effect Level.**

*This is the level above which significant adverse effects on health and quality of life occur.*

The NPSE does not define the SOAEL numerically, stating in paragraph 2.22:

*“It is not possible to have a single objective noise-based measure that defines SOAEL that is applicable to all sources of noise in all situations. Consequently, the SOAEL is likely to be different for different noise sources, for different receptors and at different times. It is acknowledged that further research is required to increase our understanding of what may constitute a significant adverse impact on health and quality of life from noise. However, not having specific SOAEL values in the “NPSE provides the necessary policy flexibility until further evidence and suitable guidance is available.”*

There is no local or national guidance on how the three terms should be defined numerically, it is for the assessor to collate and interpret appropriate guidance on noise, such as may be found in British Standards, and correlate the guidance with the concepts of NOEL, LOAEL and SOAEL.

## BS4142:2014+A1:2019

The common standard for the assessment of industrial and commercial sound is ‘**BS4142 – Methods for rating and assessing industrial and commercial sound**’. The industrial noise assessment method in BS4142 is based on the difference between the measured ‘background sound level’ ( $L_{A90}$ ), and the ‘Rating Level’ of the industrial source, at a noise-sensitive location (NSR). BS4142:2014 states:

*“The significance of sound of an industrial and/or commercial nature depends upon both the margin by which the rating level of the specific sound source exceeds the background sound level and the context in which the sound occurs.”*

An estimation of the impact of the specific sound can be obtained by the difference between the rating sound level and the background sound level whilst considering the following:

*“A Sound Rating Level at or below the background noise level is indicative of Low Impact;  
A Sound Rating Level that exceeds the background noise level by around +5dB is likely an indication of Adverse Impact, depending on the context;  
A Sound Rating Level that exceeds the background noise level by around +10dB is likely an indication of Significant Adverse Impact, depending on the context;”*

BS4142 further states:

*“The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a negligible impact, depending on the context.”*

Achievement of a *Low Impact* in accordance with BS4142 along with a contextual assessment can be deemed to correspond to ‘*NOEL – No Observed Effect Level*’ in the NPSE.

## BS8233:2014

BS8233:2014 - *Guidance on sound insulation and noise reduction for buildings* suggests indoor ambient noise levels for dwellings in Table 4, Section 7.7.2. These are summarised below.

Activity	Location	07:00 to 23:00	23:00 to 07:00
Resting	Living Room	35 dB $L_{Aeq,16hour}$	-
Dining	Dining room/area	40 dB $L_{Aeq,16hour}$	-
Sleeping	Bedroom	35 dB $L_{Aeq,16hour}$	30 dB $L_{Aeq,8hour}$

BS8233 states that the guideline values given above are for ‘noise without character’, further stating:

*“Noise has a specific character if it contains features such as a distinguishable, discrete and continuous tone, is irregular enough to attract attention, or has strong low-frequency content, in which case lower noise limits might be appropriate.”*

Table 4 of BS8233 also has accompanying notes that were subject to additions in ProPG. The relevant notes with the additions of ProPG are given below.

*“NOTE 4 Regular individual noise events (for example, scheduled aircraft or passing trains) can cause sleep disturbance. A guideline value may be set in terms of SEL or  $L_{Amax,F}$ , depending on the character and number of events per night. Sporadic noise events could require separate values. In most circumstances in noise sensitive rooms at night (e.g. bedrooms) good acoustic design can be used so that individual noise events do not normally exceed 45dB  $L_{Amax,F}$  more than 10 times a night. However, where it is not reasonably practicable to achieve this guideline then the judgement of acceptability will depend not only on the maximum noise levels but also on factors such as the source, number, distribution, predictability and regularity of noise events.”*

*“NOTE 7 Where development is considered necessary or desirable, despite external noise levels above WHO guidelines, the internal  $L_{Aeq}$  target levels may be relaxed by up to 5 dB and reasonable internal conditions still achieved.”*



## APPENDIX J - Acoustic Terminology

To aid the understanding of acoustic terminology and the relative difference between noise levels the following background information is provided.

We perceive sound when the ear detects fluctuations in air pressure (sound waves), which are then processed by the brain and perceived as sound. Humans can hear an incredibly wide range of sound intensities ranging from jet engines to fingertips lightly brushing against each other. This range is quantified using a logarithmic scale called the decibel scale (dB). The comfortable range of the decibel scale typically ranges from 0dB (the threshold of hearing) to around 140dB. Here are some examples of common environments and their typical noise levels.

Noise Level	Environment
0 dB(A)	Threshold of hearing
20 to 30 dB(A)	Quiet bedroom at night
30 to 40 dB(A)	Living room during the day
40 to 50 dB(A)	Typical office
50 to 60 dB(A)	Inside a moving car
60 to 70 dB(A)	Typical high street
100 to 110 dB(A)	Fire alarm at 1 metre away
140 dB(A)	Threshold of pain

### Terminology

**dB (decibel)** – A unit used to quantify the pressure level of sound. Defined as 20 times the logarithm of the ratio between the root-mean-square pressure of a given sound field and a reference pressure level ( $2 \times 10^{-5}$  Pa – threshold of hearing).

**$L_{Aeq, T}$**  – The equivalent continuous sound pressure level over a stated period. It quantifies a fluctuating sound level over a given period as the equivalent continuous sound level over which the same amount of acoustic energy is contained over. This is A-weighted in order to assess human perception.

**$L_{A90}$**  – The sound level exceeded 90% of the time. Typically used to describe background noise the  $L_{90}$  is regarded as the ‘average minimum level’ and quantifies the common sound level of a fluctuating sound field i.e. the sound level that occurs 90% of the time. Alternatively,  $L_{10}$  describes the sound level exceeded 10% of the time and therefore quantifies the ‘average maximum level’ of sound which is often used during the calculation of road traffic noise.

**A-Weighting** – A standard weighting of the audible frequencies designed to reflect the response of the human ear to noise.

**$R_w$**  – The Weighted Sound Reduction Index ( $R_w$ ) is a number used to rate the effectiveness of a soundproofing system or material.