

Application ref: 2023/0294/P  
Contact: Lauren Ford  
Tel: 020 7974 3040  
Email: [Lauren.Ford@camden.gov.uk](mailto:Lauren.Ford@camden.gov.uk)  
Date: 17 January 2024

**Development Management**  
Regeneration and Planning  
London Borough of Camden  
Town Hall  
Judd Street  
London  
WC1H 9JE

Phone: 020 7974 4444

[planning@camden.gov.uk](mailto:planning@camden.gov.uk)  
[www.camden.gov.uk/planning](http://www.camden.gov.uk/planning)

Xiaoqing Liu  
13 Cosmo Place  
London  
WC1N 3AP

Dear Sir/Madam

## **DECISION**

Town and Country Planning Act 1990 (as amended)

### **Full Planning Permission Granted**

Address:  
**13 Cosmo Place**  
**London**  
**WC1N 3AP**

Proposal:  
Installation of two air conditioning units on rear first floor roof (retrospective)

Drawing Nos: Design and Access Statement, Site Photos, CP100, CP102, CP103, CP104, CP105, CP106, CP107, CP101, Acoustic Assessment of Installed Mechanical Services Equipment 7th July 2023.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted shall be carried out in accordance with the following approved plans Design and Access Statement, Site Photos, CP100, CP102, CP103, CP104, CP105, CP106, CP107, CP101, Acoustic Assessment of Installed Mechanical Services Equipment 7th July 2023.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 2 The external noise level emitted from plant, machinery or equipment at the development with specified noise mitigation hereby approved shall be lower

than the typical existing background noise level by at least 10dBA, by 15dBA where the source is tonal, as assessed according to BS4142:2014 at the nearest and/or most affected noise sensitive premises, with all machinery operating together at maximum capacity and thereafter be permanently retained.

Reason: To ensure that the amenity of occupiers of the development site/ surrounding premises is not adversely affected by noise from mechanical installations/ equipment in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017

- 3 Within one month of the date of this decision, the Air Conditioning units shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced and maintained as such.

Reason: To ensure that the amenity of occupiers of the development site and surrounding premises is not adversely affected by vibration in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 2 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444). Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.
- 3 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website (search for 'Camden Minimum Requirements' at [www.camden.gov.uk](http://www.camden.gov.uk)) or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays

and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2021.

You can find advice about your rights of appeal at:

<https://www.gov.uk/appeal-planning-decision>.

If you submit an appeal against this decision you are now eligible to use the new [submission form](#) (Before you start - Appeal a planning decision - GOV.UK).

Yours faithfully

A handwritten signature in black ink, appearing to read 'DPope', is positioned above the printed name and title of the signatory.

Daniel Pope  
Chief Planning Officer