

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

The London Fire Commissioner is the
fire and rescue authority for London

Date: 20th January 2024
Our Ref: 02/226208
Your Ref: 2023/4241/P

Dear Sir/Madam,

RECORD OF CONSULTATION

TOWN AND COUNTRY PLANNING ACT 1990

SCOPE OF WORKS: Erection of six-storey building providing 14 flats and associated

PREMISES ADDRESS: 31 Daleham Gardens London NW3 5BU

DOCUMENTS REVIEWED: 230426 Daleham Gardens Residential London Plan Policy D12 Fire Safety Compliance Statement

The London Fire Commissioner (the Commissioner) is the fire and rescue authority for London. The Commissioner is responsible for enforcing the Regulatory Reform (Fire Safety) Order 2005 (as amended) in London.

The London Fire Brigade (LFB) has been consulted with regard to the above-mentioned premises and have the following observations to make. It should be ensured that if any material amendments to this consultation is proposed, a further consultation may be required.

The Applicant is advised to ensure the plans conform to Part B of Approved Document of the Building Regulations and that the application is submitted to Building Control/Approved Inspector who in some circumstances may be obliged to consult the Fire Authority.

I also enclose Guidance note 29 on Fire Brigade Access similar to that in B5 of the Building Regulations. Particular attention should be made to paragraph 16, Water Mains and Hydrants, by the applicant. If there are any deviations from the guidance in ADB) vol 1 and 2: B5 Access and facilities for the fire service in relation to water provisions, then this information needs to be provided to the Water Office (water@london-fire.gov.uk) to discuss the proposed provision.

If there are any deviations to Brigade access and facilities then this information needs to be provided to Fire Safety Regulation (FSR-AdminSupport@london-fire.gov.uk) to review the proposed provision. Once we have received this information then the LFB can provide a response on the consultation and advice in regards to hydrants upon receipt of an appropriate site plan showing premises layout, access to it, and water supply infrastructure if available.

Any queries regarding this letter should be addressed to FSR-AdminSupport@london-fire.gov.uk if you are dissatisfied in any way with the response given, please ask to speak to the Team Leader quoting our reference.

Yours faithfully,



Assistant Commissioner (Fire Safety)

Reply To: Kiran Patel

FSR-AdminSupport@london-fire.gov.uk

The London Fire Brigade promotes the installation of sprinkler suppression systems, as there is clear evidence that they are effective in suppressing and extinguishing fires; they can help reduce the numbers of deaths and injuries from fire, and the risk to firefighters.