## | bm | certification

## **Appendix A**

Issue No: 1 Date: 31.10.2022 Certificate No: 2358-CPR-0260

Product Description				
Product name	fire e ss	Doleta Fire Alu El60 (I)		
Product description	Resistance to fii and smoke leakage class	Fire-resistant external door-sets and openable windows		
Fire resistant side		Opening towards the unexposed and the exposed window side		
Frame - width x height, mm		1300 x 1600		
*Multi framed total dimension		2600 x 2600*		
Leaf - width x height, mm		1211 x 1529		
Frame width x depth (with aluminium cladding), mm	E60 El <sub>2</sub> 60	90 x 93		
Leaf width x depth, mm	El <sub>1</sub> 60	82 x 78		
Frame and leaf material	EW60	Finger-jointed pine timber		
Leaf and frame finish or cover material		Paint		
Glass - max width x height, mm		1073 x 1391		
Hinges per leaf		≥2		
Insulation for installation		Mineral wool		
Supporting construction		Rigid		

## Field of application:

As stated in clause 13 of EVS EN 1634-1: 2014, the results of the test are directly applicable to similar constructions where one or more of the changes listed under the "Field of Direct Application" are made. Other changes are not permitted by this document.

Essential characteristics of Doleta Fire Alu EI60 (I)				
Classification characteristic		Performance	Reference to classification and test evidence	
13923	Integrity – E	E15; E20; E30; E45; E60	Test reports: GTC 59-1.2022.4 Classification reports: GTC 59-1.2022.1	
Resistance to fire	Thermal insulation – I1	l115; l120; l130; l145; l160		
	Thermal insulation – I <sub>2</sub>	l215; l220; l230; l245; l260		
	Radiation - W	W20; W30; W60	Extended application reports: NA	
Smoke leakage S	Smoke leakage at ambient temperature - S₁	NPD	Test reports: NA Classification reports: NA	
	Smoke leakage at ambient and 200 C° temperature - S <sub>200</sub>	NPD	Extended application reports: NA	
Self-closing	С	NPD	Test reports: NA	
1 martine in the			Classification reports: NA	

BM Certification SIA, 15 Jūrkalnes street, Riga, LV-1046, Latvia

This certificate remains the property of BM Certification SIA. Further clarification regarding the scope of the certificate and verification of the certificate is available through BM Certification SIA at the above address or at <u>www.bmcertification.com</u>