

Application ref: 2023/5144/A  
Contact: Ewan Campbell  
Tel: 020 7974 5458  
Email: Ewan.Campbell@camden.gov.uk  
Date: 14 February 2024

**Development Management**  
Regeneration and Planning  
London Borough of Camden  
Town Hall  
Judd Street  
London  
WC1H 9JE

Phone: 020 7974 4444

[planning@camden.gov.uk](mailto:planning@camden.gov.uk)  
[www.camden.gov.uk/planning](http://www.camden.gov.uk/planning)

Michael Fabs Ltd  
Thames House  
Charfleets Service Road  
Canvey island  
Canvey Island  
Essex  
SS80PA

Dear Sir/Madam

## **DECISION**

Town and Country Planning Act 1990

### **Advertisement Consent Granted**

Address:

**184-192 Drummond Street**  
**London**  
**NW1 3HP**

Proposal:

Installation of 2x internally illuminated fascia signs and 2x illuminated hanging signs  
Drawing Nos: 01, 02, 03, 04, 05, 06, 07, 08 (all V1)

The Council has considered your application and decided to grant consent subject to the following condition(s):

Conditions and Reasons:

- 1 No advertisement is to be displayed without the permission of the owner of the site or any other person with an interest in the site entitled to grant permission.

Reason: - As required by regulation 2(1) and Schedule 2 of the Town & Country Planning (Control of Advertisements) (England) Regulations 2007.

- 2 No advertisement shall be sited or displayed so as to
  - (a) endanger persons using any highway, railway, waterway, dock, harbour or aerodrome (civil or military);
  - (b) obscure, or hinder the ready interpretation of any traffic sign, railway signal or aid to navigation by water or air; or
  - (c) hinder the operation of any device used for the purpose of security or

surveillance or for measuring the speed of any vehicle

Reason: - As required by regulation 2(1) and Schedule 2 of the Town & Country Planning (Control of Advertisements) (England) Regulations 2007.

- 3 Any advertisement displayed and any site used for the display of advertisements, shall be maintained in a condition that does not impair the visual amenity of the site.

Reason: - As required by regulation 2(1) and Schedule 2 of the Town & Country Planning (Control of Advertisements) (England) Regulations 2007.

- 4 Any structure or hoarding erected or used principally for the purpose of displaying advertisements shall be maintained in a safe condition.

Reason: - As required by regulation 2(1) and Schedule 2 of the Town & Country Planning (Control of Advertisements) (England) Regulations 2007.

- 5 Where an advertisement is required under these Regulations to be removed, the site shall be left in a condition that does not endanger the public or impair visual amenity.

Reason: - As required by regulation 2(1) and Schedule 2 of the Town & Country Planning (Control of Advertisements) (England) Regulations 2007.

Informative(s):

- 1 Reasons for granting permission/consent-

The two externally illuminated fascia signs will be located on the southern facing elevations and are an acceptable scale in terms of height and width in relation to the elevation As per the Adverts CPG guidance on illuminance should be taken from 'The Professional Lighting Guide 05' which recommends urban areas to have a maximum illuminance of 600 cdm<sup>2</sup>. As confirmed by the application form these signs have an illuminance level of 452 cdm<sup>2</sup> and therefore provides an acceptable level in line with the character of the area. The proposal also removes signage which is in the exact same location and therefore the overall impact of the proposal is minimal.

The projecting signs are small in scale and project at an acceptable height and depth. The black material with white lettering is appropriate for the location. The sign is illuminated and located to the side of the fascia. This location, scale and illuminance, as per above, is considered acceptable.

Due to the scale, level of illuminance and location of the projecting sign there is considered to be very limited impacts on amenity as a consequence of this proposal and is therefore acceptable.

No objections have been received prior to making this decision. The planning history of the site has been taken into account when coming to this decision.

As such, the proposed development is in general accordance with policies A1, D1, D2 and D4 of the Camden Local Plan 2017. The proposed development also accords with the London Plan 2021 and the National Planning Policy Framework 2023.

- 2 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444). Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.
- 3 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website (search for 'Camden Minimum Requirements' at [www.camden.gov.uk](http://www.camden.gov.uk)) or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

- 4 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2021.

You can find advice in regard to your rights of appeal at:

<https://www.gov.uk/appeal-planning-decision>.

If you submit an appeal against this decision you are now eligible to use the new [submission form](#) (Before you start - Appeal a planning decision - GOV.UK).

Yours faithfully

A handwritten signature in black ink, appearing to read 'DPope', is positioned in the upper left corner of the page.

Daniel Pope  
Chief Planning Officer