

Application ref: 2022/3904/P
Contact: Elaine Quigley
Tel: 020 7974 5101
Email: Elaine.Quigley@camden.gov.uk
Date: 12 February 2024

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

ARD
Limewharf
Vyner Street
LONDON
E2 9DJ
United Kingdom

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:
67 Charlotte Street
London
W1T 4PH

Proposal: Installation of 3 air conditioning units on the roof of the rear extension and installation of new kitchen extract duct at low level to be connected to existing riser duct in association with commercial unit on the basement and ground floor.

Drawing Nos: 379-ARD-1110-SLP; 379-ARD-0012-EX-01; 375-ARD-1160-S_A-EX rev A; 375-ARD-1165-E_A-EX; 375-ARD-1012-P-01; 375-ARD-1161-S_A-PROP rev A; 375-ARD-1165-E_A-PROP; Noise Impact Assessment prepared by Max Fordham dated 26/07/2023; Letter from Delta House Maintenance Ltd dated 27/10/2023; Design and Access Statement Revision A prepared by AB Rogers Design dated 20/06/2023.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans:
379-ARD-1110-SLP; 379-ARD-0012-EX-01; 375-ARD-1160-S_A-EX rev A;
375-ARD-1165-E_A-EX; 375-ARD-1012-P-01; 375-ARD-1161-S_A-PROP rev A;
375-ARD-1165-E_A-PROP; Noise Impact Assessment prepared by Max Fordham dated 26/07/2023; Letter from Delta House Maintenance Ltd dated 27/10/2023; Design and Access Statement Revision A prepared by AB Rogers Design dated 20/06/2023.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies D1 and D2 of the London Borough of Camden Local Plan 2017.

- 4 Prior to use of the development, details shall be submitted to and approved in writing by the Council, of the external noise level emitted from plant/ machinery/ equipment and mitigation measures as appropriate. The measures shall ensure that the external noise level emitted from plant, machinery/ equipment will be lower than the typical existing background noise level by at least 10dBA, by 15dBA where the source is tonal, as assessed according to "Methods for rating and assessing industrial and commercial sound". at the nearest and/or most affected noise sensitive premises, with all machinery operating together at maximum capacity. The post installation noise assessment shall be carried out to confirm compliance with the noise criteria and additional steps to mitigate noise shall be taken, as necessary. Approved details shall be implemented prior to occupation of the development and thereafter be permanently retained.
- Reason: To ensure that the amenity of occupiers of the development site/ surrounding premises is not adversely affected by noise from mechanical installations/ equipment in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017

Prior to use, machinery, plant or equipment at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced and maintained as such.

Reason: To ensure that the amenity of occupiers of the development site and surrounding premises is not adversely affected by vibration in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017

- 5 Prior to use, machinery, plant or equipment at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration-isolated from the casing and adequately silenced and maintained as such.

Reason: To safeguard the amenities of the adjoining premises and the area

generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 6 Prior to commencement of the commercial use, details shall be submitted to and approved in writing by the Council, of the installation, operation, and maintenance of the odour abatement equipment and extract system, including the height of the extract duct and vertical discharge outlet, in accordance with the 'EMAQ+Control of Odour and Noise from Commercial Kitchen Exhaust Systems'. Approved details shall be implemented prior to the commencement of the use and thereafter be permanently retained.

Reason: To ensure that the amenity of occupiers of the development site/ surrounding premises is not adversely affected by cooking odour in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444). Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.
- 2 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 3 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website (search for 'Camden Minimum Requirements' at www.camden.gov.uk) or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2023.

You can find advice about your rights of appeal at:

<https://www.gov.uk/appeal-planning-decision>.

If you submit an appeal against this decision you are now eligible to use the new [submission form](#) (Before you start - Appeal a planning decision - GOV.UK).

Yours faithfully

A handwritten signature in black ink, appearing to read 'DPope', is written over a light grey rectangular background.

Daniel Pope
Chief Planning Officer