

Application ref: 2022/4136/P  
Contact: Sam Fitzpatrick  
Tel: 020 7974 1343  
Email: [sam.fitzpatrick@camden.gov.uk](mailto:sam.fitzpatrick@camden.gov.uk)  
Date: 11 March 2024

**Development Management**  
Regeneration and Planning  
London Borough of Camden  
Town Hall  
Judd Street  
London  
WC1H 9JE

Phone: 020 7974 4444

[planning@camden.gov.uk](mailto:planning@camden.gov.uk)  
[www.camden.gov.uk/planning](http://www.camden.gov.uk/planning)

Steyn Studio  
Unit G1  
Lion Works  
55 - 57 Wallis Road  
London  
E9 5LH

Dear Sir/Madam

## **DECISION**

Town and Country Planning Act 1990 (as amended)

### **Full Planning Permission Granted**

Address:

**Maisonette A Lower Ground 1st And 2nd Floor Front  
4 Lambolle Road  
London  
NW3 4HP**

Proposal: Erection of single storey outbuilding and installation of associated air source heat pump in rear garden to replace existing play equipment, for use ancillary to lower ground floor flat.

Drawing Nos: F\_0\_0001\_P1; F\_0\_100\_P1; F\_0\_102\_P1; F\_0\_300\_P1; D\_0\_100\_P1; D\_0\_101\_P1; D\_0\_102\_P1; D\_0\_200\_P1; D\_0\_300\_P1; Design and Access Statement (prepared by Steyn Studio); Noise Impact Assessment (prepared by Nova Acoustics, dated 15/01/2021); Arboricultural Report (prepared by Andrew Day Arboricultural Consultancy, dated 16/06/2021); Tree Protection Plan; Sedum Pitched Roof System Specification Details; Air Source Heat Pump Specification Details.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans:

F\_0\_0001\_P1; F\_0\_100\_P1; F\_0\_102\_P1; F\_0\_300\_P1; D\_0\_100\_P1;  
D\_0\_101\_P1; D\_0\_102\_P1; D\_0\_200\_P1; D\_0\_300\_P1.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of Policies D1 and D2 of the London Borough of Camden Local Plan 2017.

- 4 Before the relevant part of the work is begun, detailed drawings, or samples of materials as appropriate, in respect of the following, shall be submitted to and approved in writing by the local planning authority:

- a) Details of external plant enclosure for the air source heat pump (including colour and materials).

The relevant part of the works shall be carried out in accordance with the details thus approved and all approved samples shall be retained on site during the course of the works.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of Policies D1 and D2 of the London Borough of Camden Local Plan 2017.

- 5 The outbuilding hereby approved shall not be occupied at any time other than for purposes incidental to the residential use of the dwelling known as Maisonette A, Lower Ground, 1st and 2nd Floor Front, 4 Lambolle Road and shall not be used as a separate independent Class C3 dwelling or Class E business use.

Reason: To protect amenity of adjoining occupiers and also ensure the outbuilding hereby permitted does not become a self-contained dwelling, separate and apart from the original dwellinghouse in accordance with Policies H1, H6, A1 and A4 of the London Borough of Camden Local Plan 2017.

- 6 Prior to first use of the air source heat pump hereby approved, the active cooling function shall be disabled on the factory setting and the air source heat pump shall be used for the purposes of heating only.

Reason: To ensure the proposal is energy efficient and sustainable in accordance with Policy CC2 of the London Borough of Camden Local Plan 2017.

- 7 The external noise level emitted from plant, machinery, or equipment at the development with specified noise mitigation hereby approved shall be lower

than the typical existing background noise level by at least 10dBA, by 15dBA where the source is tonal, as assessed according to BS4142:2014 at the nearest and/or most affected noise sensitive premises, with all machinery operating together at maximum capacity and thereafter be permanently retained.

Reason: To ensure that the amenity of occupiers of the site and surrounding premises is not adversely affected by noise from mechanical equipment in accordance with the requirements of Policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 8 Prior to use, machinery, plant or equipment at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced and maintained as such.

Reason: To ensure that the amenity of occupiers of the development site and surrounding premises is not adversely affected by vibration in accordance with the requirements of Policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 9 Prior to the commencement of works on site, tree protection measures shall be installed and working practices adopted in accordance with the Arboricultural Report ref. AD10121 dated 16th July 2021. All trees on the site, or parts of trees growing from adjoining sites, unless shown on the permitted drawings as being removed, shall be retained and protected from damage in accordance with BS5837:2012 and with the approved protection details. The development shall be monitored by the project arboriculturalist in accordance with the approved report.

Reason: To ensure that the development will not have an adverse effect on existing trees and in order to maintain the character and amenity of the area in accordance with the requirements of Policies A2 and A3 of the Camden Local Plan 2017.

- 10 Prior to commencement of development , full details in respect of the living roof in the area indicated on the approved roof plan shall be submitted to and approved by the local planning authority. The details shall include:
- i. a detailed scheme of maintenance
  - ii. sections at a scale of 1:20 with manufacturers details demonstrating the construction and materials used
  - iii. full details of planting species and density

The living roofs shall be fully provided in accordance with the approved details prior to first occupation and thereafter retained and maintained in accordance with the approved scheme.

Reason: In order to ensure the development undertakes reasonable measures to take account of biodiversity and the water environment in accordance with policies G1, CC1, CC2, CC3, D1, D2, and A3 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 2 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444). Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.
- 3 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website (search for 'Camden Minimum Requirements' at [www.camden.gov.uk](http://www.camden.gov.uk)) or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2023.

You can find advice about your rights of appeal at:

<https://www.gov.uk/appeal-planning-decision>.

If you submit an appeal against this decision you are now eligible to use the new [submission form](#) (Before you start - Appeal a planning decision - GOV.UK).

Yours faithfully



Daniel Pope, Chief Planning Officer