

LEGEND SYMBOL DESCRIPTION ——— MCW —— MCW —— MCW ——— MAINS COLD WATER PIPE IN DUCT BOOSTED COLD WATER IN DUCT LEAK DETECTION CABLE METER DUCT ENTRY POINT THROUGH SLAB FIRE ALARM/SECURITY CABLE IN DUCT —— FA —— FA —— FA —— FA —— DATA CABLE IN DUCT

LV CABLE IN DUCT

ELEMENT.

1. FOR BUILDING SERVICES INFORMATION ONLY. 2. THIS DRAWING SHALL BE READ IN COLOUR.

3. THIS DRAWING SHALL BE READ IN CONJUNCTION

WITH THE MECHANICAL SCHEDULES & ANY ASSOCIATED SPECIFICATION. . ALL BUILDING FABRIC PENETRATIONS SHALL BE

SEALED IN ACCORDANCE TO THE BUILDING FABRIC MANUFACTURERS SPECIFICATION AND REQUIREMENTS TO ENSURE THE FIRE RESISTANCE AND/OR FIRE-RETARDANT CHARACTERISTICS AND WEATHER RESISTANCE CHARACTERISTIC OF SUCH MATERIALS ARE NOT COMPROMISED. EXACT FIRE AND WEATHER SEALING DETAILS ARE A CONTRACTOR DESIGN

5. EXTERNAL LIGHTING SHALL BE CONTROLLED VIA TIME SWITCH AND PHOTOCELL COMPLETE WITH MANUAL OVERRIDE SWITCH.


6. THE POWER & DISTRIBUTION INSTALLATION SHALL CONFORM TO THE REQUIREMENTS OF THIS DRAWING, THE LATEST EDITION OF BS7671 THE IET WIRING REGULATIONS AND ALL OTHER TENDER DOCUMENTS.

7. ALL DUCT DIMENSIONS ARE INTERNAL. DUCT ROUTES SHALL BE COMPLETE WITH SLOW RADIUS BEND PVC

8. ALL DUCTS TO BE 150mm MINIMUM UNLESS OTHERWISE STATED.

9. DUCTING SHALL BE INSTALLED WITH GLUED JOINTS WITH A STRATEGICALLY SITED ACCESS CHAMBER SYSTEM SIZED TO SUIT THE CABLES TO BE ROUTED WITHIN IT. PULL IN CHAMBERS SHALL BE SITED AS A MINIMUM AT EACH BEND AND ALSO IDEALLY NO GREATER THAN EVERY 50 METRES. THE CABLING AND DUCTING SHALL BE BURIED AT DEPTHS AND

SPACED ACCORDING TO NJUG - NATIONAL JOINT UTILITIES GUIDANCE SUITABLE FOR THE VOLTAGES OF THE INSTALLATION. ALL DUCTS SHALL BE INSTALLED AND LEFT WITH 2 NO DRAW ROPES AS A MINIMUM.



NOTES:

1. ALL DUCTS TO BE SMOOTH BORE WITH SLOW RADIUS BENDS AND COMPLETE WITH TETHERED DRAW ROPES. ALL DUCT SIZES ARE

INTERNAL DIMENSIONS. 2. FINAL DEPTH OF SERVICES AT DRAINAGE RUN CROSSOVER POINTS MAY NEED TO BE SHALLOWER OR DEEPER AS NECESSARY ADJUST OVER

LENGTH OF RUN TO AVOID BENDS. 3. BURIED SERVICES DEPTHS ARE IN ACCORDANCE WITH NATIONAL JOINT UTILITIES GROUP (NJUG)

TYPICAL M&E SERVICES UNDER FOOTWAY AND VERGE C.BROOK / E.THORNTON V.GRIMLEY / A.MOSS INSTALLATION DEPTHS
SCALE NTS M.BURKINSHAW

A.HIRST Drawing Start Date: Size: Scale: Security Classification: 14.12.2023 A0 1:50 UNCLASSIFIED Project No. - Originator - Function - Level - Form - Discipline - Drawing No. Status: Revision: 123007-AGL-CA-XX-DR-N-4001

P01 STAGE 4 - ISSUED FOR COMMENT 10.01.2024

Anderson
Green

| Noting and Old 15 975 4141 | Old 15 975 4141 | Old 14 243 5913 | Condon | Old 14 243 5913 | Condon | Old 16 243 6941 | O

STAGE 4

CAMDEN HOSTELS

CAMDEN ROAD

EXTERNAL SERVICES

www.andersongreen.co.uk Weeds 0113 243 2672

Rev. Description