

APPENDIX A – PROPOSED SPECIFICATIONS

METHODOLOGY

Performance evaluation has been undertaken using compliant software in accordance with Approved Document L of the Building Regulations 2021 and the National Calculation Methodology (NCM) for assessing the energy performance of buildings required. Modelling has been carried out as follows:

- **Non-Domestic:** Tested by a certified CIBSE Energy Assessor using government approved Dynamic Simulation Modelling Software IES virtual Environment which can assess compliance against Part L 2021 and the National Calculation Methodology (NCM). ‘Be Seen’ results have been calculated using the CIBSE TM54 methodology.

Notes:

- The Developed Design of the building has not yet been undertaken, therefore reasonable assumptions about the performance of the building envelope and building services have been made based on consultation with the design team.

BUILDING FABRIC INPUTS

| | | | U-value target | NOTES |
|------------------------------------|--|---|--------------------------|-------|
| U-VALUES OPAQUE ELEMENTS | External Walls (Existing Cavity Block) - U-value | W/m ² K | 1.6 | |
| | External Walls (Existing Terrazzo Facade) - U-value | W/m ² K | 1.55 | |
| | External Walls (New Facade) - U-value | W/m ² K | 0.15 | |
| | Basement Wall (Existing) - U-value | W/m ² K | 1.7 | |
| | Party walls | W/m ² K | - | |
| | Internal Wall - U-value | W/m ² K | - | |
| | Intermediate Floor/Ceiling - U-value | W/m ² K | - | |
| | Roof (existing) - U-value | W/m ² K | 2.3 | |
| | Roof (new) - U-value | W/m ² K | 0.1 | |
| | Ground/exposed floor (existing) - U-value | W/m ² K | 0.45 | |
| | Ground/exposed floor (new) - U-value | W/m ² K | 0.1 | |
| | Opaque Door | W/m ² K | 1.2 | |
| | Window& glazing door: u-value (including frame) | W/m ² K | 2.0 | |
| WINDOWS & GLAZING DOORS (EXISTING) | Window& glazing door - Frame factor | % | 30 | |
| | Window& glazing door - Glass solar transmission: g-value | g-value | 72 | |
| | Window - Light transmittance | LT % | 71 | |
| | Window& glazing door: u-value (including frame) | W/m ² K | 1.2 | |
| WINDOWS & GLAZING DOORS (NEW) | Window& glazing door - Frame factor | % | 20 | |
| | Window& glazing door - Glass solar transmission: g-value | g-value | 0.4 | |
| | Window - Light transmittance | LT % | 0.7 | |
| | Window& glazing door: u-value (including frame) | W/m ² K | 1.2 | |
| THERMAL MASS | Thermal Mass | - | Based on build ups | |
| THERMAL BRIDGING | Thermal bridging allowance (γ-value) | W/m ² K | Default (25% of u-value) | |
| AIR PERMEABILITY | Air leakage value (existing) | m ³ /m ² .hr @ 50Pa | 25 | |
| | Air leakage value (extension) | | 3 | |

BUILDING SERVICES INPUTS

| Space Type / Grouping | | | | | | | | |
|-----------------------|---------------------------------------|-----------------------------------|---------------------|---------------------------|-------|----------|---------------------|------------------|
| Space type | NCM building type | NCM activity | HVAC – system level | Ventilation – zonal level | DHW | Lighting | Building Management | LZC technologies |
| Office | B1: Office | Office (Open) | HVAC-1 | VENT-1 | DHW-1 | LT-1 | BM-1 | LZC-1 |
| Goods Office | B1: Office | Office (Common) | HVAC-1 | VENT-1 | DHW-1 | LT-1 | BM-1 | LZC-1 |
| Bin Store | B1: Office | Cupboard | - | - | DHW-1 | LT-2 | BM-1 | LZC-1 |
| Circulation | B1: Office | Circulation area | HVAC-1 | - | DHW-1 | LT-2 | BM-1 | LZC-1 |
| Comms Room | B1: Office | Light plant room (office: server) | HVAC-4 | - | DHW-1 | LT-2 | BM-1 | LZC-1 |
| Cycle Store | B1: Office | Cupboard | HVAC-2 | - | DHW-1 | LT-2 | BM-1 | LZC-1 |
| Plant | B1: Office | Light plant room | - | - | DHW-1 | LT-2 | BM-1 | LZC-1 |
| Laboratory | B2 to B7: Industrial process building | Laboratory | HVAC-6 | VENT-1 | DHW-1 | LT-1 | BM-1 | LZC-1 |
| Reception | B1: Office | Reception | HVAC-1 | VENT-1 | DHW-1 | LT-1 | BM-1 | LZC-1 |
| Drying Room | B1: Office | Cupboard | HVAC-2 | VENT-3 | DHW-1 | LT-2 | BM-1 | LZC-1 |
| Showers | B1: Office | Changing facilities | HVAC-2 | VENT-2 | DHW-2 | LT-2 | BM-1 | LZC-1 |
| Stairs | B1: Office | Circulation area | HVAC-3 | - | DHW-1 | LT-2 | BM-1 | LZC-1 |
| Toilet | B1: Office | Toilet | HVAC-2 | VENT-2 | DHW-1 | LT-2 | BM-1 | LZC-1 |
| Winter Garden | B1: Office | Office (Speculative) | HVAC-5 | VENT-1 | DHW-1 | LT-1 | BM-1 | LZC-1 |
| Void / Lift / Risers | Internal void or warm roof | - | - | - | - | - | - | - |

| Heating, Cooling & Ventilation (HVAC) - SYSTEM LEVEL | | HVAC-1 | HVAC-2 | HVAC-3 | HVAC-4 | HVAC-5 | HVAC-6 | |
|--|---------------------|-----------------------------------|--|--|-------------------------|---|-------------------------|--|
| System description | Description | VRF Mixed mode on perimeter | Constant volume system from VRF | Constant volume system from VRF | DX Unit | Winter Garden fan coil | VRF for labs | |
| UK NCM type | Type | VRF | Constant volume system (variable fresh air rate) | Constant volume system (variable fresh air rate) | Single Room Cooling | Fan coil systems | VRF | |
| Heating System | | | | | | | | |
| - Heat Fuel Type | Elec/gas | Elec | Elec | Elec | Elec | Elec | Elec | |
| - Heat generator seasonal efficiency | SCOP | 4 | 4 | 4 | - | 4 | 4 | |
| - Does it Qualify for ECA? | Yes | N/A | N/A | N/A | N/A | N/A | N/A | |
| Cooling System | | | | | | | | |
| - Cooling system type (assumed system in model) | Description | Heat Pump | Heat Pump | Heat Pump | Heat Pump | Heat Pump | Heat Pump | |
| - Chiller fuel type | Description | Elec | Elec | Elec | Elec | Elec | Elec | |
| - Nominal Seasonal EER | SEER | 4 | 4 | 4 | 2 | 4 | 4 | |
| - Nominal EER | EER | 3.5 | 3.5 | 3.5 | 2.5 | 3.5 | 3.5 | |
| - Does it Qualify for ECA? | Yes | N/A | N/A | N/A | N/A | N/A | N/A | |
| System adjustment | | | | | | | | |
| - Ductwork Leakage Classification | Class | Default | Default | Default | Default | Default | Default | |
| - AHU Leakage Classification | Class | Default | Default | Default | Default | Default | Default | |
| - Specific Fan Power (AHUs) | W/l/s | 1.6 | 1.6 | 1.6 | N/A | 1.6 | 1.6 | |
| - Pump type | Description | N/A | Variable speed with multiple pressure sensors | Variable speed with multiple pressure sensors | N/A | Variable speed with multiple pressure sensors | N/A | |
| Metering Provision | | | | | | | | |
| - Does the system have provision for metering? | Yes/No | Yes | Yes | Yes | Yes | Yes | Yes | |
| - Does the system warn of "out of range" values | Yes/No | Yes | Yes | Yes | Yes | Yes | Yes | |
| Ventilation & pumping | | | | | | | | |
| - Cooling/vent mechanism | Air con / nat vent | Air con | Air con | Air con | Air con | Air con | Air con | |
| - Air supply mechanism | Description | Centralised balanced | Centralised balanced | Centralised balanced | Centralised balanced | Centralised balanced | Centralised balanced | |
| - Heat recovery | % efficiency or n/a | 75 | 75 | 75 | N/A | 75 | 75 | |
| System Controls | | | | | | | | |
| - Central Time Control? | Yes | Yes | Yes | Yes | Yes | Yes | Yes | |
| - Optimum start/stop control? | No | Yes | Yes | Yes | Yes | Yes | Yes | |
| - Local Time Control? | No | Yes | Yes | Yes | Yes | Yes | Yes | |
| - Local Temperature Control? | Yes | Yes | Yes | Yes | Yes | Yes | Yes | |
| - Weather Compensation Control? | No | Yes | Yes | Yes | Yes | Yes | Yes | |
| Ventilation - ZONAL LEVEL | | VENT-1 | VENT-2 | VENT-3 | | | | |
| System description | Description | Office and laboratory | WC / Shower Extract | Drying Room Extract | | | | |
| Applies to.... | Room types | Office and laboratory areas | Toilets | Drying Room | | | | |
| Specific Fan Power (Terminal units) | W/l/s | N/A | 0.3 (extract) | 0.3 (extract) | | | | |
| Fan location | Description | N/A | Remote from room | Remote from room | | | | |
| Air change rate (if applicable) | ACH | N/A | 10 / 20 | 10 | | | | |

| | | | | | | | | |
|--|---------------------------|---|-------------------------|-----|--|--|--|--|
| Demand Control Ventilation (DCV) | Description / type | Yes / CO ₂ sensors + speed control | N/A | Yes | | | | |
| Domestic DHW | | DHW-1 | DHW-2 | | | | | |
| System description | Description | POU | ASHP for showers | | | | | |
| Heating fuel | Elec/gas | Elec | Elec | | | | | |
| Heat generator seasonal efficiency | % | 100% | 280% | | | | | |
| Is a CHP system installed? (see below for details) | Yes/No | No | No | | | | | |
| DHW delivery efficiency | % | 95 | 95 | | | | | |
| Is the system a storage system? | Yes/No | No | Yes | | | | | |
| Storage system size | litres | N/A | 1000 | | | | | |
| Storage system losses | kWh/(l.day) | N/A | 50mm insulation assumed | | | | | |
| Does the system have secondary circulation? | Yes/No | No | Yes | | | | | |
| Secondary circulation total flow & return pipe length & losses | m / W/m | N/A | 50 / 10 | | | | | |
| DHW pump power / time switch? | W / Time switch? | N/A | 200 / yes | | | | | |
| Lighting | | LT-1 | LT-2 | | | | | |
| Lamp Type | type | LED | LED | | | | | |
| Illuminance | lux | - | - | | | | | |
| Averaged lighting power density across the building OR.... | Lumens/circuit W | 100 | 100 | | | | | |
| Installed lighting Power Density | W/m ² /(100lx) | - | - | | | | | |
| PIR controls? | Description | Auto on/off | Auto on/off | | | | | |
| PIR - Parasitic Power | W/m ² | 0.1 | 0.1 | | | | | |
| PIR - Time switching? | Yes/No | Yes | Yes | | | | | |
| Automatic Daylighting Control? | Yes/No | Yes (perimeter zones only) | No | | | | | |
| Control Type (Switching/Dimming) | Switch/Dim | Dimming | - | | | | | |
| Sensor Type (Standalone/Addressable) | Stand/Add | Addressable | - | | | | | |
| Daylight - Parasitic Power | W/m ² | 0.1 | - | | | | | |
| Display lighting uses efficient lamps? | lm | 85 | 85 | | | | | |
| Building Management | | BM-1 | | | | | | |
| Electric Power Factor of the building | Power Factor Control | 0.95-0.98 | | | | | | |
| Lighting systems have provision for metering? | Yes/No | YES | | | | | | |
| Lighting systems metering warns of 'out of range' values? | Yes/No | YES | | | | | | |
| Does the system have provision for metering? | Yes/No | YES | | | | | | |
| Does the metering warn "out of range" values? | Yes/No | YES | | | | | | |
| LZC Details - PV | | LZC-1 | | | | | | |
| Area | m ² | 32 | | | | | | |
| PV module efficiency | % | 19.8 | | | | | | |
| Inclination | ° | 10 | | | | | | |
| Azimuth – from north | ° | 220 | | | | | | |
| Reference irradiance from NOCT | W/m ² | 800 | | | | | | |
| Nominal cell temperature (NOCT) | °C | 45 | | | | | | |
| Temperature coefficient for module efficiency | 1/K | -0.36 | | | | | | |
| Electrical conversion efficiency | % | 96 | | | | | | |
| Shading factor | 0-1 | 1 | | | | | | |

APPENDIX B – OVERHEATING ANALYSIS

This document summarises the outcomes of an overheating analysis undertaken to evaluate compliance of the office areas of the proposed development against the criteria established within CIBSE Technical Memoranda (TM) 52: 2013 – The limits of thermal comfort: avoiding overheating in European buildings. The following sections summarise inputs, methodology and performance and have been structured in line with the recommended by the standard.

Introduction to CIBSE TM52

TM52 is a Technical Memorandum (TM) about predicting overheating in non-domestic buildings, developed by CIBSE. TM52 methodology, which is based on Dynamic Thermal Simulation. It is intended to inform designers, developers and others responsible for defining the indoor environment in buildings. The methodology will:

- allow different designs to be compared with a common approach, based on reasonable assumptions
- support design decisions that improve comfort without cooling
- provide consistency across the industry as all consultants will be using the same methodology for overheating risk prediction.

The methodology will not:

- guarantee that people will always be comfortable in compliant spaces
- take into account unusual usage of the spaces.

CIBSE TM52 Adaptive Comfort Criteria

The following criteria is for overheating in free running buildings - buildings without active cooling:

1. The first criterion sets a limit for the number of hours that the operative temperature can exceed the threshold comfort temperature (upper limit of the range of comfort temperature) by 1 K or more during the occupied hours of a typical non-heating season (1 May to 30 September).
2. The second criterion deals with the severity of overheating within any one day, which can be as important as its frequency, the level of which is a function of both temperature rise and its duration. This criterion sets a daily limit for acceptability.
3. The third criterion sets an absolute maximum daily temperature for a room, beyond which the level of overheating is unacceptable.

The upper limits of the above criteria are:

- Criteria 1: 3%
- Criteria 2: 6 hours
- Criteria 3: 4 hours

According to CIBSE TM52 methodology, a room or building that fails any two of the three criteria is classed as overheating.

Methodology and key assumptions

This section summarises the key assumptions made for the analysis including design proposal and modelling inputs.

Modelling tool

The analysis has been undertaken using the Dynamic Thermal Simulation software IES VE – 2023 which is compliant with the methodology in CIBSE AM11: Building Performance Modelling (2015b). A 3D model has been developed which reflects the geometry and thermal performance of the proposed development.

Design proposals

Floors 2, 7 and 8 were assessed as the representative floor for compliance against the TM52 adaptive method criteria. Floorplans, sections, and elevations provided by Gortt Scott in March 2024 formed the basis of the model developed to carry out the calculations.

The following image shows the energy model developed to test the overheating risk of the office and laboratory areas.




Figure 13 Model Geometry (tested floors shaded in blue)

Weather files

In line with the recommended within the GLA's Energy Assessment Guidance (March 2022), compliance has been tested using LWC_DSY1 for the 2020's high emissions, 50% percentile scenario.

Additional testing will be undertaken if compliance with DSY-1 achieved using the 2020 versions of the following more extreme design weather years:

- DSY2 – 2003: a year with a very intense single warm spell.
- DSY3 – 1976: a year with a prolonged period of sustained warmth.

Assumptions

The following paragraphs summarise key modelling inputs.

Thermal comfort category

The thermal category assumed for this project is Cat II.

Building constructions

Please refer to section Appendix A for details of the building constructions. The constructions have been based on information provided by Gort Scott Architects and NCM build ups.

Internal Gains

Internal gains including people, lighting and equipment have been taken from the project specific Outline Specification (dated October 2023) and assumed as per NCM, where unknown.

| Internal gain | Units | All areas | Notes |
|---------------------------|-----------------------------|----------------------------------|--|
| Lighting | W/m ² | 8 | As per Design parameters |
| Equipment (Small Power) | W/m ² | 25 (Office) 75 (Laboratory) | As per Design parameters |
| Occupancy | m ² /person | 10 55 people in Winter Garden | As per Design parameters |
| Profiles of Use | Time period | Percentage of Gains (%) | Notes |
| Lighting | 09:00 – 17:00 | 100% | As per NABERS UK |
| Occupancy | 09:00 – 17:00 | 70% | As per NABERS UK |
| Occupancy – Winter Garden | 09:00 – 17:00 (Mon – Thurs) | 15% | Assumed based on design team/client feedback |
| | 12:00 – 16:00 (Fri) | 100% | |
| Equipment | 09:00 – 17:00 | 100% | As per NABERS UK |

Table 27 Internal gain assumptions and inputs

Openings

Openable windows are provided to existing office floors, these openings have been modelled in the following manner:

- Windows will have a maximum opening angle of 20-degrees. Rooflights will have a maximum opening angle of 30-degrees.
- Panels open between the hours of 7am and 6pm if the internal temperature is above 22°C.

An example of the window assignment within IESVE can be seen in the following figure.




Figure 14 IESVE MacroFlo assignment

Infiltration

An infiltration rate of 0.60 ach-1 was modelled, based on 25.0 m³/m²/hr @ 50 Pa as per CIBSE Guide A.

Mechanical ventilation

| Ventilation | Units | Laboratory | Office | Notes |
|------------------------|-------------|------------|--------|--------------------------|
| Mechanical ventilation | l/s/person | 6 ach | 14 | As per Design parameters |
| Profiles of Use | Time period | Laboratory | Office | Notes |
| Ventilation | 07:00-19:00 | - | - | As per NABERS UK |

Table 28 Ventilation assumptions and inputs

Results

A summary of results for the assessed spaces against the DSY-1 weather file are presented in the next sections. The overheating assessments of the proposed office building demonstrates the following:

- All spaces fail to comply with the CIBSE TM52 overheating criteria for free-running buildings against the DSY-1 weather file.

The overheating assessment shows that due to the design requirements for the laboratory spaces, which have very high equipment gains compared to a typical office and no openable windows (due to the requirements for a controlled environment), the spaces will not meet the overheating criteria for free-running buildings. As such, integration of active cooling is required to ensure a thermally comfortable environment for occupants and future proof the building. However, where openable windows have been provided, the risk of overheating is significantly reduced when compared to areas with a sealed façade.

Buildings with provision of active cooling need to be assessed against different thermal comfort criteria, as per CIBSE Guide A, requiring a more detailed evaluation of spaces, central plant cooling capacities and terminal units locations in addition to other comfort variables. These details will be developed and evaluated as the design progresses.

DSY1 Weather file

The table below summarise the results of the analysis against the DSY1 weather file.

| Room Name | Criteria 1 (%Hours Top-Tmax≥1K) Target ≤3% | Criteria 2 (Ma Daily Deg.Hours) Target ≤6 | Criteria 3 (Max Daily Deg.Hours) Target ≤4K | Pass/Fail |
|---------------------|--|---|---|-----------|
| Lab (P)_L2 | 92.3 | 138 | 12 | Fail |
| Lab (P)_L2 | 87.2 | 140 | 12 | Fail |
| Lab_L2 | 91.2 | 136 | 12 | Fail |
| Lab_L2 | 88.1 | 137 | 12 | Fail |
| Office (P)_L2 | 10.9 | 48 | 6 | Fail |
| Office_L2 | 11.3 | 48 | 6 | Fail |
| Lab (P)_L7 | 77.7 | 147 | 13 | Fail |
| Lab (P)_L7 | 68.3 | 140 | 13 | Fail |
| Lab_L7 | 70.4 | 139 | 13 | Fail |
| Office (P)_L7 | 6.2 | 40 | 5 | Fail |
| Office_L7 | 7.1 | 40 | 5 | Fail |
| Office (P)_L8 | 7.6 | 43 | 6 | Fail |
| Winter Garden_L8 | 4.3 | 23 | 5 | Fail |

Table 29 TM52 results – DSY-1

APPENDIX C – RENEWABLE TECHNOLOGY FEASIBILITY

PHOTOVOLTAICS

Photovoltaics (PV) are a method of generating electrical power by converting sunlight into direct current electricity using semiconducting materials. Uses of this technology have been explored for more than 50 years and nowadays it is a well-established and reliable technology which has seen prices dramatically reduce over the last decade thanks to economies of scale and the introduction of Feed-in-Tariff's in the UK (which was closed to new applicants in March 2019). This has resulted in typical financial payback of 8-9 years with returns on investment over 20 years typically in the order of 8-12%.



Table 30. Image of PV panel

Types of PV Panels

There are three basic types of PV technologies: Monocrystalline, Polycrystalline (or multi-crystalline) and Amorphous.

- **Monocrystalline cells.** These are cut from a single crystal of silicon. In appearance, it has a smooth texture and the thickness of the slice can be easily seen. These PV cells have efficiencies of 13-17% and are the most efficient of the three types of silicon PV cell. However, they require more time and energy to produce than polycrystalline silicon PV cells, and are therefore more expensive.
- **Polycrystalline (or Multi-crystalline).** Polycrystalline silicon is produced from a molten and highly pure molten silicon but using a casting process. The silicon is heated to a high temperature and cooled under controlled conditions in a mould. It sets as an irregular poly- or multi-crystalline form. The square silicon block is then cut into 0.3mm slices. The typical blue appearance is due to the application of an anti-reflective layer. The thickness of this layer determines the colour - blue has the best optical qualities. It reflects the least and absorbs the lightest. More chemical processes and fixing of the conducting grid and electrical contacts complete the process. Mass-produced polycrystalline PV cell modules have an efficiency of 11-15%.
- **Amorphous silicon.** These are made from non-crystalline silicon, similar to the material found in pocket calculators etc. The layer of semi-conductor material is only 0.5-2.0um thick, where 1um is 0.001mm. This means that considerably less raw material is necessary in their production compared with crystalline silicon PV production. The film of amorphous silicon is deposited as a gas on a

surface such as glass. Further chemical processes and the fixing of a conducting grid and electrical contacts follow. These PV cells have an efficiency of between 6-8%. Multi-junction amorphous thin film PV cells are also available which are sensitive to different wavelengths of the light spectrum. These have slightly higher efficiencies.

The favourable efficiency-to-cost ratio of polycrystalline silicon makes them the most commonly used form of PV. The amount of silicon waste produced during manufacture is also less compared to monocrystalline panels.

Applicability to Development

Installation of solar technologies (PV and/or solar hot water) requires unshaded flat or south-facing areas. The potential to install PV at roof level has been reviewed based on availability of roof, access to the panels and overshadowing. For the above reasons, **PV is deemed a viable renewable energy solution for the development.**

SOLAR HOT WATER

Solar water heating is a widely used technology within a number of hot and sunny countries and has also been proven a viable technology within the UK climate.

Heat is trapped by collectors usually located on the roof which in turn is used to preheat water, which is typically stored in a dual coil cylinder. In order to ensure adequate hot water (particularly during the winter months), and to prevent legionella, the hot water tank usually incorporates a second heating coil which is heated via a gas boiler or electric immersion heater.



Table 31. Image of an evacuated tubes solar thermal panel

Types of Solar Water Heating Collectors

There are two main types of solar water heating collectors: evacuated tubes and flat plate. **Evacuated tube** solar thermal systems are one of the most popular solar thermal systems available and are the most efficient with an efficiency of up to 70%. Their efficiency is achieved because of the way in which the evacuated tube systems are constructed, meaning they have excellent insulation and are virtually unaffected by air temperatures. The collector itself is made up of rows of insulated glass tubes which contain a vacuum with

copper pipes at their core. Water is heated in the collector and is then sent through the pipes to the water tank.

The cylindrical shape of evacuated tubes means that they are able to collect sunlight throughout the day and at all times in the year. Evacuated tube collectors are also easier to install as they are light, compact, easy to maintain - the tubes can be replaced individually if one becomes faulty - and reliable but are also the most expensive type of collectors. The system is efficient and durable with the vacuum inside the collector tubes having been proven to last for over twenty years. The reflective coating on the inside of the tube will also not degrade unless the vacuum is lost.

Flat plate solar thermal systems comprise a dark-coloured flat plate absorber with an insulated cover, a heat transfer liquid containing antifreeze to transfer heat from the absorber to the hot water tank, and an insulated backing. The flat plate feature of the solar panel increases the surface area for heat absorption. The heat transfer liquid is circulated through copper or silicon tubes contained within the flat surface plate.

In an area of the UK that produces an average level of solar energy, the amount of energy a flat plate solar collector generates equates to around one square foot panel generating one gallon (4.5 litres) of one day's hot water.

This design of solar panel is, overall, slightly less compact and less efficient when compared with an evacuated tube system, however this is reflected in a lower overall price. Solar thermal can typically provide up to 50% of total hot water demand (depending on the size of the system) and can have a life expectancy of over 25 years.

Applicability to Development

As with PV panels, installation of solar collectors requires unshaded surfaces which receive direct sunlight. SHW collectors would compete with PV panels for the available roof space. PV panels are anticipated to result in higher carbon emissions savings and are deemed more suitable for the development, therefore SHW collectors are not recommended. Therefore, Solar Hot Water **is not recommended**.

HEAT PUMPS

A heat pump is a device that is able to transfer heat from one fluid (e.g. external air) which is at a lower temperature to another fluid (e.g. internal air) at a higher temperature. This is typically achieved through use of a refrigerant that is pumped around a closed circuit of pipework using a pump (compressor). Heat pumps can be considered low or zero carbon when the heat is taken from a renewable source such as ground heat or external air. The efficiency of a heat pump is termed 'coefficient of performance' or COP and is the ratio of electrical (input) energy to drive the pump to the heat or output energy of the system. A typical air source heat pump has a COP of ~2.5 which means that for every unit of electrical energy used by the pump, the system will produce 2.5 units of heat energy (of which 1.5 units comes from the air, and the other 1 unit comes from the pumping energy). The figure below shows the main components and refrigeration cycle within a heat pump




Table 32 Heat Pump components and refrigeration cycle

Types of Heat Pumps

Heat Pumps are categorised as follows depending on the source of heat:

- A **Ground Source Heat Pump (GSHP)** uses buried coils to extract the heat from the ground into a fluid that contains a mixture of water and antifreeze. The fluid is then passed through a heat exchanger into the heat pump. The ground stays at a fairly constant temperature under the surface, so the heat pump can be used throughout the year - even in the middle of winter. Coils can be laid down horizontally, which requires larger surface areas, vertically into 100-150m deep boreholes or can be integrated into the building piles - also called thermal piles. When there is an aquifer in close proximity to the site, boreholes can be 'open loop' and directly circulate water from the aquifer as the working fluid.
- A **Water Source Heat Pump (WSHP)** produces heat in a similar way to ground source systems. Pipes are submerged in a river, stream or lake, where temperatures can remain at a relatively constant level of between 7 and 12°C. Fluid in the pipes absorbs the heat from the open water source. This fluid in turn is passed through a heat pump which transfers the heat energy to a distribution system within the building (e.g. radiators, underfloor heating or fan coil units).
- An **Air Source Heat Pump (ASHP)** takes heat directly from the external air and boosts it to a higher temperature using a heat pump. As with the above systems, the pump (compressor) needs electricity to operate. As with most Heat Pumps, ASHPs are available in different sizes and configurations. One form of ASHP is called Variable Refrigerant Flow / Volume (VRF/VRV) which can deliver both heating and cooling within a building, but also recover heat from one area and transfer the heat to another area through a refrigeration circuit. This can therefore maximise the carbon emissions savings, when installed in buildings that may have concurrent heating and cooling demand such as in offices.

Applicability to Development

Heat pumps provide a low carbon form of heating and cooling with zero local emissions, helping to minimise the impact of the building on local air quality. **Therefore, heat pumps are suitable for the development.**

WIND TURBINES

Wind turbines use the energy of the wind to generate electricity. On-shore and off-shore wind farms are one of the most widely used technologies for large scale generation of renewable energy with a total installed capacity in the UK of over 28 gigawatts with a 60%/40% on-shore/off-shore split (as of 2014). Whilst large scale turbines (1MW+) are a financially viable technology for producing clean energy, their visual impact together with the extensive area requirements make them unsuitable for use in most city/town centre locations.

With sizes typically between 0.3 and 10kW, 'Microwind' or 'Small-wind' turbines, are an alternative which can be considered for on-site use as roof-mounted devices. According to the Energy Saving Trust, forty percent of all the wind energy in Europe blows over the UK, making it an ideal country for domestic turbines. Whilst this statement applies to some areas, ground roughness due to the built landscape can create turbulence which quite often makes the use of roof mounted turbines unfeasible. Also, it is recommended that annual wind speeds average at least 6m/s to provide significant carbon emissions savings.



Table 33 Image of a wind turbine

Applicability to Development

Large scale wind turbines can present nuisances such as noise and flicker effect which are not considered acceptable for an urban development of this nature and are likely to face significant objection through the planning process.

With regards to roof-mounted wind turbines, recent studies demonstrate that they underperform in urban environments as a result of turbulent air flows, and therefore they are not deemed suitable for a building in this location. Additionally, roof-mounted turbines present issues to the currently proposed building structure due to vibration and structural loading. Therefore, Wind Turbines are **not a suitable option** for this development.

BIOMASS HEATING

Biomass heating systems for domestic or commercial use typically burn wood pellets, chips or logs to provide warmth to a single room, or multiple rooms when the heat is delivered through a central heating system. Biomass can also be produced from non-woody fuel sources such as sugar, starch or oils, although most commercially available systems in the UK work with wood-based fuel usually in the shape of wood chips or pellets. Wood, in the form of logs, can also be used in some systems, but needs to be manually fed and therefore are not viable for most commercial buildings.

Wood chips are typically the cheapest form of biomass (depending on the source of supply) but require larger storage space than pellets as they typically have a lower calorific value per unit volume of fuel as a result of their irregular shape and higher moisture content. On the other hand, pellets require more energy to manufacture and quality can significantly vary, therefore sourcing needs careful consideration. In both cases, in addition to the storage requirements of biomass fuels, long-term local reliable supply can be an issue. With limited availability in the UK, it is important to set up supply agreements when installing a biomass boiler to avoid price escalation, lack of supply or sourcing of the fuel from abroad. New sustainability criteria regarding biomass has been introduced for the Renewable Heat Incentive (RHI), which will make sure biomass meets the Government's carbon and environmental objectives, ensuring that support delivers value for money. This will affect domestic and non-domestic RHI participants, producers and traders of biomass fuels.

Biomass boilers are available in a wide range of sizes and fuel storage / feed configurations. As well as heat-only boilers, a limited number of manufacturers also produce biomass combined heat and power systems that can run on biomass fuel, although they are relatively expensive and are only available in a limited range of sizes (outputs).



Table 34. Image of wood pellets

Applicability to Development

Use of biomass heating requires a large area for the supply of pellets which must be within easy reach for the pellets/chips to be blown. The development does not have any available area, making the use of this technology unfeasible. In addition, the burning of biomass produces high particulate and NOx emissions which can reduce local air quality, particularly in urban settings. Therefore, Biomass Heating is **not considered suitable** for this development.

APPENDIX D – INDICATIVE PV PANEL SPECIFICATION AND LAYOUT





Figure 15 Indicate PV array layout, panels highlighted in blue

APPENDIX E – NON-DOMESTIC BRUKL REPORTS

BRUKL Output Document HM Government Compliance with England Building Regulations Part L 2021

Project name

Tavis House - Extension Be Lean As designed

Date: Mon Mar 18 17:04:34 2024

Administrative information

Building Details

Address:

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.25

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.25

BRUKL compliance module version: v8.1.e.1

Certifier details

Name:

Telephone number:

Address: , ,

Foundation area [m²]: 173.89

The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|-------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² :annum | 17.87 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² :annum | 15.29 |
| Target primary energy rate (TPER), kWh _{eq} /m ² :annum | 194.51 |
| Building primary energy rate (BPER), kWh _{eq} /m ² :annum | 165.41 |
| Do the building's emission and primary energy rates exceed the targets? | BER <= TER BPER <= TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _{a-Limit} | U _{a-Calc} | U _{a-Calc} | First surface with maximum value |
|---|----------------------|---------------------|---------------------|--|
| Walls* | 0.26 | 0.15 | 0.15 | GF000003:Surf[3] |
| Floors | 0.18 | 0.17 | 0.45 | GF000003:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | 0.1 | 0.1 | FF00000E:Surf[10] |
| Windows** and roof windows | 1.6 | 1.2 | 1.2 | GF000003:Surf[1] |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors^ | 1.6 | - | - | No personnel doors in building |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |
| U _{a-Limit} = Limiting area-weighted average U-values [W/(m ² K)] U _{a-Calc} = Calculated area-weighted average U-values [W/(m ² K)] * Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows. ** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position. ^ For fire doors, limiting U-value is 1.8 W/(m ² K) NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool. | | | | |
| Air permeability | Limiting standard | This building | | |
| m ³ /(h.m ²) at 50 Pa | 8 | 21.25 | | |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|-------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | >0.95 |

1- HVAC-1

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 3.09 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2* | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.

* Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

2- HVAC-6

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 3.09 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2* | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.

* Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

1- DHW-1

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|----------------|--------------------------|---|
| This building | 1.05 | - |
| Standard value | 1 | N/A |

"No zones in project where local mechanical ventilation, exhaust, or terminal unit is applicable"

| General lighting and display lighting | General luminaire | Display light source | |
|---------------------------------------|-------------------|----------------------|-----------------------------------|
| Zone name | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] |
| Standard value | 95 | 80 | 0.3 |
| Circulation_L0 | 100 | - | - |
| Circulation_L0 | 100 | - | - |
| Lab (P)_L2 | 100 | - | - |
| Lab (P)_L3 | 100 | - | - |
| Lab (P)_L4 | 100 | - | - |
| Lab (P)_L5 | 100 | - | - |
| Lab (P)_L6 | 100 | - | - |
| Lab (P)_L7 | 100 | - | - |
| Goods Office_L0 | 100 | - | - |
| Lab (P)_L1 | 100 | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|----------------|--------------------------------|-----------------------|
| Circulation_L0 | NO (-48%) | NO |
| Circulation_L0 | NO (-74%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-----------------|--------------------------------|-----------------------|
| Lab (P)_L2 | NO (-35%) | NO |
| Lab (P)_L3 | NO (-26.4%) | NO |
| Lab (P)_L4 | NO (-16.9%) | NO |
| Lab (P)_L5 | NO (-16%) | NO |
| Lab (P)_L6 | NO (-14.5%) | NO |
| Lab (P)_L7 | NO (-5%) | NO |
| Goods Office_L0 | NO (-34%) | NO |
| Lab (P)_L1 | NO (-41.8%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|----|
| Were alternative energy systems considered and analysed as part of the design process? | NO |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | NO |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|--------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 1391.2 | 1391.2 | | Retail/Financial and Professional Services |
| External area [m ²] | 1321.6 | 1321.6 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | | 3 Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 21 | 5 | 97 | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 585.87 | 393.1 | | Storage or Distribution |
| Average U-value [W/m ² K] | 0.44 | 0.3 | | Hotels |
| Alpha value* [%] | 25 | 10 | | Residential Institutions: Hospitals and Care Homes |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Residential Institutions: Residential Schools
Residential Institutions: Universities and Colleges
Secure Residential Institutions
Residential Spaces
Non-residential Institutions: Community/Day Centre
Non-residential Institutions: Libraries, Museums, and Galleries
Non-residential Institutions: Education
Non-residential Institutions: Primary Health Care Building
Non-residential Institutions: Crown and County Courts
General Assembly and Leisure, Night Clubs, and Theatres
Others: Passenger Terminals
Others: Emergency Services
Others: Miscellaneous 24hr Activities
Others: Car Parks 24 hrs
Others: Stand Alone Utility Block

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|-----------------|---------------|---------------|
| Heating | 6.85 | 2.26 |
| Cooling | 0.78 | 0.61 |
| Auxiliary | 75.6 | 85.1 |
| Lighting | 24.29 | 39.86 |
| Hot water | 4.14 | 3.94 |
| Equipment* | 29.43 | 29.43 |
| TOTAL ** | 111.65 | 131.76 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems | 0 | 0 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| Displaced electricity | 0 | 0 |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 75.98 | 32.77 |
| Primary energy [kWh _{ve} /m ²] | 165.41 | 194.51 |
| Total emissions [kg/m ²] | 15.29 | 17.87 |

| HVAC Systems Performance | | | | | | | | | |
|---|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 365.8 | 27.2 | 36.6 | 2.8 | 5.6 | 2.78 | 2.67 | 3.09 | 4 |
| Notional | 200.2 | 15.9 | 20 | 1 | 8.1 | 2.78 | 4.63 | --- | --- |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 60.9 | 7 | 6.1 | 0.7 | 77.4 | 2.78 | 2.67 | 3.09 | 4 |
| Notional | 18 | 10.1 | 1.8 | 0.6 | 87.1 | 2.78 | 4.63 | --- | --- |
| [ST] No Heating or Cooling | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Notional | 0 | 0 | 0 | 0 | 0 | 0 | 0 | --- | --- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

BRUKL Output Document



Compliance with England Building Regulations Part L 2021

Project name

Tavis House - Extension Be Green

As designed

Date: Mon Mar 18 16:51:59 2024

Administrative information

Building Details

Address:

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.25

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.25

BRUKL compliance module version: v0.1.e.1

Certifier details

Name:

Telephone number:

Address: . .

Foundation area [m²]: 173.89

The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|----------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m²annum | 17.87 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m²annum | 14.93 |
| Target primary energy rate (TPER), kWh _{eq} /m²annum | 194.51 |
| Building primary energy rate (BPER), kWh _{eq} /m²annum | 161.6 |
| Do the building's emission and primary energy rates exceed the targets? | BER =< TER BPER =< TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _{o-Limit} | U _{o-Calcd} | U _{i-Calcd} | First surface with maximum value |
|--------------------------------------|----------------------|----------------------|----------------------|--|
| Walls* | 0.26 | 0.15 | 0.15 | GF000003:Surf[3] |
| Floors | 0.18 | 0.17 | 0.45 | GF000003:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | 0.1 | 0.1 | FF00000E:Surf[10] |
| Windows** and roof windows | 1.6 | 1.2 | 1.2 | GF000003:Surf[1] |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors ^A | 1.6 | - | - | No personnel doors in building |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_{o-Limit} = Limiting area-weighted average U-values [W/(m²K)]
 U_{o-Calcd} = Calculated area-weighted average U-values [W/(m²K)]
 U_{i-Calcd} = Calculated maximum individual element U-values [W/(m²K)]
 * Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.
 ** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.
^A For fire doors, limiting U-value is 1.8 W/m²K.
 NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--------------------|-------------------|---------------|
| m³/(h.m²) at 50 Pa | 8 | 21.25 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|-------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | >0.95 |

1- HVAC-1

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.

^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

2- HVAC-6

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.

^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

1- DHW-1

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|----------------|--------------------------|---|
| This building | 1 | - |
| Standard value | 1 | N/A |

"No zones in project where local mechanical ventilation, exhaust, or terminal unit is applicable"

| General lighting and display lighting | | General luminaire | | Display light source | |
|---------------------------------------|----------------|-------------------|--|----------------------|----------------------|
| Zone name | | Efficacy [lm/W] | | Efficacy [lm/W] | Power density [W/m²] |
| | Standard value | 95 | | 80 | 0.3 |
| Circulation_L0 | | 100 | | - | - |
| Circulation_L0 | | 100 | | - | - |
| Lab (P)_L2 | | 100 | | - | - |
| Lab (P)_L3 | | 100 | | - | - |
| Lab (P)_L4 | | 100 | | - | - |
| Lab (P)_L5 | | 100 | | - | - |
| Lab (P)_L6 | | 100 | | - | - |
| Lab (P)_L7 | | 100 | | - | - |
| Goods Office_L0 | | 100 | | - | - |
| Lab (P)_L1 | | 100 | | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|----------------|--------------------------------|-----------------------|
| Circulation_L0 | NO (-48%) | NO |
| Circulation_L0 | NO (-74%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-----------------|--------------------------------|-----------------------|
| Lab (P)_L2 | NO (-35%) | NO |
| Lab (P)_L3 | NO (-26.4%) | NO |
| Lab (P)_L4 | NO (-16.9%) | NO |
| Lab (P)_L5 | NO (-16%) | NO |
| Lab (P)_L6 | NO (-14.5%) | NO |
| Lab (P)_L7 | NO (-5%) | NO |
| Goods Office_L0 | NO (-34%) | NO |
| Lab (P)_L1 | NO (-41.8%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|----|
| Were alternative energy systems considered and analysed as part of the design process? | NO |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | NO |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|--------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 1391.2 | 1391.2 | | Retail/Financial and Professional Services |
| External area [m ²] | 1321.6 | 1321.6 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | | 3 Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 21 | 5 | 97 | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 585.87 | 393.1 | | Storage or Distribution |
| Average U-value [W/m ² K] | 0.44 | 0.3 | | Hotels |
| Alpha value* [%] | 25 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|-----------------|---------------|---------------|
| Heating | 4.86 | 2.26 |
| Cooling | 0.78 | 0.61 |
| Auxiliary | 75.6 | 85.1 |
| Lighting | 24.29 | 39.86 |
| Hot water | 4.36 | 3.94 |
| Equipment* | 29.43 | 29.43 |
| TOTAL ** | 109.88 | 131.76 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems | 0.72 | 0 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| Displaced electricity | 0.72 | 0 |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 75.98 | 32.77 |
| Primary energy [kWh _{PE} /m ²] | 161.6 | 194.51 |
| Total emissions [kg/m ²] | 14.93 | 17.87 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|---|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 365.8 | 27.2 | 25.9 | 2.8 | 5.6 | 3.92 | 2.67 | 4 | 4 |
| Notional | 200.2 | 15.9 | 20 | 1 | 8.1 | 2.78 | 4.63 | --- | --- |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 60.9 | 7 | 4.3 | 0.7 | 77.4 | 3.92 | 2.67 | 4 | 4 |
| Notional | 18 | 10.1 | 1.8 | 0.6 | 87.1 | 2.78 | 4.63 | --- | --- |
| [ST] No Heating or Cooling | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Notional | 0 | 0 | 0 | 0 | 0 | 0 | 0 | --- | --- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

BRUKL Output Document



HM Government

Compliance with England Building Regulations Part L 2021

Project name

Tavis House - Refurb Appendix 3

As designed

Date: Mon Mar 18 15:57:38 2024

Administrative information

Building Details

Address:

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.25

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.25

BRUKL compliance module version: v6.1.e.1

Certifier details

Name:

Telephone number:

Address: , ,

Foundation area [m²]: 526.54

The CO₂ emission and primary energy rates of the building must not exceed the targets

The building does not comply with England Building Regulations Part L 2021

| | |
|--|--------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m²annum | 9.23 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m²annum | 16.06 |
| Target primary energy rate (TPER), kWh _{eq} /m²annum | 100.84 |
| Building primary energy rate (BPER), kWh _{eq} /m²annum | 174.62 |
| Do the building's emission and primary energy rates exceed the targets? | BER > TER BPER > TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _{a-Limit} | U _{a-Calc} | U _{i-Calc} | First surface with maximum value |
|--------------------------------------|----------------------|---------------------|---------------------|--|
| Walls* | 0.26 | 0.55 | 0.55 | LF00002C:Surf[1] |
| Floors | 0.18 | 0.25 | 0.25 | GF000004:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | 0.18 | 0.18 | LF00002C:Surf[0] |
| Windows** and roof windows | 1.6 | 1.4 | 1.4 | FF000014:Surf[1] |
| Rooflights*** | 2.2 | 1.4 | 1.4 | WN000000:Surf[16] |
| Personnel doors^ | 1.6 | 1.2 | 1.2 | CR000016:Surf[0] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_{a-Limit} = Limiting area-weighted average U-values [W/(m²K)]
 U_{a-Calc} = Calculated area-weighted average U-values [W/(m²K)]
 U_{i-Calc} = Calculated maximum individual element U-values [W/(m²K)]
 * Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.
 ** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.
 ^ For fire doors, limiting U-value is 1.8 W/m²K
 NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--------------------|-------------------|---------------|
| m³/(h.m²) at 50 Pa | 8 | 25 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | NO |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- HVAC-3

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 2.5 | 5 | 0 | 2.6 | 0.7 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system NO

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.

^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

2- HVAC-1

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 2.5 | 5 | 0 | 2.6 | 0.7 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system NO

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.

^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

3- HVAC-2

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 2.5 | 5 | 0 | 2.6 | 0.7 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system NO

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.

^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

4- HVAC-4

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 2.5 | 5 | - | - | - |
| Standard value | 2.5* | N/A | N/A | N/A | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system NO

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.

5- HVAC-6

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 2.5 | 5 | 0 | 2.6 | 0.7 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system NO

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.

^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

6- HVAC-1 (MM)

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 2.5 | 5 | 0 | 2.6 | 0.7 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | NO |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

7- HVAC-5

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 2.5 | 5 | 0 | 2.6 | 0.7 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | NO |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

1- DHW-1

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|----------------|--------------------------|---|
| This building | 1 | - |
| Standard value | 1 | N/A |

2- DHW-2

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|--|--------------------------|---|
| This building | 2 | - |
| Standard value | 2* | N/A |
| * Standard shown is for all types except absorption and gas engine heat pumps. | | |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|--|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |
| NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | |

| Zone name | SFP [W/(l/s)] | | | | | | | | | | HR efficiency | |
|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---|---------------|----------|
| ID of system type | A | B | C | D | E | F | G | H | I | | Zone | Standard |
| Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | | |
| WC_L0 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L0 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| WC_L1 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L1 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |

| Zone name | SFP [W/(l/s)] | | | | | | | | | | HR efficiency | |
|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---|---------------|----------|
| ID of system type | A | B | C | D | E | F | G | H | I | | Zone | Standard |
| Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | | |
| WC_L2 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L2 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| WC_L3 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L3 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| WC_L4 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L4 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| WC_L5 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L5 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| WC_L6 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L6 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| WC_L7 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L7 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| WC_L8 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L8 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_B1 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| WC_B1 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| Acc Shower_B1 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| Drying Room_B1 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |
| WC_B1 | - | - | 0.5 | - | - | - | - | - | - | - | - | N/A |

| General lighting and display lighting | | General luminaire | Display light source | |
|---------------------------------------|--|-------------------|----------------------|----------------------|
| Zone name | | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m²] |
| Standard value | | 95 | 80 | 0.3 |
| Stairs_L0 | | 60 | - | - |
| Circulation_L0 | | 60 | - | - |
| Lobby_L0 | | 60 | - | - |
| WC_L0 | | 60 | - | - |
| Circulation_L0 | | 60 | - | - |
| Circulation_L0 | | 60 | - | - |
| Stairs_L0 | | 60 | - | - |
| Acc WC_L0 | | 60 | - | - |
| Stairs_L1 | | 60 | - | - |
| Circulation_L1 | | 60 | - | - |
| Lobby_L1 | | 60 | - | - |
| WC_L1 | | 60 | - | - |
| Circulation_L1 | | 60 | - | - |
| Circulation_L1 | | 60 | - | - |
| Stairs_L1 | | 60 | - | - |
| Acc WC_L1 | | 60 | - | - |
| Stairs_L2 | | 60 | - | - |
| Circulation_L2 | | 60 | - | - |
| Lobby_L2 | | 60 | - | - |
| WC_L2 | | 60 | - | - |

| General lighting and display lighting | | Display light source | |
|---------------------------------------|-------------------|----------------------|----------------------|
| Zone name | General luminaire | Efficacy [lm/W] | Power density [W/m²] |
| Standard value | 95 | 80 | 0.3 |
| Circulation_L2 | 60 | - | - |
| Circulation_L2 | 60 | - | - |
| Stairs_L2 | 60 | - | - |
| Acc WC_L2 | 60 | - | - |
| Stairs_L3 | 60 | - | - |
| Circulation_L3 | 60 | - | - |
| Lobby_L3 | 60 | - | - |
| WC_L3 | 60 | - | - |
| Circulation_L3 | 60 | - | - |
| Circulation_L3 | 60 | - | - |
| Stairs_L3 | 60 | - | - |
| Acc WC_L3 | 60 | - | - |
| Stairs_L4 | 60 | - | - |
| Circulation_L4 | 60 | - | - |
| Lobby_L4 | 60 | - | - |
| WC_L4 | 60 | - | - |
| Circulation_L4 | 60 | - | - |
| Circulation_L4 | 60 | - | - |
| Stairs_L4 | 60 | - | - |
| Acc WC_L4 | 60 | - | - |
| Stairs_L5 | 60 | - | - |
| Circulation_L5 | 60 | - | - |
| Lobby_L5 | 60 | - | - |
| WC_L5 | 60 | - | - |
| Circulation_L5 | 60 | - | - |
| Circulation_L5 | 60 | - | - |
| Stairs_L5 | 60 | - | - |
| Acc WC_L5 | 60 | - | - |
| Stairs_L6 | 60 | - | - |
| Circulation_L6 | 60 | - | - |
| Lobby_L6 | 60 | - | - |
| WC_L6 | 60 | - | - |
| Circulation_L6 | 60 | - | - |
| Circulation_L6 | 60 | - | - |
| Stairs_L6 | 60 | - | - |
| Acc WC_L6 | 60 | - | - |
| Stairs_L7 | 60 | - | - |
| Circulation_L7 | 60 | - | - |
| Lobby_L7 | 60 | - | - |
| WC_L7 | 60 | - | - |
| Circulation_L7 | 60 | - | - |
| Circulation_L7 | 60 | - | - |
| Stairs_L7 | 60 | - | - |

| General lighting and display lighting | | Display light source | |
|---------------------------------------|-------------------|----------------------|----------------------|
| Zone name | General luminaire | Efficacy [lm/W] | Power density [W/m²] |
| Standard value | 95 | 80 | 0.3 |
| Acc WC_L7 | 60 | - | - |
| Lobby_L8 | 60 | - | - |
| WC_L8 | 60 | - | - |
| Circulation_L8 | 60 | - | - |
| Circulation_L8 | 60 | - | - |
| Stairs_L8 | 60 | - | - |
| Acc WC_L8 | 60 | - | - |
| Circulation_L8 | 60 | - | - |
| Stairs_L8 | 60 | - | - |
| Stairs_L8 | 60 | - | - |
| Plant_L8 | 60 | - | - |
| Plant_B1 | 60 | - | - |
| Circulation_B1 | 60 | - | - |
| Goods In Store_B1 | 60 | - | - |
| Lobby_B1 | 60 | - | - |
| Acc WC_B1 | 60 | - | - |
| Circulation_B1 | 60 | - | - |
| Stairs_B1 | 60 | - | - |
| Comms Room_B1 | 60 | - | - |
| Lab Support_B1 | 60 | - | - |
| Plant_B1 | 60 | - | - |
| Changing_B1 | 60 | - | - |
| WC_B1 | 60 | - | - |
| Acc Shower_B1 | 60 | - | - |
| Drying Room_B1 | 60 | - | - |
| WC_B1 | 60 | - | - |
| Changing_B1 | 60 | - | - |
| Post Room_B1 | 60 | - | - |
| Circulation_B1 | 60 | - | - |
| Cycle Store_B1 | 60 | - | - |
| Switch Room_B1 | 60 | - | - |
| Plant_B1 | 60 | - | - |
| Office (P)_L0 | 60 | - | - |
| Office_L7 | 60 | - | - |
| Lab_L7 | 60 | - | - |
| Lab_L0 | 60 | - | - |
| Office (P)_L0 | 60 | - | - |
| Office (P)_L0 | 60 | - | - |
| Reception (P)_L0 | 60 | 15 | 9 |
| Office_L0 | 60 | - | - |
| Reception_L0 | 60 | 15 | 9 |
| Office_L0 | 60 | - | - |
| Lab_L1 | 60 | - | - |

| General lighting and display lighting | | Display light source | |
|---------------------------------------|-------------------|----------------------|----------------------|
| Zone name | General luminaire | Efficacy [lm/W] | Power density [W/m²] |
| | Standard value | 95 | 0.3 |
| Lab_L1 | 60 | - | - |
| Office_L1 | 60 | - | - |
| Office (P)_L1 | 60 | - | - |
| Lab_L2 | 60 | - | - |
| Lab_L2 | 60 | - | - |
| Office_L2 | 60 | - | - |
| Lab_L3 | 60 | - | - |
| Lab_L3 | 60 | - | - |
| Office_L3 | 60 | - | - |
| Lab_L4 | 60 | - | - |
| Lab_L4 | 60 | - | - |
| Office_L4 | 60 | - | - |
| Lab_L5 | 60 | - | - |
| Lab_L5 | 60 | - | - |
| Office_L5 | 60 | - | - |
| Lab_L6 | 60 | - | - |
| Lab_L6 | 60 | - | - |
| Office_L6 | 60 | - | - |
| Lab(P)_L6 | 60 | - | - |
| Office(P)_L6 | 60 | - | - |
| Bin Store_L0 | 60 | - | - |
| Lab (P)_L0 | 60 | - | - |
| Lab (P)_L1 | 60 | - | - |
| Office(P)_L2 | 60 | - | - |
| Lab(P)_L2 | 60 | - | - |
| Office(P)_L3 | 60 | - | - |
| Lab(P)_L3 | 60 | - | - |
| Office(P)_L4 | 60 | - | - |
| Lab(P)_L4 | 60 | - | - |
| Office(P)_L5 | 60 | - | - |
| Lab(P)_L5 | 60 | - | - |
| Office(P)_L7 | 60 | - | - |
| Lab(P)_L7 | 60 | - | - |
| Store_L8 | 60 | - | - |
| Office(P)_L8 | 60 | - | - |
| Winter Garden_L8 | 60 | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|----------------|--------------------------------|-----------------------|
| Stairs_L0 | N/A | N/A |
| Circulation_L0 | N/A | N/A |
| Lobby_L0 | N/A | N/A |
| WC_L0 | N/A | N/A |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|----------------|--------------------------------|-----------------------|
| Circulation_L0 | N/A | N/A |
| Circulation_L0 | NO (-100%) | NO |
| Stairs_L0 | N/A | N/A |
| Acc WC_L0 | N/A | N/A |
| Stairs_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Lobby_L1 | N/A | N/A |
| WC_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Stairs_L1 | N/A | N/A |
| Acc WC_L1 | N/A | N/A |
| Stairs_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Lobby_L2 | N/A | N/A |
| WC_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Stairs_L2 | N/A | N/A |
| Acc WC_L2 | N/A | N/A |
| Stairs_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Lobby_L3 | N/A | N/A |
| WC_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Stairs_L3 | N/A | N/A |
| Acc WC_L3 | N/A | N/A |
| Stairs_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Lobby_L4 | N/A | N/A |
| WC_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Stairs_L4 | N/A | N/A |
| Acc WC_L4 | N/A | N/A |
| Stairs_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Lobby_L5 | N/A | N/A |
| WC_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Stairs_L5 | N/A | N/A |
| Acc WC_L5 | N/A | N/A |
| Stairs_L6 | N/A | N/A |
| Circulation_L6 | N/A | N/A |
| Lobby_L6 | N/A | N/A |
| WC_L6 | N/A | N/A |
| Circulation_L6 | N/A | N/A |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|------------------|--------------------------------|-----------------------|
| Circulation_L6 | N/A | N/A |
| Stairs_L6 | N/A | N/A |
| Acc WC_L6 | N/A | N/A |
| Stairs_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Lobby_L7 | N/A | N/A |
| WC_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Stairs_L7 | N/A | N/A |
| Acc WC_L7 | N/A | N/A |
| Lobby_L8 | N/A | N/A |
| WC_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Acc WC_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Circulation_B1 | N/A | N/A |
| Lobby_B1 | N/A | N/A |
| Acc WC_B1 | N/A | N/A |
| Circulation_B1 | NO (-100%) | NO |
| Stairs_B1 | N/A | N/A |
| Comms Room_B1 | N/A | N/A |
| Lab Support_B1 | N/A | N/A |
| Changing_B1 | NO (-100%) | NO |
| WC_B1 | NO (-99.9%) | NO |
| Acc Shower_B1 | N/A | N/A |
| Drying Room_B1 | NO (-100%) | NO |
| WC_B1 | N/A | N/A |
| Changing_B1 | N/A | N/A |
| Circulation_B1 | NO (-100%) | NO |
| Cycle Store_B1 | N/A | N/A |
| Office (P)_L0 | NO (-60.1%) | NO |
| Office_L7 | NO (-80%) | NO |
| Lab_L7 | NO (-58.9%) | NO |
| Lab_L0 | NO (-74.8%) | NO |
| Office (P)_L0 | NO (-3.8%) | NO |
| Office (P)_L0 | NO (-22.5%) | NO |
| Reception (P)_L0 | YES (+45.1%) | NO |
| Office_L0 | NO (-55.3%) | NO |
| Reception_L0 | YES (+46.8%) | NO |
| Office_L0 | YES (+10.6%) | NO |
| Lab_L1 | N/A | N/A |
| Lab_L1 | NO (-75.5%) | NO |
| Office_L1 | NO (-21.3%) | NO |
| Office (P)_L1 | NO (-19.6%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|------------------|--------------------------------|-----------------------|
| Lab_L2 | N/A | N/A |
| Lab_L2 | NO (-79.4%) | NO |
| Office_L2 | YES (+11.2%) | NO |
| Lab_L3 | N/A | N/A |
| Lab_L3 | NO (-77.2%) | NO |
| Office_L3 | YES (+1.2%) | NO |
| Lab_L4 | N/A | N/A |
| Lab_L4 | NO (-75.8%) | NO |
| Office_L4 | YES (+1.5%) | NO |
| Lab_L5 | N/A | N/A |
| Lab_L5 | NO (-74.9%) | NO |
| Office_L5 | YES (+2.1%) | NO |
| Lab_L6 | N/A | N/A |
| Lab_L6 | NO (-72.6%) | NO |
| Office_L6 | NO (-6.9%) | NO |
| Lab(P)_L6 | YES (+12.9%) | NO |
| Office(P)_L6 | NO (-34.9%) | NO |
| Lab (P)_L0 | NO (-16.4%) | NO |
| Lab (P)_L1 | YES (+0.8%) | NO |
| Office(P)_L2 | NO (-17.2%) | NO |
| Lab(P)_L2 | NO (-14.1%) | NO |
| Office(P)_L3 | NO (-25.6%) | NO |
| Lab(P)_L3 | NO (-6%) | NO |
| Office(P)_L4 | NO (-26.1%) | NO |
| Lab(P)_L4 | NO (-0.5%) | NO |
| Office(P)_L5 | NO (-25.8%) | NO |
| Lab(P)_L5 | YES (+3.6%) | NO |
| Office(P)_L7 | NO (-20.7%) | NO |
| Lab(P)_L7 | YES (+15%) | NO |
| Office(P)_L8 | NO (-23.5%) | NO |
| Winter Garden_L8 | YES (+89.5%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|----|
| Were alternative energy systems considered and analysed as part of the design process? | NO |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | NO |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|---------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 6213.4 | 6213.4 | | Retail/Financial and Professional Services |
| External area [m ²] | 4596.4 | 4596.4 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | 63 | Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 25 | 4 | 37 | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 2796.49 | 1580.33 | | Storage or Distribution |
| Average U-value [W/m ² K] | 0.61 | 0.34 | | Hotels |
| Alpha value* [%] | 25.3 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|------------|--------|----------|
| Heating | 6.99 | 0.82 |
| Cooling | 2.03 | 2.39 |
| Auxiliary | 56.36 | 36.94 |
| Lighting | 38.96 | 20.84 |
| Hot water | 10.92 | 7.43 |
| Equipment* | 40.14 | 40.14 |
| TOTAL ** | 115.25 | 68.42 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
 ** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems | 0 | 0 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| Displaced electricity | 0 | 0 |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 82.51 | 41.35 |
| Primary energy [kWh _{eq} /m ²] | 174.62 | 100.84 |
| Total emissions [kg/m ²] | 16.06 | 9.23 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|--|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 45.2 | 62 | 5.2 | 5.6 | 10.5 | 2.42 | 3.06 | 2.5 | 5 |
| Notional | 5.2 | 91.8 | 0.5 | 5.5 | 7.7 | 2.78 | 4.63 | --- | --- |
| [ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 82.1 | 11.9 | 9.6 | 1.5 | 39.8 | 2.37 | 2.27 | 2.5 | 5 |
| Notional | 6 | 41 | 0.6 | 2.5 | 17.1 | 2.78 | 4.63 | --- | --- |
| [ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 57.2 | 19.8 | 6.7 | 2.4 | 22.3 | 2.37 | 2.27 | 2.5 | 5 |
| Notional | 5.3 | 52.3 | 0.5 | 3.1 | 7.6 | 2.78 | 4.63 | --- | --- |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 69.6 | 16.5 | 8 | 1.5 | 10.2 | 2.42 | 3.06 | 2.5 | 5 |
| Notional | 11.3 | 34.3 | 1.1 | 3.4 | 8.3 | 2.78 | 2.84 | --- | --- |
| [ST] Single room cooling system, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 2.33 | 3.55 | 2.5 | 5 |
| Notional | 0 | 0 | 0 | 0 | 0 | 2.78 | 4.63 | --- | --- |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 158.6 | 76.9 | 18.2 | 7 | 10.2 | 2.42 | 3.06 | 2.5 | 5 |
| Notional | 58 | 19.8 | 5.8 | 1.9 | 8 | 2.78 | 2.84 | --- | --- |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 64.6 | 12 | 7.4 | 1.1 | 132.4 | 2.42 | 3.06 | 2.5 | 5 |
| Notional | 6.5 | 11.3 | 0.7 | 0.7 | 87.1 | 2.78 | 4.63 | --- | --- |
| [ST] No Heating or Cooling | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Notional | 0 | 0 | 0 | 0 | 0 | 0 | 0 | --- | --- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

BRUKL Output Document



HM Government

Compliance with England Building Regulations Part L 2021

Project name

Tavis House - Refurb Be Lean

As designed

Date: Mon Mar 18 17:07:44 2024

Administrative information

Building Details

Address:

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.25

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.25

BRUKL compliance module version: v6.1.e.1

Certifier details

Name:

Telephone number:

Address: . .

Foundation area [m²]: 526.54

The CO₂ emission and primary energy rates of the building must not exceed the targets

The building does not comply with England Building Regulations Part L 2021

| | |
|---|--------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m²·annum | 9.23 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m²·annum | 10.06 |
| Target primary energy rate (TPER), kWh _{ep} /m²·annum | 100.84 |
| Building primary energy rate (BPER), kWh _{ep} /m²·annum | 108.08 |
| Do the building's emission and primary energy rates exceed the targets? | BER > TER BPER > TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _{a-Limit} | U _{a-Calc} | U _{i-Calc} | First surface with maximum value |
|--------------------------------------|----------------------|---------------------|---------------------|--|
| Walls* | 0.26 | 1.59 | 1.7 | B1000000:Surf[3] |
| Floors | 0.18 | 0.45 | 0.45 | GF000004:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | 1.56 | 2.3 | B1000000:Surf[1] |
| Windows** and roof windows | 1.6 | 1.97 | 2 | FF00001B:Surf[3] |
| Rooflights*** | 2.2 | 1.4 | 1.4 | WN000000:Surf[16] |
| Personnel doors^ | 1.6 | 1.2 | 1.2 | CR000016:Surf[0] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_{a-Limit} = Limiting area-weighted average U-values [W/(m²K)]
U_{a-Calc} = Calculated area-weighted average U-values [W/(m²K)]
U_{i-Calc} = Calculated maximum individual element U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.
** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.
^ For fire doors, limiting U-value is 1.8 W/m²K
NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--------------------|-------------------|---------------|
| m³/(h.m²) at 50 Pa | 8 | 21.25 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|-------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | >0.95 |

1- HVAC-3

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 3.09 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

2- HVAC-1

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 3.09 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

3- HVAC-2

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 3.09 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

4- HVAC-4

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|---|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 3.09 | 2 | - | - | - |
| Standard value | 2.5* | N/A | N/A | N/A | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |

5- HVAC-6

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 3.09 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

6- HVAC-1 (MM)

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 3.09 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

7- HVAC-5

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 3.09 | 5 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

1- DHW-1

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|-----------------------|--------------------------|---|
| This building | 1.05 | - |
| Standard value | 1 | N/A |

2- DHW-2

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|--|--------------------------|---|
| This building | 3.01 | - |
| Standard value | 2* | N/A |
| * Standard shown is for all types except absorption and gas engine heat pumps. | | |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|--|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |
| NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | |

| Zone name | SFP [W/(l/s)] | | | | | | | | | | HR efficiency | |
|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---|---------------|----------|
| ID of system type | A | B | C | D | E | F | G | H | I | | Zone | Standard |
| Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | | |
| WC_L0 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L0 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |

| Zone name | SFP [W/(l/s)] | | | | | | | | | | HR efficiency | |
|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---|---------------|----------|
| ID of system type | A | B | C | D | E | F | G | H | I | | Zone | Standard |
| Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | | |
| WC_L2 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L2 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L3 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L3 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L4 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L4 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L5 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L5 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L6 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L6 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L7 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L7 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L8 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L8 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc Shower_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Drying Room_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |

| General lighting and display lighting | | General luminaire | Display light source | |
|---------------------------------------|-----|-------------------|----------------------|----------------------|
| Zone name | | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m²] |
| Standard value | 95 | 80 | 0.3 | |
| Stairs_L0 | 100 | - | - | - |
| Circulation_L0 | 100 | - | - | - |
| Lobby_L0 | 100 | - | - | - |
| WC_L0 | 100 | - | - | - |
| Circulation_L0 | 100 | - | - | - |
| Circulation_L0 | 100 | - | - | - |
| Stairs_L0 | 100 | - | - | - |
| Acc WC_L0 | 100 | - | - | - |
| Stairs_L1 | 100 | - | - | - |
| Circulation_L1 | 100 | - | - | - |
| Lobby_L1 | 100 | - | - | - |
| WC_L1 | 100 | - | - | - |
| Circulation_L1 | 100 | - | - | - |
| Circulation_L1 | 100 | - | - | - |
| Stairs_L1 | 100 | - | - | - |
| Acc WC_L1 | 100 | - | - | - |
| Stairs_L2 | 100 | - | - | - |
| Circulation_L2 | 100 | - | - | - |
| Lobby_L2 | 100 | - | - | - |
| WC_L2 | 100 | - | - | - |

| General lighting and display lighting | | General luminaire | | Display light source | |
|---------------------------------------|----------------|-------------------|--|----------------------|----------------------|
| Zone name | | Efficacy [lm/W] | | Efficacy [lm/W] | Power density [W/m²] |
| | Standard value | 95 | | 80 | 0.3 |
| Circulation_L2 | | 100 | | - | - |
| Circulation_L2 | | 100 | | - | - |
| Stairs_L2 | | 100 | | - | - |
| Acc WC_L2 | | 100 | | - | - |
| Stairs_L3 | | 100 | | - | - |
| Circulation_L3 | | 100 | | - | - |
| Lobby_L3 | | 100 | | - | - |
| WC_L3 | | 100 | | - | - |
| Circulation_L3 | | 100 | | - | - |
| Circulation_L3 | | 100 | | - | - |
| Stairs_L3 | | 100 | | - | - |
| Acc WC_L3 | | 100 | | - | - |
| Stairs_L4 | | 100 | | - | - |
| Circulation_L4 | | 100 | | - | - |
| Lobby_L4 | | 100 | | - | - |
| WC_L4 | | 100 | | - | - |
| Circulation_L4 | | 100 | | - | - |
| Circulation_L4 | | 100 | | - | - |
| Stairs_L4 | | 100 | | - | - |
| Acc WC_L4 | | 100 | | - | - |
| Stairs_L5 | | 100 | | - | - |
| Circulation_L5 | | 100 | | - | - |
| Lobby_L5 | | 100 | | - | - |
| WC_L5 | | 100 | | - | - |
| Circulation_L5 | | 100 | | - | - |
| Circulation_L5 | | 100 | | - | - |
| Stairs_L5 | | 100 | | - | - |
| Acc WC_L5 | | 100 | | - | - |
| Stairs_L6 | | 100 | | - | - |
| Circulation_L6 | | 100 | | - | - |
| Lobby_L6 | | 100 | | - | - |
| WC_L6 | | 100 | | - | - |
| Circulation_L6 | | 100 | | - | - |
| Circulation_L6 | | 100 | | - | - |
| Stairs_L6 | | 100 | | - | - |
| Acc WC_L6 | | 100 | | - | - |
| Stairs_L7 | | 100 | | - | - |
| Circulation_L7 | | 100 | | - | - |
| Lobby_L7 | | 100 | | - | - |
| WC_L7 | | 100 | | - | - |
| Circulation_L7 | | 100 | | - | - |
| Circulation_L7 | | 100 | | - | - |
| Stairs_L7 | | 100 | | - | - |

| General lighting and display lighting | | General luminaire | | Display light source | |
|---------------------------------------|----------------|-------------------|--|----------------------|----------------------|
| Zone name | | Efficacy [lm/W] | | Efficacy [lm/W] | Power density [W/m²] |
| | Standard value | 95 | | 80 | 0.3 |
| Acc WC_L7 | | 100 | | - | - |
| Lobby_L8 | | 100 | | - | - |
| WC_L8 | | 100 | | - | - |
| Circulation_L8 | | 100 | | - | - |
| Circulation_L8 | | 100 | | - | - |
| Stairs_L8 | | 100 | | - | - |
| Acc WC_L8 | | 100 | | - | - |
| Circulation_L8 | | 100 | | - | - |
| Stairs_L8 | | 100 | | - | - |
| Stairs_L8 | | 100 | | - | - |
| Plant_L8 | | 100 | | - | - |
| Plant_B1 | | 100 | | - | - |
| Circulation_B1 | | 100 | | - | - |
| Goods In Store_B1 | | 100 | | - | - |
| Lobby_B1 | | 100 | | - | - |
| Acc WC_B1 | | 100 | | - | - |
| Circulation_B1 | | 100 | | - | - |
| Stairs_B1 | | 100 | | - | - |
| Comms Room_B1 | | 100 | | - | - |
| Lab Support_B1 | | 100 | | - | - |
| Plant_B1 | | 100 | | - | - |
| Changing_B1 | | 100 | | - | - |
| WC_B1 | | 100 | | - | - |
| Acc Shower_B1 | | 100 | | - | - |
| Drying Room_B1 | | 100 | | - | - |
| WC_B1 | | 100 | | - | - |
| Changing_B1 | | 100 | | - | - |
| Post Room_B1 | | 100 | | - | - |
| Circulation_B1 | | 100 | | - | - |
| Cycle Store_B1 | | 100 | | - | - |
| Switch Room_B1 | | 100 | | - | - |
| Plant_B1 | | 100 | | - | - |
| Office (P)_L0 | | 100 | | - | - |
| Office_L7 | | 100 | | - | - |
| Lab_L7 | | 100 | | - | - |
| Lab_L0 | | 100 | | - | - |
| Office (P)_L0 | | 100 | | - | - |
| Office (P)_L0 | | 100 | | - | - |
| Reception (P)_L0 | | 100 | | 80 | 1.688 |
| Office_L0 | | 100 | | - | - |
| Reception_L0 | | 100 | | 80 | 1.687 |
| Office_L0 | | 100 | | - | - |
| Lab_L1 | | 100 | | - | - |

| General lighting and display lighting | | Display light source | |
|---------------------------------------|-------------------|----------------------|----------------------|
| Zone name | General luminaire | Efficacy [lm/W] | Power density [W/m²] |
| | Standard value | 95 | 0.3 |
| Lab_L1 | 100 | - | - |
| Office_L1 | 100 | - | - |
| Office (P)_L1 | 100 | - | - |
| Lab_L2 | 100 | - | - |
| Lab_L2 | 100 | - | - |
| Office_L2 | 100 | - | - |
| Lab_L3 | 100 | - | - |
| Lab_L3 | 100 | - | - |
| Office_L3 | 100 | - | - |
| Lab_L4 | 100 | - | - |
| Lab_L4 | 100 | - | - |
| Office_L4 | 100 | - | - |
| Lab_L5 | 100 | - | - |
| Lab_L5 | 100 | - | - |
| Office_L5 | 100 | - | - |
| Lab_L6 | 100 | - | - |
| Lab_L6 | 100 | - | - |
| Office_L6 | 100 | - | - |
| Lab(P)_L6 | 100 | - | - |
| Office(P)_L6 | 100 | - | - |
| Bin Store_L0 | 100 | - | - |
| Lab (P)_L0 | 100 | - | - |
| Lab (P)_L1 | 100 | - | - |
| Office(P)_L2 | 100 | - | - |
| Lab(P)_L2 | 100 | - | - |
| Office(P)_L3 | 100 | - | - |
| Lab(P)_L3 | 100 | - | - |
| Office(P)_L4 | 100 | - | - |
| Lab(P)_L4 | 100 | - | - |
| Office(P)_L5 | 100 | - | - |
| Lab(P)_L5 | 100 | - | - |
| Office(P)_L7 | 100 | - | - |
| Lab(P)_L7 | 100 | - | - |
| Store_L8 | 100 | - | - |
| Office(P)_L8 | 100 | - | - |
| Winter Garden_L8 | 100 | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|----------------|--------------------------------|-----------------------|
| Stairs_L0 | N/A | N/A |
| Circulation_L0 | N/A | N/A |
| Lobby_L0 | N/A | N/A |
| WC_L0 | N/A | N/A |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|----------------|--------------------------------|-----------------------|
| Circulation_L0 | N/A | N/A |
| Circulation_L0 | NO (-100%) | NO |
| Stairs_L0 | N/A | N/A |
| Acc WC_L0 | N/A | N/A |
| Stairs_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Lobby_L1 | N/A | N/A |
| WC_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Stairs_L1 | NO (-100%) | NO |
| Acc WC_L1 | N/A | N/A |
| Stairs_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Lobby_L2 | N/A | N/A |
| WC_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Stairs_L2 | N/A | N/A |
| Acc WC_L2 | N/A | N/A |
| Stairs_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Lobby_L3 | N/A | N/A |
| WC_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Stairs_L3 | N/A | N/A |
| Acc WC_L3 | N/A | N/A |
| Stairs_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Lobby_L4 | N/A | N/A |
| WC_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Stairs_L4 | N/A | N/A |
| Acc WC_L4 | N/A | N/A |
| Stairs_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Lobby_L5 | N/A | N/A |
| WC_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Stairs_L5 | N/A | N/A |
| Acc WC_L5 | N/A | N/A |
| Stairs_L6 | N/A | N/A |
| Circulation_L6 | N/A | N/A |
| Lobby_L6 | N/A | N/A |
| WC_L6 | N/A | N/A |
| Circulation_L6 | N/A | N/A |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|------------------|--------------------------------|-----------------------|
| Circulation_L6 | N/A | N/A |
| Stairs_L6 | N/A | N/A |
| Acc WC_L6 | N/A | N/A |
| Stairs_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Lobby_L7 | N/A | N/A |
| WC_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Stairs_L7 | N/A | N/A |
| Acc WC_L7 | N/A | N/A |
| Lobby_L8 | N/A | N/A |
| WC_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Acc WC_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Circulation_B1 | N/A | N/A |
| Lobby_B1 | N/A | N/A |
| Acc WC_B1 | N/A | N/A |
| Circulation_B1 | NO (-100%) | NO |
| Stairs_B1 | N/A | N/A |
| Comms Room_B1 | N/A | N/A |
| Lab Support_B1 | N/A | N/A |
| Changing_B1 | NO (-100%) | NO |
| WC_B1 | NO (-99.8%) | NO |
| Acc Shower_B1 | N/A | N/A |
| Drying Room_B1 | NO (-100%) | NO |
| WC_B1 | N/A | N/A |
| Changing_B1 | N/A | N/A |
| Circulation_B1 | NO (-100%) | NO |
| Cycle Store_B1 | N/A | N/A |
| Office (P)_L0 | NO (-56.8%) | NO |
| Office_L7 | NO (-67.7%) | NO |
| Lab_L7 | NO (-34.3%) | NO |
| Lab_L0 | NO (-59.6%) | NO |
| Office (P)_L0 | YES (+54%) | NO |
| Office (P)_L0 | YES (+22.4%) | NO |
| Reception (P)_L0 | YES (+130.9%) | NO |
| Office_L0 | NO (-35.3%) | NO |
| Reception_L0 | YES (+134.5%) | NO |
| Office_L0 | YES (+77.9%) | NO |
| Lab_L1 | N/A | N/A |
| Lab_L1 | NO (-60.8%) | NO |
| Office_L1 | YES (+27%) | NO |
| Office (P)_L1 | YES (+28.5%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|------------------|--------------------------------|-----------------------|
| Lab_L2 | N/A | N/A |
| Lab_L2 | NO (-66.9%) | NO |
| Office_L2 | YES (+79.3%) | NO |
| Lab_L3 | N/A | N/A |
| Lab_L3 | NO (-63.4%) | NO |
| Office_L3 | YES (+63.5%) | NO |
| Lab_L4 | N/A | N/A |
| Lab_L4 | NO (-61.1%) | NO |
| Office_L4 | YES (+63.9%) | NO |
| Lab_L5 | N/A | N/A |
| Lab_L5 | NO (-59.8%) | NO |
| Office_L5 | YES (+64.9%) | NO |
| Lab_L6 | N/A | N/A |
| Lab_L6 | NO (-56%) | NO |
| Office_L6 | YES (+50.3%) | NO |
| Lab(P)_L6 | YES (+79.7%) | NO |
| Office(P)_L6 | YES (+4%) | NO |
| Lab (P)_L0 | YES (+33.1%) | NO |
| Lab (P)_L1 | YES (+60.3%) | NO |
| Office(P)_L2 | YES (+32.4%) | NO |
| Lab(P)_L2 | YES (+36.9%) | NO |
| Office(P)_L3 | YES (+19%) | NO |
| Lab(P)_L3 | YES (+49.7%) | NO |
| Office(P)_L4 | YES (+18.2%) | NO |
| Lab(P)_L4 | YES (+58.4%) | NO |
| Office(P)_L5 | YES (+18.7%) | NO |
| Lab(P)_L5 | YES (+65%) | NO |
| Office(P)_L7 | YES (+26.8%) | NO |
| Lab(P)_L7 | YES (+82.7%) | NO |
| Office(P)_L8 | YES (+22.4%) | NO |
| Winter Garden_L8 | YES (+123%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|----|
| Were alternative energy systems considered and analysed as part of the design process? | NO |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | NO |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|---------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 6213.4 | 6213.4 | | Retail/Financial and Professional Services |
| External area [m ²] | 4596.4 | 4596.4 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | 63 | Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 21 | 4 | 37 | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 6726.32 | 1580.33 | | Storage or Distribution |
| Average U-value [W/m ² K] | 1.46 | 0.34 | | Hotels |
| Alpha value* [%] | 25.2 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|------------|--------|----------|
| Heating | 14.69 | 0.82 |
| Cooling | 1.72 | 2.39 |
| Auxiliary | 32.31 | 36.94 |
| Lighting | 15.94 | 20.84 |
| Hot water | 8.04 | 7.43 |
| Equipment* | 40.14 | 40.14 |
| TOTAL ** | 72.7 | 68.42 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
 ** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems | 0 | 0 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| Displaced electricity | 0 | 0 |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 163.59 | 41.35 |
| Primary energy [kWh _{pe} /m ²] | 108.08 | 100.84 |
| Total emissions [kg/m ²] | 10.06 | 9.23 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|--|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 83.3 | 48.7 | 8.3 | 5.1 | 4.5 | 2.78 | 2.67 | 3.09 | 4 |
| Notional | 5.2 | 91.8 | 0.5 | 5.5 | 7.7 | 2.78 | 4.63 | --- | --- |
| [ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 208.2 | 2.6 | 20.8 | 0.3 | 33 | 2.78 | 2.31 | 3.09 | 4 |
| Notional | 6 | 41 | 0.6 | 2.5 | 17.1 | 2.78 | 4.63 | --- | --- |
| [ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 120.9 | 10.3 | 12.1 | 1.2 | 18.4 | 2.78 | 2.31 | 3.09 | 4 |
| Notional | 5.3 | 52.3 | 0.5 | 3.1 | 7.6 | 2.78 | 4.63 | --- | --- |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 186.7 | 12.7 | 18.7 | 1.3 | 2.3 | 2.78 | 2.67 | 3.09 | 4 |
| Notional | 11.3 | 34.3 | 1.1 | 3.4 | 8.3 | 2.78 | 2.84 | --- | --- |
| [ST] Single room cooling system, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 2.78 | 1.49 | 3.09 | 2 |
| Notional | 0 | 0 | 0 | 0 | 0 | 2.78 | 4.63 | --- | --- |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 523.3 | 49.8 | 52.3 | 4.1 | 2.3 | 2.78 | 3.34 | 3.09 | 5 |
| Notional | 58 | 19.8 | 5.8 | 1.9 | 8 | 2.78 | 2.84 | --- | --- |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 146.4 | 10.7 | 14.6 | 1.1 | 77.4 | 2.78 | 2.67 | 3.09 | 4 |
| Notional | 6.5 | 11.3 | 0.7 | 0.7 | 87.1 | 2.78 | 4.63 | --- | --- |
| [ST] No Heating or Cooling | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Notional | 0 | 0 | 0 | 0 | 0 | 0 | 0 | --- | --- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

BRUKL Output Document

HM Government
Compliance with England Building Regulations Part L 2021

Project name

Tavis House - Refurb Be Green As designed

Date: Mon Mar 18 16:55:18 2024

Administrative information

Building Details

Address:

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.25

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.25

BRUKL compliance module version: v6.1.e.1

Certifier details

Name:

Telephone number:

Address: . .

Foundation area [m²]: 526.54

The CO₂ emission and primary energy rates of the building must not exceed the targets

The building does not comply with England Building Regulations Part L 2021

| | |
|---|-----------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum | 9.23 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum | 9.41 |
| Target primary energy rate (TPER), kWh _{eq} /m ² annum | 100.84 |
| Building primary energy rate (BPER), kWh _{eq} /m ² annum | 101.46 |
| Do the building's emission and primary energy rates exceed the targets? | BER > TER BPER > TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a Limit | U _a Calc | U _i Calc | First surface with maximum value |
|--|----------------------|---------------------|---------------------|--|
| Walls* | 0.26 | 1.59 | 1.7 | B1000000:Surf[3] |
| Floors | 0.18 | 0.45 | 0.45 | GF000004:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | 1.56 | 2.3 | B1000000:Surf[1] |
| Windows** and roof windows | 1.6 | 1.97 | 2 | FF00001B:Surf[3] |
| Rooflights*** | 2.2 | 1.4 | 1.4 | WN000000:Surf[16] |
| Personnel doors^ | 1.6 | 1.2 | 1.2 | CR000016:Surf[0] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |
| U _a Limit = Limiting area-weighted average U-values [W/(m ² K)] U _a Calc = Calculated area-weighted average U-values [W/(m ² K)] U _i Calc = Calculated maximum individual element U-values [W/(m ² K)] * Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows. ** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position. ^ For fire doors, limiting U-value is 1.8 W/m ² K NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool. | | | | |

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 21.25 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|-------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | >0.95 |

1- HVAC-3

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

2- HVAC-1

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

3- HVAC-2

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

4- HVAC-4

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|---|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 2.5 | 2 | - | - | - |
| Standard value | 2.5* | N/A | N/A | N/A | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |

5- HVAC-6

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

6- HVAC-1 (MM)

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

7- HVAC-5

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 5 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

1- DHW-1

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|-----------------------|--------------------------|---|
| This building | 1 | - |
| Standard value | 1 | N/A |

2- DHW-2

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|--|--------------------------|---|
| This building | 2.8 | - |
| Standard value | 2* | N/A |
| * Standard shown is for all types except absorption and gas engine heat pumps. | | |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|--|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |
| NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | |

| Zone name | SFP [W/(l/s)] | | | | | | | | | | HR efficiency | |
|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---|---------------|----------|
| ID of system type | A | B | C | D | E | F | G | H | I | | Zone | Standard |
| Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | | |
| WC_L0 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L0 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |

| Zone name | SFP [W/(l/s)] | | | | | | | | | | HR efficiency | |
|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---|---------------|----------|
| ID of system type | A | B | C | D | E | F | G | H | I | | Zone | Standard |
| Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | | |
| WC_L2 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L2 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L3 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L3 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L4 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L4 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L5 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L5 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L6 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L6 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L7 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L7 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L8 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L8 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc Shower_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Drying Room_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |

| General lighting and display lighting | | General luminaire | Display light source | |
|---------------------------------------|-----|-------------------|----------------------|----------------------|
| Zone name | | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m²] |
| Standard value | 95 | 80 | 0.3 | |
| Stairs_L0 | 100 | - | - | |
| Circulation_L0 | 100 | - | - | |
| Lobby_L0 | 100 | - | - | |
| WC_L0 | 100 | - | - | |
| Circulation_L0 | 100 | - | - | |
| Circulation_L0 | 100 | - | - | |
| Stairs_L0 | 100 | - | - | |
| Acc WC_L0 | 100 | - | - | |
| Stairs_L1 | 100 | - | - | |
| Circulation_L1 | 100 | - | - | |
| Lobby_L1 | 100 | - | - | |
| WC_L1 | 100 | - | - | |
| Circulation_L1 | 100 | - | - | |
| Circulation_L1 | 100 | - | - | |
| Stairs_L1 | 100 | - | - | |
| Acc WC_L1 | 100 | - | - | |
| Stairs_L2 | 100 | - | - | |
| Circulation_L2 | 100 | - | - | |
| Lobby_L2 | 100 | - | - | |
| WC_L2 | 100 | - | - | |

| General lighting and display lighting | | Display light source | |
|---------------------------------------|-------------------|----------------------|----------------------|
| Zone name | General luminaire | Efficacy [lm/W] | Power density [W/m²] |
| Standard value | 95 | 80 | 0.3 |
| Circulation_L2 | 100 | - | - |
| Circulation_L2 | 100 | - | - |
| Stairs_L2 | 100 | - | - |
| Acc WC_L2 | 100 | - | - |
| Stairs_L3 | 100 | - | - |
| Circulation_L3 | 100 | - | - |
| Lobby_L3 | 100 | - | - |
| WC_L3 | 100 | - | - |
| Circulation_L3 | 100 | - | - |
| Circulation_L3 | 100 | - | - |
| Stairs_L3 | 100 | - | - |
| Acc WC_L3 | 100 | - | - |
| Stairs_L4 | 100 | - | - |
| Circulation_L4 | 100 | - | - |
| Lobby_L4 | 100 | - | - |
| WC_L4 | 100 | - | - |
| Circulation_L4 | 100 | - | - |
| Circulation_L4 | 100 | - | - |
| Stairs_L4 | 100 | - | - |
| Acc WC_L4 | 100 | - | - |
| Stairs_L5 | 100 | - | - |
| Circulation_L5 | 100 | - | - |
| Lobby_L5 | 100 | - | - |
| WC_L5 | 100 | - | - |
| Circulation_L5 | 100 | - | - |
| Circulation_L5 | 100 | - | - |
| Stairs_L5 | 100 | - | - |
| Acc WC_L5 | 100 | - | - |
| Stairs_L6 | 100 | - | - |
| Circulation_L6 | 100 | - | - |
| Lobby_L6 | 100 | - | - |
| WC_L6 | 100 | - | - |
| Circulation_L6 | 100 | - | - |
| Circulation_L6 | 100 | - | - |
| Stairs_L6 | 100 | - | - |
| Acc WC_L6 | 100 | - | - |
| Stairs_L7 | 100 | - | - |
| Circulation_L7 | 100 | - | - |
| Lobby_L7 | 100 | - | - |
| WC_L7 | 100 | - | - |
| Circulation_L7 | 100 | - | - |
| Circulation_L7 | 100 | - | - |
| Stairs_L7 | 100 | - | - |

| General lighting and display lighting | | Display light source | |
|---------------------------------------|-------------------|----------------------|----------------------|
| Zone name | General luminaire | Efficacy [lm/W] | Power density [W/m²] |
| Standard value | 95 | 80 | 0.3 |
| Acc WC_L7 | 100 | - | - |
| Lobby_L8 | 100 | - | - |
| WC_L8 | 100 | - | - |
| Circulation_L8 | 100 | - | - |
| Circulation_L8 | 100 | - | - |
| Stairs_L8 | 100 | - | - |
| Acc WC_L8 | 100 | - | - |
| Circulation_L8 | 100 | - | - |
| Stairs_L8 | 100 | - | - |
| Stairs_L8 | 100 | - | - |
| Plant_L8 | 100 | - | - |
| Plant_B1 | 100 | - | - |
| Circulation_B1 | 100 | - | - |
| Goods In Store_B1 | 100 | - | - |
| Lobby_B1 | 100 | - | - |
| Acc WC_B1 | 100 | - | - |
| Circulation_B1 | 100 | - | - |
| Stairs_B1 | 100 | - | - |
| Comms Room_B1 | 100 | - | - |
| Lab Support_B1 | 100 | - | - |
| Plant_B1 | 100 | - | - |
| Changing_B1 | 100 | - | - |
| WC_B1 | 100 | - | - |
| Acc Shower_B1 | 100 | - | - |
| Drying Room_B1 | 100 | - | - |
| WC_B1 | 100 | - | - |
| Changing_B1 | 100 | - | - |
| Post Room_B1 | 100 | - | - |
| Circulation_B1 | 100 | - | - |
| Cycle Store_B1 | 100 | - | - |
| Switch Room_B1 | 100 | - | - |
| Plant_B1 | 100 | - | - |
| Office (P)_L0 | 100 | - | - |
| Office_L7 | 100 | - | - |
| Lab_L7 | 100 | - | - |
| Lab_L0 | 100 | - | - |
| Office (P)_L0 | 100 | - | - |
| Office (P)_L0 | 100 | - | - |
| Reception (P)_L0 | 100 | 80 | 1.688 |
| Office_L0 | 100 | - | - |
| Reception_L0 | 100 | 80 | 1.687 |
| Office_L0 | 100 | - | - |
| Lab_L1 | 100 | - | - |

| General lighting and display lighting | | Display light source | |
|---------------------------------------|-------------------|----------------------|----------------------|
| Zone name | General luminaire | Efficacy [lm/W] | Power density [W/m²] |
| Standard value | 95 | 80 | 0.3 |
| Lab_L1 | 100 | - | - |
| Office_L1 | 100 | - | - |
| Office (P)_L1 | 100 | - | - |
| Lab_L2 | 100 | - | - |
| Lab_L2 | 100 | - | - |
| Office_L2 | 100 | - | - |
| Lab_L3 | 100 | - | - |
| Lab_L3 | 100 | - | - |
| Office_L3 | 100 | - | - |
| Lab_L4 | 100 | - | - |
| Lab_L4 | 100 | - | - |
| Office_L4 | 100 | - | - |
| Lab_L5 | 100 | - | - |
| Lab_L5 | 100 | - | - |
| Office_L5 | 100 | - | - |
| Lab_L6 | 100 | - | - |
| Lab_L6 | 100 | - | - |
| Office_L6 | 100 | - | - |
| Lab(P)_L6 | 100 | - | - |
| Office(P)_L6 | 100 | - | - |
| Bin Store_L0 | 100 | - | - |
| Lab (P)_L0 | 100 | - | - |
| Lab (P)_L1 | 100 | - | - |
| Office(P)_L2 | 100 | - | - |
| Lab(P)_L2 | 100 | - | - |
| Office(P)_L3 | 100 | - | - |
| Lab(P)_L3 | 100 | - | - |
| Office(P)_L4 | 100 | - | - |
| Lab(P)_L4 | 100 | - | - |
| Office(P)_L5 | 100 | - | - |
| Lab(P)_L5 | 100 | - | - |
| Office(P)_L7 | 100 | - | - |
| Lab(P)_L7 | 100 | - | - |
| Store_L8 | 100 | - | - |
| Office(P)_L8 | 100 | - | - |
| Winter Garden_L8 | 100 | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|----------------|--------------------------------|-----------------------|
| Stairs_L0 | N/A | N/A |
| Circulation_L0 | N/A | N/A |
| Lobby_L0 | N/A | N/A |
| WC_L0 | N/A | N/A |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|----------------|--------------------------------|-----------------------|
| Circulation_L0 | N/A | N/A |
| Circulation_L0 | NO (-100%) | NO |
| Stairs_L0 | N/A | N/A |
| Acc WC_L0 | N/A | N/A |
| Stairs_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Lobby_L1 | N/A | N/A |
| WC_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Stairs_L1 | NO (-100%) | NO |
| Acc WC_L1 | N/A | N/A |
| Stairs_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Lobby_L2 | N/A | N/A |
| WC_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Stairs_L2 | N/A | N/A |
| Acc WC_L2 | N/A | N/A |
| Stairs_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Lobby_L3 | N/A | N/A |
| WC_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Stairs_L3 | N/A | N/A |
| Acc WC_L3 | N/A | N/A |
| Stairs_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Lobby_L4 | N/A | N/A |
| WC_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Stairs_L4 | N/A | N/A |
| Acc WC_L4 | N/A | N/A |
| Stairs_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Lobby_L5 | N/A | N/A |
| WC_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Stairs_L5 | N/A | N/A |
| Acc WC_L5 | N/A | N/A |
| Stairs_L6 | N/A | N/A |
| Circulation_L6 | N/A | N/A |
| Lobby_L6 | N/A | N/A |
| WC_L6 | N/A | N/A |
| Circulation_L6 | N/A | N/A |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|------------------|--------------------------------|-----------------------|
| Circulation_L6 | N/A | N/A |
| Stairs_L6 | N/A | N/A |
| Acc WC_L6 | N/A | N/A |
| Stairs_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Lobby_L7 | N/A | N/A |
| WC_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Stairs_L7 | N/A | N/A |
| Acc WC_L7 | N/A | N/A |
| Lobby_L8 | N/A | N/A |
| WC_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Acc WC_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Circulation_B1 | N/A | N/A |
| Lobby_B1 | N/A | N/A |
| Acc WC_B1 | N/A | N/A |
| Circulation_B1 | NO (-100%) | NO |
| Stairs_B1 | N/A | N/A |
| Comms Room_B1 | N/A | N/A |
| Lab Support_B1 | N/A | N/A |
| Changing_B1 | NO (-100%) | NO |
| WC_B1 | NO (-99.8%) | NO |
| Acc Shower_B1 | N/A | N/A |
| Drying Room_B1 | NO (-100%) | NO |
| WC_B1 | N/A | N/A |
| Changing_B1 | N/A | N/A |
| Circulation_B1 | NO (-100%) | NO |
| Cycle Store_B1 | N/A | N/A |
| Office (P)_L0 | NO (-56.8%) | NO |
| Office_L7 | NO (-67.7%) | NO |
| Lab_L7 | NO (-34.3%) | NO |
| Lab_L0 | NO (-59.6%) | NO |
| Office (P)_L0 | YES (+54%) | NO |
| Office (P)_L0 | YES (+22.4%) | NO |
| Reception (P)_L0 | YES (+130.9%) | NO |
| Office_L0 | NO (-35.3%) | NO |
| Reception_L0 | YES (+134.5%) | NO |
| Office_L0 | YES (+77.9%) | NO |
| Lab_L1 | N/A | N/A |
| Lab_L1 | NO (-60.8%) | NO |
| Office_L1 | YES (+27%) | NO |
| Office (P)_L1 | YES (+28.5%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|------------------|--------------------------------|-----------------------|
| Lab_L2 | N/A | N/A |
| Lab_L2 | NO (-66.9%) | NO |
| Office_L2 | YES (+79.3%) | NO |
| Lab_L3 | N/A | N/A |
| Lab_L3 | NO (-63.4%) | NO |
| Office_L3 | YES (+63.5%) | NO |
| Lab_L4 | N/A | N/A |
| Lab_L4 | NO (-61.1%) | NO |
| Office_L4 | YES (+63.9%) | NO |
| Lab_L5 | N/A | N/A |
| Lab_L5 | NO (-59.8%) | NO |
| Office_L5 | YES (+64.9%) | NO |
| Lab_L6 | N/A | N/A |
| Lab_L6 | NO (-56%) | NO |
| Office_L6 | YES (+50.3%) | NO |
| Lab(P)_L6 | YES (+79.7%) | NO |
| Office(P)_L6 | YES (+4%) | NO |
| Lab (P)_L0 | YES (+33.1%) | NO |
| Lab (P)_L1 | YES (+60.3%) | NO |
| Office(P)_L2 | YES (+32.4%) | NO |
| Lab(P)_L2 | YES (+36.9%) | NO |
| Office(P)_L3 | YES (+19%) | NO |
| Lab(P)_L3 | YES (+49.7%) | NO |
| Office(P)_L4 | YES (+18.2%) | NO |
| Lab(P)_L4 | YES (+58.4%) | NO |
| Office(P)_L5 | YES (+18.7%) | NO |
| Lab(P)_L5 | YES (+65%) | NO |
| Office(P)_L7 | YES (+26.8%) | NO |
| Lab(P)_L7 | YES (+82.7%) | NO |
| Office(P)_L8 | YES (+22.4%) | NO |
| Winter Garden_L8 | YES (+123%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|----|
| Were alternative energy systems considered and analysed as part of the design process? | NO |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | NO |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|--|---------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 6213.4 | 6213.4 | | Retail/Financial and Professional Services |
| External area [m ²] | 4596.4 | 4596.4 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | 63 | Offices and Workshop Businesses |
| Infiltration [m ³ /h/m ² @ 50Pa] | 21 | 4 | 37 | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 6726.32 | 1580.33 | | Storage or Distribution |
| Average U-value [W/m ² K] | 1.46 | 0.34 | | Hotels |
| Alpha value* [%] | 25.2 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|------------|--------|----------|
| Heating | 10.52 | 0.82 |
| Cooling | 1.72 | 2.39 |
| Auxiliary | 32.31 | 36.94 |
| Lighting | 15.94 | 20.84 |
| Hot water | 8.59 | 7.43 |
| Equipment* | 40.14 | 40.14 |
| TOTAL** | 69.08 | 68.42 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
 ** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems | 0.7 | 0 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| Displaced electricity | 0.7 | 0 |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 163.59 | 41.35 |
| Primary energy [kWh _{PE} /m ²] | 101.46 | 100.84 |
| Total emissions [kg/m ²] | 9.41 | 9.23 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|--|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 83.3 | 48.7 | 5.9 | 5.1 | 4.5 | 3.92 | 2.67 | 4 | 4 |
| Notional | 5.2 | 91.8 | 0.5 | 5.5 | 7.7 | 2.78 | 4.63 | --- | --- |
| [ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 208.2 | 2.6 | 16.2 | 0.3 | 33 | 3.57 | 2.31 | 4 | 4 |
| Notional | 6 | 41 | 0.6 | 2.5 | 17.1 | 2.78 | 4.63 | --- | --- |
| [ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 120.9 | 10.3 | 9.4 | 1.2 | 18.4 | 3.57 | 2.31 | 4 | 4 |
| Notional | 5.3 | 52.3 | 0.5 | 3.1 | 7.6 | 2.78 | 4.63 | --- | --- |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 186.7 | 12.7 | 13.2 | 1.3 | 2.3 | 3.92 | 2.67 | 4 | 4 |
| Notional | 11.3 | 34.3 | 1.1 | 3.4 | 8.3 | 2.78 | 2.84 | --- | --- |
| [ST] Single room cooling system, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 2.45 | 1.49 | 2.5 | 2 |
| Notional | 0 | 0 | 0 | 0 | 0 | 2.78 | 4.63 | --- | --- |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 523.3 | 49.8 | 37.1 | 4.1 | 2.3 | 3.92 | 3.34 | 4 | 5 |
| Notional | 58 | 19.8 | 5.8 | 1.9 | 8 | 2.78 | 2.84 | --- | --- |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 146.4 | 10.7 | 10.4 | 1.1 | 77.4 | 3.92 | 2.67 | 4 | 4 |
| Notional | 6.5 | 11.3 | 0.7 | 0.7 | 87.1 | 2.78 | 4.63 | --- | --- |
| [ST] No Heating or Cooling | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Notional | 0 | 0 | 0 | 0 | 0 | 0 | 0 | --- | --- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

APPENDIX F – NON-DOMESTIC BRUKL REPORTS – PART L

2021 CLAUSE 10.11

BRUKL Output Document HM Government Compliance with England Building Regulations Part L 2021

Project name

Tavis House - Notional Extension As designed

Date: Wed Mar 20 12:04:08 2024

Administrative information

Building Details

Address:

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.25

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.25

BRUKL compliance module version: v6.1.e.1

Certifier details

Name:

Telephone number:

Address: , ,

Foundation area [m²]: 653

The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|---|-------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum | 10.78 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum | 10.75 |
| Target primary energy rate (TPER), kWh _u /m ² annum | 117.59 |
| Building primary energy rate (BPER), kWh _u /m ² annum | 115.99 |
| Do the building's emission and primary energy rates exceed the targets? | BER ≤ TER BPER ≤ TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _o -Limit | U _o -Calc | U _o -Calc | First surface with maximum value |
|---|-----------------------|----------------------|----------------------|--|
| Walls* | 0.26 | 1.32 | 1.7 | B1000000:Surf[3] |
| Floors | 0.18 | 0.41 | 0.45 | GF000003:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | 1.24 | 2.3 | B1000000:Surf[1] |
| Windows** and roof windows | 1.6 | 1.85 | 2 | FF00001B:Surf[3] |
| Rooflights*** | 2.2 | 1.4 | 1.4 | WN000000:Surf[16] |
| Personnel doors^ | 1.6 | 1.2 | 1.2 | CR000016:Surf[0] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |
| U _o -Limit = Limiting area-weighted average U-values [W/(m ² K)] U _o -Calc = Calculated area-weighted average U-values [W/(m ² K)] * Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows. ** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position. ^ For fire doors, limiting U-value is 1.8 W/m ² K NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool. | | | | |
| Air permeability | Limiting standard | This building | | |
| m ³ /(h.m ²) at 50 Pa | 8 | 22.1 | | |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|-------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | >0.95 |

1- HVAC-1

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | |
| YES | | | | | |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

2- HVAC-3

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | |
| YES | | | | | |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

3- HVAC-2

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | |
| YES | | | | | |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

4- HVAC-6

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | |
| YES | | | | | |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

5- HVAC-4

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|---|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 2.5 | 2 | - | - | - |
| Standard value | 2.5* | N/A | N/A | N/A | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | |
| YES | | | | | |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |

6- HVAC-1 (MM)

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

7- HVAC-5

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 2.8 | 3.65 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

1- DHW-1

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|----------------|--------------------------|---|
| This building | 1 | - |
| Standard value | 1 | N/A |

2- DHW-2

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|--|--------------------------|---|
| This building | 2.2 | - |
| Standard value | 2* | N/A |
| * Standard shown is for all types except absorption and gas engine heat pumps. | | |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|--|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |
| NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | |

| Zone name | SFP [W/(l/s)] | | | | | | | | | | HR efficiency | |
|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---|---------------|----------|
| ID of system type | A | B | C | D | E | F | G | H | I | | Zone | Standard |
| Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | | |
| WC_L0 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L0 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |

| Zone name | SFP [W/(l/s)] | | | | | | | | | | HR efficiency | |
|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---|---------------|----------|
| ID of system type | A | B | C | D | E | F | G | H | I | | Zone | Standard |
| Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | | |
| WC_L2 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L2 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L3 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L3 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L4 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L4 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L5 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L5 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L6 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L6 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L7 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L7 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_L8 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_L8 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc WC_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Acc Shower_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Drying Room_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| WC_B1 | - | - | 0.3 | - | - | - | - | - | - | - | - | N/A |
| Winter Garden_L8 | - | - | - | - | - | - | - | 0.3 | - | - | - | N/A |

| General lighting and display lighting | | General luminaire | Display light source | |
|---------------------------------------|--|-------------------|----------------------|----------------------|
| Zone name | | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m²] |
| Standard value | | 95 | 80 | 0.3 |
| Circulation_L0 | | 100 | - | - |
| Stairs_L0 | | 100 | - | - |
| Circulation_L0 | | 100 | - | - |
| Lobby_L0 | | 100 | - | - |
| WC_L0 | | 100 | - | - |
| Circulation_L0 | | 100 | - | - |
| Circulation_L0 | | 100 | - | - |
| Stairs_L0 | | 100 | - | - |
| Circulation_L0 | | 100 | - | - |
| Acc WC_L0 | | 100 | - | - |
| Stairs_L1 | | 100 | - | - |
| Circulation_L1 | | 100 | - | - |
| Lobby_L1 | | 100 | - | - |
| WC_L1 | | 100 | - | - |
| Circulation_L1 | | 100 | - | - |
| Circulation_L1 | | 100 | - | - |
| Stairs_L1 | | 100 | - | - |
| Acc WC_L1 | | 100 | - | - |
| Stairs_L2 | | 100 | - | - |

| General lighting and display lighting | | General luminaire | | Display light source | |
|---------------------------------------|----------------|-------------------|---|----------------------|----------------------|
| Zone name | | Efficacy [lm/W] | | Efficacy [lm/W] | Power density [W/m²] |
| | Standard value | 95 | | 80 | 0.3 |
| Circulation_L2 | 100 | - | - | - | - |
| Lobby_L2 | 100 | - | - | - | - |
| WC_L2 | 100 | - | - | - | - |
| Circulation_L2 | 100 | - | - | - | - |
| Circulation_L2 | 100 | - | - | - | - |
| Stairs_L2 | 100 | - | - | - | - |
| Acc WC_L2 | 100 | - | - | - | - |
| Lab (P)_L2 | 100 | - | - | - | - |
| Stairs_L3 | 100 | - | - | - | - |
| Circulation_L3 | 100 | - | - | - | - |
| Lobby_L3 | 100 | - | - | - | - |
| WC_L3 | 100 | - | - | - | - |
| Circulation_L3 | 100 | - | - | - | - |
| Circulation_L3 | 100 | - | - | - | - |
| Stairs_L3 | 100 | - | - | - | - |
| Acc WC_L3 | 100 | - | - | - | - |
| Lab (P)_L3 | 100 | - | - | - | - |
| Stairs_L4 | 100 | - | - | - | - |
| Circulation_L4 | 100 | - | - | - | - |
| Lobby_L4 | 100 | - | - | - | - |
| WC_L4 | 100 | - | - | - | - |
| Circulation_L4 | 100 | - | - | - | - |
| Circulation_L4 | 100 | - | - | - | - |
| Stairs_L4 | 100 | - | - | - | - |
| Acc WC_L4 | 100 | - | - | - | - |
| Lab (P)_L4 | 100 | - | - | - | - |
| Stairs_L5 | 100 | - | - | - | - |
| Circulation_L5 | 100 | - | - | - | - |
| Lobby_L5 | 100 | - | - | - | - |
| WC_L5 | 100 | - | - | - | - |
| Circulation_L5 | 100 | - | - | - | - |
| Circulation_L5 | 100 | - | - | - | - |
| Stairs_L5 | 100 | - | - | - | - |
| Acc WC_L5 | 100 | - | - | - | - |
| Lab (P)_L5 | 100 | - | - | - | - |
| Stairs_L6 | 100 | - | - | - | - |
| Circulation_L6 | 100 | - | - | - | - |
| Lobby_L6 | 100 | - | - | - | - |
| WC_L6 | 100 | - | - | - | - |
| Circulation_L6 | 100 | - | - | - | - |
| Circulation_L6 | 100 | - | - | - | - |
| Stairs_L6 | 100 | - | - | - | - |
| Acc WC_L6 | 100 | - | - | - | - |

| General lighting and display lighting | | General luminaire | | Display light source | |
|---------------------------------------|----------------|-------------------|---|----------------------|----------------------|
| Zone name | | Efficacy [lm/W] | | Efficacy [lm/W] | Power density [W/m²] |
| | Standard value | 95 | | 80 | 0.3 |
| Lab (P)_L6 | 100 | - | - | - | - |
| Stairs_L7 | 100 | - | - | - | - |
| Circulation_L7 | 100 | - | - | - | - |
| Lobby_L7 | 100 | - | - | - | - |
| WC_L7 | 100 | - | - | - | - |
| Circulation_L7 | 100 | - | - | - | - |
| Circulation_L7 | 100 | - | - | - | - |
| Stairs_L7 | 100 | - | - | - | - |
| Acc WC_L7 | 100 | - | - | - | - |
| Lab (P)_L7 | 100 | - | - | - | - |
| Lobby_L8 | 100 | - | - | - | - |
| WC_L8 | 100 | - | - | - | - |
| Circulation_L8 | 100 | - | - | - | - |
| Circulation_L8 | 100 | - | - | - | - |
| Stairs_L8 | 100 | - | - | - | - |
| Acc WC_L8 | 100 | - | - | - | - |
| Circulation_L8 | 100 | - | - | - | - |
| Stairs_L8 | 100 | - | - | - | - |
| Stairs_L8 | 100 | - | - | - | - |
| Plant_L8 | 100 | - | - | - | - |
| Plant_B1 | 100 | - | - | - | - |
| Circulation_B1 | 100 | - | - | - | - |
| Goods In Store_B1 | 100 | - | - | - | - |
| Lobby_B1 | 100 | - | - | - | - |
| Acc WC_B1 | 100 | - | - | - | - |
| Circulation_B1 | 100 | - | - | - | - |
| Stairs_B1 | 100 | - | - | - | - |
| Comms Room_B1 | 100 | - | - | - | - |
| Lab Support_B1 | 100 | - | - | - | - |
| Plant_B1 | 100 | - | - | - | - |
| Changing_B1 | 100 | - | - | - | - |
| WC_B1 | 100 | - | - | - | - |
| Acc Shower_B1 | 100 | - | - | - | - |
| Drying Room_B1 | 100 | - | - | - | - |
| WC_B1 | 100 | - | - | - | - |
| Changing_B1 | 100 | - | - | - | - |
| Post Room_B1 | 100 | - | - | - | - |
| Circulation_B1 | 100 | - | - | - | - |
| Cycle Store_B1 | 100 | - | - | - | - |
| Switch Room_B1 | 100 | - | - | - | - |
| Plant_B1 | 100 | - | - | - | - |
| Goods Office_L0 | 100 | - | - | - | - |
| Office (P)_L0 | 100 | - | - | - | - |

| General lighting and display lighting | | Display light source | |
|---------------------------------------|-------------------|----------------------|----------------------|
| Zone name | General luminaire | Efficacy [lm/W] | Power density [W/m²] |
| | Standard value | 95 | 0.3 |
| Lab (P)_L1 | 100 | - | - |
| Office_L7 | 100 | - | - |
| Lab_L7 | 100 | - | - |
| Lab_L0 | 100 | - | - |
| Office (P)_L0 | 100 | - | - |
| Office (P)_L0 | 100 | - | - |
| Reception (P)_L0 | 100 | 80 | 1.688 |
| Office_L0 | 100 | - | - |
| Reception_L0 | 100 | 80 | 1.687 |
| Office_L0 | 100 | - | - |
| Lab_L1 | 100 | - | - |
| Lab_L1 | 100 | - | - |
| Office_L1 | 100 | - | - |
| Office (P)_L1 | 100 | - | - |
| Lab_L2 | 100 | - | - |
| Lab_L2 | 100 | - | - |
| Office_L2 | 100 | - | - |
| Lab_L3 | 100 | - | - |
| Lab_L3 | 100 | - | - |
| Office_L3 | 100 | - | - |
| Lab_L4 | 100 | - | - |
| Lab_L4 | 100 | - | - |
| Office_L4 | 100 | - | - |
| Lab_L5 | 100 | - | - |
| Lab_L5 | 100 | - | - |
| Office_L5 | 100 | - | - |
| Lab_L6 | 100 | - | - |
| Lab_L6 | 100 | - | - |
| Office_L6 | 100 | - | - |
| Lab(P)_L6 | 100 | - | - |
| Office(P)_L6 | 100 | - | - |
| Bin Store_L0 | 100 | - | - |
| Lab (P)_L0 | 100 | - | - |
| Lab (P)_L1 | 100 | - | - |
| Office(P)_L2 | 100 | - | - |
| Lab(P)_L2 | 100 | - | - |
| Office(P)_L3 | 100 | - | - |
| Lab(P)_L3 | 100 | - | - |
| Office(P)_L4 | 100 | - | - |
| Lab(P)_L4 | 100 | - | - |
| Office(P)_L5 | 100 | - | - |
| Lab(P)_L5 | 100 | - | - |
| Office(P)_L7 | 100 | - | - |

| General lighting and display lighting | | Display light source | |
|---------------------------------------|-------------------|----------------------|----------------------|
| Zone name | General luminaire | Efficacy [lm/W] | Power density [W/m²] |
| | Standard value | 95 | 0.3 |
| Lab(P)_L7 | 100 | - | - |
| Store_L8 | 100 | - | - |
| Office(P)_L8 | 100 | - | - |
| Winter Garden_L8 | 100 | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|----------------|--------------------------------|-----------------------|
| Circulation_L0 | NO (-79.9%) | NO |
| Stairs_L0 | N/A | N/A |
| Circulation_L0 | N/A | N/A |
| Lobby_L0 | N/A | N/A |
| WC_L0 | N/A | N/A |
| Circulation_L0 | N/A | N/A |
| Circulation_L0 | NO (-100%) | NO |
| Stairs_L0 | N/A | N/A |
| Circulation_L0 | NO (-85.6%) | NO |
| Acc WC_L0 | N/A | N/A |
| Stairs_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Lobby_L1 | N/A | N/A |
| WC_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Stairs_L1 | NO (-100%) | NO |
| Acc WC_L1 | N/A | N/A |
| Stairs_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Lobby_L2 | N/A | N/A |
| WC_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Stairs_L2 | N/A | N/A |
| Acc WC_L2 | N/A | N/A |
| Lab (P)_L2 | NO (-54.4%) | NO |
| Stairs_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Lobby_L3 | N/A | N/A |
| WC_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Stairs_L3 | N/A | N/A |
| Acc WC_L3 | N/A | N/A |
| Lab (P)_L3 | NO (-48.2%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|----------------|--------------------------------|-----------------------|
| Stairs_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Lobby_L4 | N/A | N/A |
| WC_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Stairs_L4 | N/A | N/A |
| Acc WC_L4 | N/A | N/A |
| Lab (P)_L4 | NO (-47.2%) | NO |
| Stairs_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Lobby_L5 | N/A | N/A |
| WC_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Stairs_L5 | N/A | N/A |
| Acc WC_L5 | N/A | N/A |
| Lab (P)_L5 | NO (-46.5%) | NO |
| Stairs_L6 | N/A | N/A |
| Circulation_L6 | N/A | N/A |
| Lobby_L6 | N/A | N/A |
| WC_L6 | N/A | N/A |
| Circulation_L6 | N/A | N/A |
| Circulation_L6 | N/A | N/A |
| Stairs_L6 | N/A | N/A |
| Acc WC_L6 | N/A | N/A |
| Lab (P)_L6 | NO (-45.3%) | NO |
| Stairs_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Lobby_L7 | N/A | N/A |
| WC_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Stairs_L7 | N/A | N/A |
| Acc WC_L7 | N/A | N/A |
| Lab (P)_L7 | NO (-35.4%) | NO |
| Lobby_L8 | N/A | N/A |
| WC_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Acc WC_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Circulation_B1 | N/A | N/A |
| Lobby_B1 | N/A | N/A |
| Acc WC_B1 | N/A | N/A |
| Circulation_B1 | NO (-100%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|------------------|--------------------------------|-----------------------|
| Stairs_B1 | N/A | N/A |
| Comms Room_B1 | N/A | N/A |
| Lab Support_B1 | N/A | N/A |
| Changing_B1 | NO (-100%) | NO |
| WC_B1 | NO (-99.8%) | NO |
| Acc Shower_B1 | N/A | N/A |
| Drying Room_B1 | NO (-100%) | NO |
| WC_B1 | N/A | N/A |
| Changing_B1 | N/A | N/A |
| Circulation_B1 | NO (-100%) | NO |
| Cycle Store_B1 | N/A | N/A |
| Goods Office_L0 | NO (-81%) | NO |
| Office (P)_L0 | NO (-56.8%) | NO |
| Lab (P)_L1 | NO (-53%) | NO |
| Office_L7 | NO (-67.7%) | NO |
| Lab_L7 | NO (-30.2%) | NO |
| Lab_L0 | NO (-59.6%) | NO |
| Office (P)_L0 | YES (+54%) | NO |
| Office (P)_L0 | YES (+22.4%) | NO |
| Reception (P)_L0 | YES (+130.9%) | NO |
| Office_L0 | NO (-35.3%) | NO |
| Reception_L0 | YES (+134.5%) | NO |
| Office_L0 | YES (+77.9%) | NO |
| Lab_L1 | NO (-89.8%) | NO |
| Lab_L1 | NO (-57.5%) | NO |
| Office_L1 | YES (+27%) | NO |
| Office (P)_L1 | YES (+28.5%) | NO |
| Lab_L2 | NO (-89.3%) | NO |
| Lab_L2 | NO (-63.6%) | NO |
| Office_L2 | YES (+79.3%) | NO |
| Lab_L3 | NO (-86.8%) | NO |
| Lab_L3 | NO (-59.7%) | NO |
| Office_L3 | YES (+63.5%) | NO |
| Lab_L4 | NO (-86.4%) | NO |
| Lab_L4 | NO (-57.3%) | NO |
| Office_L4 | YES (+63.9%) | NO |
| Lab_L5 | NO (-86.2%) | NO |
| Lab_L5 | NO (-55.9%) | NO |
| Office_L5 | YES (+64.9%) | NO |
| Lab_L6 | NO (-86%) | NO |
| Lab_L6 | NO (-52.1%) | NO |
| Office_L6 | YES (+50.3%) | NO |
| Lab(P)_L6 | YES (+80.6%) | NO |
| Office(P)_L6 | YES (+4%) | NO |
| Lab (P)_L0 | YES (+33.1%) | NO |
| Lab (P)_L1 | YES (+61.1%) | NO |
| Office(P)_L2 | YES (+32.4%) | NO |
| Lab(P)_L2 | YES (+37.6%) | NO |
| Office(P)_L3 | YES (+19%) | NO |

| | |
|--|----|
| Were alternative energy systems considered and analysed as part of the design process? | NO |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | NO |

| Building Global Parameters | | | Building Use | |
|---|---------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 7604.5 | 7604.5 | | Retail/Financial and Professional Services |
| External area [m ²] | 5918 | 5918 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | 52 | Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 22 | 4 | 48 | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 7549.75 | 1973.44 | | Storage or Distribution |
| Average U-value [W/m ² K] | 1.28 | 0.33 | | Hotels |
| Alpha value* [%] | 25.05 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

| | Actual | Notional |
|-----------------|-------------|--------------|
| Heating | 10.29 | 1.02 |
| Cooling | 1.42 | 1.83 |
| Auxiliary | 40.48 | 45.78 |
| Lighting | 17.59 | 24.32 |
| Hot water | 9.11 | 6.79 |
| Equipment* | 38.18 | 38.18 |
| TOTAL ** | 78.9 | 79.74 |

| | Actual | Notional |
|------------------------------|------------|----------|
| Photovoltaic systems | 0.7 | 0 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| <i>Displaced electricity</i> | <i>0.7</i> | <i>0</i> |

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 152.97 | 35.62 |
| Primary energy [kWh _{tp} /m ²] | 115.99 | 117.59 |
| Total emissions [kg/m ²] | 10.75 | 10.78 |

| HVAC Systems Performance | | | | | | | | | |
|--|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 104.4 | 40.9 | 7.4 | 4.3 | 4.6 | 3.92 | 2.67 | 4 | 4 |
| Notional | 12.9 | 72 | 1.3 | 4.3 | 7.7 | 2.78 | 4.63 | — | — |
| [ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 211.8 | 2.4 | 16.5 | 0.3 | 33.1 | 3.57 | 2.31 | 4 | 4 |
| Notional | 6.9 | 37.5 | 0.7 | 2.3 | 17.1 | 2.78 | 4.63 | — | — |
| [ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 138.1 | 7.1 | 10.8 | 0.9 | 18.5 | 3.57 | 2.31 | 4 | 4 |
| Notional | 8.8 | 39.1 | 0.9 | 2.3 | 7.5 | 2.78 | 4.63 | — | — |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 190.1 | 12.2 | 13.5 | 1.3 | 2.3 | 3.92 | 2.67 | 4 | 4 |
| Notional | 12.5 | 32.2 | 1.3 | 3.1 | 8.2 | 2.78 | 2.84 | — | — |
| [ST] Single room cooling system, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 2.45 | 1.49 | 2.5 | 2 |
| Notional | 0 | 0 | 0 | 0 | 0 | 2.78 | 4.63 | — | — |
| [ST] Fan coil systems, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 524.6 | 49.5 | 57.9 | 4.8 | 18.6 | 2.52 | 2.86 | 2.8 | 3.65 |
| Notional | 58.9 | 19.4 | 5.9 | 1.9 | 11.1 | 2.78 | 2.84 | — | — |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 121.9 | 9 | 8.6 | 0.9 | 77.4 | 3.92 | 2.67 | 4 | 4 |
| Notional | 8.3 | 10.6 | 0.8 | 0.6 | 87.1 | 2.78 | 4.63 | — | — |
| [ST] No Heating or Cooling | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Notional | 0 | 0 | 0 | 0 | 0 | 0 | 0 | — | — |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

BRUKL Output Document



Compliance with England Building Regulations Part L 2021

Project name

Tavis House - Be Green

As designed

Date: Wed Mar 20 14:13:10 2024

Administrative information

Building Details

Address:

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.25

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.25

BRUKL compliance module version: v8.1.e.1

Certifier details

Name:

Telephone number:

Address: , ,

Foundation area [m²]: 653

The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|---------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m²annum | 10.78 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m²annum | 10.68 |
| Target primary energy rate (TPER), kWh _{eq} /m²annum | 117.59 |
| Building primary energy rate (BPER), kWh _{eq} /m²annum | 115.2 |
| Do the building's emission and primary energy rates exceed the targets? | BER =< TER BPER =< TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _{o-Limit} | U _{o-Calc} | U _{o-Calc} | First surface with maximum value |
|--------------------------------------|----------------------|---------------------|---------------------|--|
| Walls* | 0.26 | 1.3 | 1.7 | B1000000:Surf[3] |
| Floors | 0.18 | 0.4 | 0.45 | GF000003:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | 1.23 | 2.3 | B1000000:Surf[1] |
| Windows** and roof windows | 1.6 | 1.72 | 2 | FF00001B:Surf[3] |
| Rooflights*** | 2.2 | 1.4 | 1.4 | WN000000:Surf[16] |
| Personnel doors [^] | 1.6 | 1.2 | 1.2 | CR000016:Surf[0] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_{o-Limit} = Limiting area-weighted average U-values [W/(m²K)]
U_{o-Calc} = Calculated area-weighted average U-values [W/(m²K)]
* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.
** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.
[^] For fire doors, limiting U-value is 1.8 W/m²K.
NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--------------------|-------------------|---------------|
| m³/(h.m²) at 50 Pa | 8 | 21.25 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|-------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | >0.95 |

1- HVAC-1

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

2- HVAC-3

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

3- HVAC-2

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

4- HVAC-6

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

5- HVAC-4

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|---|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 2.5 | 2 | - | - | - |
| Standard value | 2.5* | N/A | N/A | N/A | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |

6- HVAC-1 (MM)

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4 | 4 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

7- HVAC-5

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 2.8 | 3.65 | 0 | 1.6 | 0.75 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

1- DHW-1

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|----------------|--------------------------|---|
| This building | 1 | - |
| Standard value | 1 | N/A |

2- DHW-2

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|--|--------------------------|---|
| This building | 2.2 | - |
| Standard value | 2* | N/A |
| * Standard shown is for all types except absorption and gas engine heat pumps. | | |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|--|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |
| NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | |

| Zone name | SFP [W/(l/s)] | | | | | | | | | HR efficiency | |
|-------------------|---------------|---|-----|---|---|---|---|---|---|---------------|----------|
| ID of system type | A | B | C | D | E | F | G | H | I | Zone | Standard |
| WC_L0 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Acc WC_L0 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| WC_L1 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Acc WC_L1 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |

| Zone name | SFP [W/(l/s)] | | | | | | | | | HR efficiency | |
|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---------------|----------|
| ID of system type | A | B | C | D | E | F | G | H | I | | |
| Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | Zone | Standard |
| WC_L2 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Acc WC_L2 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| WC_L3 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Acc WC_L3 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| WC_L4 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Acc WC_L4 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| WC_L5 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Acc WC_L5 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| WC_L6 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Acc WC_L6 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| WC_L7 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Acc WC_L7 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| WC_L8 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Acc WC_L8 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Acc WC_B1 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| WC_B1 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Acc Shower_B1 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Drying Room_B1 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| WC_B1 | - | - | 0.3 | - | - | - | - | - | - | - | N/A |
| Winter Garden_L8 | - | - | - | - | - | - | - | 0.3 | - | - | N/A |

| General lighting and display lighting | | General luminaire | | Display light source | |
|---------------------------------------|----------------|-------------------|--|----------------------|----------------------|
| Zone name | | Efficacy [lm/W] | | Efficacy [lm/W] | Power density [W/m²] |
| | Standard value | 95 | | 80 | 0.3 |
| Circulation_L0 | | 100 | | - | - |
| Stairs_L0 | | 100 | | - | - |
| Circulation_L0 | | 100 | | - | - |
| Lobby_L0 | | 100 | | - | - |
| WC_L0 | | 100 | | - | - |
| Circulation_L0 | | 100 | | - | - |
| Circulation_L0 | | 100 | | - | - |
| Stairs_L0 | | 100 | | - | - |
| Circulation_L0 | | 100 | | - | - |
| Acc WC_L0 | | 100 | | - | - |
| Stairs_L1 | | 100 | | - | - |
| Circulation_L1 | | 100 | | - | - |
| Lobby_L1 | | 100 | | - | - |
| WC_L1 | | 100 | | - | - |
| Circulation_L1 | | 100 | | - | - |
| Circulation_L1 | | 100 | | - | - |
| Stairs_L1 | | 100 | | - | - |
| Acc WC_L1 | | 100 | | - | - |
| Stairs_L2 | | 100 | | - | - |

| General lighting and display lighting | | General luminaire | | Display light source | |
|---------------------------------------|----------------|-------------------|--|----------------------|----------------------|
| Zone name | | Efficacy [lm/W] | | Efficacy [lm/W] | Power density [W/m²] |
| | Standard value | 95 | | 80 | 0.3 |
| Circulation_L2 | | 100 | | - | - |
| Lobby_L2 | | 100 | | - | - |
| WC_L2 | | 100 | | - | - |
| Circulation_L2 | | 100 | | - | - |
| Circulation_L2 | | 100 | | - | - |
| Stairs_L2 | | 100 | | - | - |
| Acc WC_L2 | | 100 | | - | - |
| Lab (P)_L2 | | 100 | | - | - |
| Stairs_L3 | | 100 | | - | - |
| Circulation_L3 | | 100 | | - | - |
| Lobby_L3 | | 100 | | - | - |
| WC_L3 | | 100 | | - | - |
| Circulation_L3 | | 100 | | - | - |
| Circulation_L3 | | 100 | | - | - |
| Stairs_L3 | | 100 | | - | - |
| Acc WC_L3 | | 100 | | - | - |
| Lab (P)_L3 | | 100 | | - | - |
| Stairs_L4 | | 100 | | - | - |
| Circulation_L4 | | 100 | | - | - |
| Lobby_L4 | | 100 | | - | - |
| WC_L4 | | 100 | | - | - |
| Circulation_L4 | | 100 | | - | - |
| Circulation_L4 | | 100 | | - | - |
| Stairs_L4 | | 100 | | - | - |
| Acc WC_L4 | | 100 | | - | - |
| Lab (P)_L4 | | 100 | | - | - |
| Stairs_L5 | | 100 | | - | - |
| Circulation_L5 | | 100 | | - | - |
| Lobby_L5 | | 100 | | - | - |
| WC_L5 | | 100 | | - | - |
| Circulation_L5 | | 100 | | - | - |
| Circulation_L5 | | 100 | | - | - |
| Stairs_L5 | | 100 | | - | - |
| Acc WC_L5 | | 100 | | - | - |
| Lab (P)_L5 | | 100 | | - | - |
| Stairs_L6 | | 100 | | - | - |
| Circulation_L6 | | 100 | | - | - |
| Lobby_L6 | | 100 | | - | - |
| WC_L6 | | 100 | | - | - |
| Circulation_L6 | | 100 | | - | - |
| Circulation_L6 | | 100 | | - | - |
| Stairs_L6 | | 100 | | - | - |
| Acc WC_L6 | | 100 | | - | - |

| General lighting and display lighting | | General luminaire | | Display light source | |
|---------------------------------------|----------------|-------------------|-----------------|----------------------|--|
| Zone name | | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m²] | |
| | Standard value | 95 | 80 | 0.3 | |
| Lab (P)_L6 | 100 | - | - | - | |
| Stairs_L7 | 100 | - | - | - | |
| Circulation_L7 | 100 | - | - | - | |
| Lobby_L7 | 100 | - | - | - | |
| WC_L7 | 100 | - | - | - | |
| Circulation_L7 | 100 | - | - | - | |
| Circulation_L7 | 100 | - | - | - | |
| Stairs_L7 | 100 | - | - | - | |
| Acc WC_L7 | 100 | - | - | - | |
| Lab (P)_L7 | 100 | - | - | - | |
| Lobby_L8 | 100 | - | - | - | |
| WC_L8 | 100 | - | - | - | |
| Circulation_L8 | 100 | - | - | - | |
| Circulation_L8 | 100 | - | - | - | |
| Stairs_L8 | 100 | - | - | - | |
| Acc WC_L8 | 100 | - | - | - | |
| Circulation_L8 | 100 | - | - | - | |
| Stairs_L8 | 100 | - | - | - | |
| Stairs_L8 | 100 | - | - | - | |
| Plant_L8 | 100 | - | - | - | |
| Plant_B1 | 100 | - | - | - | |
| Circulation_B1 | 100 | - | - | - | |
| Goods In Store_B1 | 100 | - | - | - | |
| Lobby_B1 | 100 | - | - | - | |
| Acc WC_B1 | 100 | - | - | - | |
| Circulation_B1 | 100 | - | - | - | |
| Stairs_B1 | 100 | - | - | - | |
| Comms Room_B1 | 100 | - | - | - | |
| Lab Support_B1 | 100 | - | - | - | |
| Plant_B1 | 100 | - | - | - | |
| Changing_B1 | 100 | - | - | - | |
| WC_B1 | 100 | - | - | - | |
| Acc Shower_B1 | 100 | - | - | - | |
| Drying Room_B1 | 100 | - | - | - | |
| WC_B1 | 100 | - | - | - | |
| Changing_B1 | 100 | - | - | - | |
| Post Room_B1 | 100 | - | - | - | |
| Circulation_B1 | 100 | - | - | - | |
| Cycle Store_B1 | 100 | - | - | - | |
| Switch Room_B1 | 100 | - | - | - | |
| Plant_B1 | 100 | - | - | - | |
| Goods Office_L0 | 100 | - | - | - | |
| Office (P)_L0 | 100 | - | - | - | |

| General lighting and display lighting | | General luminaire | | Display light source | |
|---------------------------------------|----------------|-------------------|-----------------|----------------------|--|
| Zone name | | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m²] | |
| | Standard value | 95 | 80 | 0.3 | |
| Lab (P)_L1 | 100 | - | - | - | |
| Office_L7 | 100 | - | - | - | |
| Lab_L7 | 100 | - | - | - | |
| Lab_L0 | 100 | - | - | - | |
| Office (P)_L0 | 100 | - | - | - | |
| Office (P)_L0 | 100 | - | - | - | |
| Reception (P)_L0 | 100 | 80 | 1.688 | | |
| Office_L0 | 100 | - | - | - | |
| Reception_L0 | 100 | 80 | 1.687 | | |
| Office_L0 | 100 | - | - | - | |
| Lab_L1 | 100 | - | - | - | |
| Lab_L1 | 100 | - | - | - | |
| Office_L1 | 100 | - | - | - | |
| Office (P)_L1 | 100 | - | - | - | |
| Lab_L2 | 100 | - | - | - | |
| Lab_L2 | 100 | - | - | - | |
| Office_L2 | 100 | - | - | - | |
| Lab_L3 | 100 | - | - | - | |
| Lab_L3 | 100 | - | - | - | |
| Office_L3 | 100 | - | - | - | |
| Lab_L4 | 100 | - | - | - | |
| Lab_L4 | 100 | - | - | - | |
| Office_L4 | 100 | - | - | - | |
| Lab_L5 | 100 | - | - | - | |
| Lab_L5 | 100 | - | - | - | |
| Office_L5 | 100 | - | - | - | |
| Lab_L6 | 100 | - | - | - | |
| Lab_L6 | 100 | - | - | - | |
| Office_L6 | 100 | - | - | - | |
| Lab(P)_L6 | 100 | - | - | - | |
| Office(P)_L6 | 100 | - | - | - | |
| Bin Store_L0 | 100 | - | - | - | |
| Lab (P)_L0 | 100 | - | - | - | |
| Lab (P)_L1 | 100 | - | - | - | |
| Office(P)_L2 | 100 | - | - | - | |
| Lab(P)_L2 | 100 | - | - | - | |
| Office(P)_L3 | 100 | - | - | - | |
| Lab(P)_L3 | 100 | - | - | - | |
| Office(P)_L4 | 100 | - | - | - | |
| Lab(P)_L4 | 100 | - | - | - | |
| Office(P)_L5 | 100 | - | - | - | |
| Lab(P)_L5 | 100 | - | - | - | |
| Office(P)_L7 | 100 | - | - | - | |

| General lighting and display lighting | | Display light source | |
|---------------------------------------|-------------------|----------------------|----------------------|
| Zone name | General luminaire | Efficacy [lm/W] | Power density [W/m²] |
| | Standard value | 95 | 80 |
| Lab(P)_L7 | 100 | - | - |
| Store_L8 | 100 | - | - |
| Office(P)_L8 | 100 | - | - |
| Winter Garden_L8 | 100 | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|----------------|--------------------------------|-----------------------|
| Circulation_L0 | NO (-48%) | NO |
| Stairs_L0 | NO (-100%) | NO |
| Circulation_L0 | N/A | N/A |
| Lobby_L0 | N/A | N/A |
| WC_L0 | N/A | N/A |
| Circulation_L0 | N/A | N/A |
| Circulation_L0 | NO (-100%) | NO |
| Stairs_L0 | N/A | N/A |
| Circulation_L0 | NO (-74%) | NO |
| Acc WC_L0 | N/A | N/A |
| Stairs_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Lobby_L1 | N/A | N/A |
| WC_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Circulation_L1 | N/A | N/A |
| Stairs_L1 | NO (-100%) | NO |
| Acc WC_L1 | N/A | N/A |
| Stairs_L2 | NO (-99.1%) | NO |
| Circulation_L2 | N/A | N/A |
| Lobby_L2 | N/A | N/A |
| WC_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Circulation_L2 | N/A | N/A |
| Stairs_L2 | N/A | N/A |
| Acc WC_L2 | N/A | N/A |
| Lab (P)_L2 | NO (-33.3%) | NO |
| Stairs_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Lobby_L3 | N/A | N/A |
| WC_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Circulation_L3 | N/A | N/A |
| Stairs_L3 | N/A | N/A |
| Acc WC_L3 | N/A | N/A |
| Lab (P)_L3 | NO (-24.9%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|----------------|--------------------------------|-----------------------|
| Stairs_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Lobby_L4 | N/A | N/A |
| WC_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Circulation_L4 | N/A | N/A |
| Stairs_L4 | N/A | N/A |
| Acc WC_L4 | N/A | N/A |
| Lab (P)_L4 | NO (-15.4%) | NO |
| Stairs_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Lobby_L5 | N/A | N/A |
| WC_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Circulation_L5 | N/A | N/A |
| Stairs_L5 | N/A | N/A |
| Acc WC_L5 | N/A | N/A |
| Lab (P)_L5 | NO (-14.5%) | NO |
| Stairs_L6 | N/A | N/A |
| Circulation_L6 | N/A | N/A |
| Lobby_L6 | N/A | N/A |
| WC_L6 | N/A | N/A |
| Circulation_L6 | N/A | N/A |
| Circulation_L6 | N/A | N/A |
| Stairs_L6 | N/A | N/A |
| Acc WC_L6 | N/A | N/A |
| Lab (P)_L6 | NO (-12.7%) | NO |
| Stairs_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Lobby_L7 | N/A | N/A |
| WC_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Circulation_L7 | N/A | N/A |
| Stairs_L7 | N/A | N/A |
| Acc WC_L7 | N/A | N/A |
| Lab (P)_L7 | YES (+1.5%) | NO |
| Lobby_L8 | N/A | N/A |
| WC_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Acc WC_L8 | N/A | N/A |
| Circulation_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Stairs_L8 | N/A | N/A |
| Circulation_B1 | N/A | N/A |
| Lobby_B1 | N/A | N/A |
| Acc WC_B1 | N/A | N/A |
| Circulation_B1 | NO (-100%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|------------------|--------------------------------|-----------------------|
| Stairs_B1 | N/A | N/A |
| Comms Room_B1 | N/A | N/A |
| Lab Support_B1 | N/A | N/A |
| Changing_B1 | NO (-100%) | NO |
| WC_B1 | NO (-99.8%) | NO |
| Acc Shower_B1 | N/A | N/A |
| Drying Room_B1 | NO (-100%) | NO |
| WC_B1 | N/A | N/A |
| Changing_B1 | N/A | N/A |
| Circulation_B1 | NO (-100%) | NO |
| Cycle Store_B1 | N/A | N/A |
| Goods Office_L0 | NO (-34%) | NO |
| Office (P)_L0 | NO (-56.8%) | NO |
| Lab (P)_L1 | NO (-38.5%) | NO |
| Office_L7 | NO (-67.7%) | NO |
| Lab_L7 | NO (-27.3%) | NO |
| Lab_L0 | NO (-59.6%) | NO |
| Office (P)_L0 | YES (+54%) | NO |
| Office (P)_L0 | YES (+22.4%) | NO |
| Reception (P)_L0 | YES (+130.9%) | NO |
| Office_L0 | NO (-35.3%) | NO |
| Reception_L0 | YES (+134.5%) | NO |
| Office_L0 | YES (+77.9%) | NO |
| Lab_L1 | NO (-84.5%) | NO |
| Lab_L1 | NO (-55.9%) | NO |
| Office_L1 | YES (+27%) | NO |
| Office (P)_L1 | YES (+28.5%) | NO |
| Lab_L2 | NO (-82.1%) | NO |
| Lab_L2 | NO (-61.8%) | NO |
| Office_L2 | YES (+79.3%) | NO |
| Lab_L3 | NO (-78.1%) | NO |
| Lab_L3 | NO (-57.6%) | NO |
| Office_L3 | YES (+63.5%) | NO |
| Lab_L4 | NO (-75.1%) | NO |
| Lab_L4 | NO (-54.6%) | NO |
| Office_L4 | YES (+63.9%) | NO |
| Lab_L5 | NO (-74.9%) | NO |
| Lab_L5 | NO (-53.2%) | NO |
| Office_L5 | YES (+64.9%) | NO |
| Lab_L6 | NO (-74.5%) | NO |
| Lab_L6 | NO (-49.3%) | NO |
| Office_L6 | YES (+50.3%) | NO |
| Lab(P)_L6 | YES (+81.2%) | NO |
| Office(P)_L6 | YES (+4%) | NO |
| Lab (P)_L0 | YES (+33.1%) | NO |
| Lab (P)_L1 | YES (+61.4%) | NO |
| Office(P)_L2 | YES (+32.4%) | NO |
| Lab(P)_L2 | YES (+38%) | NO |
| Office(P)_L3 | YES (+19%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|------------------|--------------------------------|-----------------------|
| Lab(P)_L3 | YES (+51%) | NO |
| Office(P)_L4 | YES (+18.2%) | NO |
| Lab(P)_L4 | YES (+59.9%) | NO |
| Office(P)_L5 | YES (+18.7%) | NO |
| Lab(P)_L5 | YES (+66.5%) | NO |
| Office(P)_L7 | YES (+26.8%) | NO |
| Lab(P)_L7 | YES (+85.4%) | NO |
| Office(P)_L8 | YES (+22.4%) | NO |
| Winter Garden_L8 | YES (+123%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|----|
| Were alternative energy systems considered and analysed as part of the design process? | NO |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | NO |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|---------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 7604.5 | 7604.5 | | Retail/Financial and Professional Services |
| External area [m ²] | 5918 | 5918 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | 52 | Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 21 | 4 | 48 | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 7312.18 | 1973.44 | | Storage or Distribution |
| Average U-value [W/m ² K] | 1.24 | 0.33 | | Hotels |
| Alpha value* [%] | 25.03 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|------------|--------|----------|
| Heating | 9.83 | 1.02 |
| Cooling | 1.49 | 1.83 |
| Auxiliary | 40.49 | 45.78 |
| Lighting | 17.47 | 24.32 |
| Hot water | 9.11 | 6.79 |
| Equipment* | 38.18 | 38.18 |
| TOTAL** | 78.39 | 79.74 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
 ** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems | 0.7 | 0 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| Displaced electricity | 0.7 | 0 |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 147.13 | 35.62 |
| Primary energy [kWh _{pe} /m ²] | 115.2 | 117.59 |
| Total emissions [kg/m ²] | 10.68 | 10.78 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|--|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 100.8 | 43.4 | 7.1 | 4.5 | 4.6 | 3.92 | 2.67 | 4 | 4 |
| Notional | 12.9 | 72 | 1.3 | 4.3 | 7.7 | 2.78 | 4.63 | — | — |
| [ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 210 | 2.5 | 16.4 | 0.3 | 33 | 3.57 | 2.31 | 4 | 4 |
| Notional | 6.9 | 37.5 | 0.7 | 2.3 | 17.1 | 2.78 | 4.63 | — | — |
| [ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 134.3 | 8.1 | 10.5 | 1 | 18.7 | 3.57 | 2.31 | 4 | 4 |
| Notional | 8.8 | 39.1 | 0.9 | 2.3 | 7.5 | 2.78 | 4.63 | — | — |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 188.3 | 12.5 | 13.3 | 1.3 | 2.3 | 3.92 | 2.67 | 4 | 4 |
| Notional | 12.5 | 32.2 | 1.3 | 3.1 | 8.2 | 2.78 | 2.84 | — | — |
| [ST] Single room cooling system, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 2.45 | 1.49 | 2.5 | 2 |
| Notional | 0 | 0 | 0 | 0 | 0 | 2.78 | 4.63 | — | — |
| [ST] Fan coil systems, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 522.9 | 49.7 | 57.7 | 4.8 | 18.6 | 2.52 | 2.86 | 2.8 | 3.65 |
| Notional | 58.9 | 19.4 | 5.9 | 1.9 | 11.1 | 2.78 | 2.84 | — | — |
| [ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 110.8 | 9.4 | 7.9 | 1 | 77.4 | 3.92 | 2.67 | 4 | 4 |
| Notional | 8.3 | 10.6 | 0.8 | 0.6 | 87.1 | 2.78 | 4.63 | — | — |
| [ST] No Heating or Cooling | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Notional | 0 | 0 | 0 | 0 | 0 | 0 | 0 | — | — |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

TWINEARTH



t: + 44 (0)203 713 9538
e: info@twinearth.co.uk
w: twinearth.co.uk

