



SPECIFICATION

- Type: ESD100 - 100mm Deep Acoustic Panel
- Outercasing: Pre-galvanised Steel Sheet.
- Inner Skin: 0.7mm Expanded pre-galvanised steel skin having minimum 30% free area.
- Acoustic Infill: 45kg/m³ density mineral wool retained behind glass fibre tissue facing.
- Finish: Painted to RAL7035.
- Door Furniture: Europrofile Cylinder 100mm (50/50), Strike Plate, Stainless Steel 1 1/2 Pairs of Hinges, Euro Profile, 44mm Backset, Deadlock, D handles

NOTE: FOR DETAILS SEE CS8664-107.

A Updated inline with architect comments. 25/09/2023

Rev Amendment Date

First Angle Projection unless stated
Scale NTS

Title
Area 2 - 5th Floor Plant Level - Chillers CH-5.01, CH-5.02 & CH-5.03 - Bottom Flashing

Project
Royal Free Hospital

Client
Logan Construction Limited

Drawing Number CS8664-106 Rev. A

CONABEARE ACOUSTICS
11 Chiltern Enterprise Centre,
Station Road, Theale,
Berkshire RG7 4AA
T:0118 930 3650 F:0118 930 3912
E:sales@conabeare.co.uk

Date: 26/07/2023 Drawn By WD

Issue Approval Checked By sjm

The information contained on this drawing/specification is the property of Conabeare Acoustics Limited and may not be reproduced or disclosed to a third party in any form without the written permission of Conabeare Acoustics Limited.