The Richard Stephens Partnership Limited own the copyright to the building services engineering content of this drawing which is not to be used copied published or reproduced in whole or in part in any form without written consent. 1. DO NOT SCALE FROM THIS DRAWING 2. THIS DRAWING TO BE READ IN CONJUNCTION WITH RELEVANT ARCHITECTURAL AND STRUCTURAL DRAWINGS, OTHER SERVICES DRAWINGS AND SPECIFICATIONS PACKAGED CHILLER UNIT DENOTES SERVICES TO BE REMOVED AS PART OF THE WORKS. THE SERVICES SHALL BE SAFELY ISOLATED, PURGED AND REMOVED OFF—SITE. EXISTING CHILLER SERVING MRI 3 SUITE TO BE STRIPPED OUT AND REMOVED OFF SITE, ALONG WITH ALL ASSOCIATED AND LLARIES ETC. W///// AIR / DIRT SEPERATOR -─ Ø54 CHW F&R ─ \ DROSPOSESHAFT -DOSING POF-PACKAGED AIR COOLED CHILLER C/W BUFFER TANK, PUMP AND FILL TANK. TO FIRST FLOOR LEVEL EXISTING ---FLOOR AND RUN TIGHT TO SOFFIT ø35 MCWS WITH EXISTING MRI CHILLER PIPEWORK DTB (FROM TANK ROOM) CONSTRUCTION PHASE ISSUE description The Richard Stephens Partnership Limited **Consulting Engineers** Mill Court Mill Hill Edenbridge Kent TN8 5DB Tel: 01732 782300 Fax: 01732 782340 E-mail: mail@theRSP.co.uk Website: www.theRSP.co.uk ROYAL FREE LONDON NHS FOUNDATION TRUST architect **ANSELL & BAILEY** ROYAL FREE HOSPITAL, approximate line of existing roof below LONDON IMAGING REFURBISHMENT FOURTH FLOOR MECHANICAL SERVICES TO BE REMOVED/ENABLING WORKS 1:100 @ A1 SEC'S OFFICE RSP CLEAN UTILITY ROOM 6 AG THERAPY STORE ASSESSMENT 1 BED ROOM 1 AG EXAMINATION ROOM 5 AG CONSTRUCTION PHASE DRAWING 2345-RSP-XX-04-DR-M-00041 C1