

EQUIPMENT SCHEDULE				CONDENSER SCHEDULE			
REFERENCE	CON-09-01	CON-09-02	CON-09-03				
SERVING	Basement floor FCUs	Ground floor FCUs	9th floor FCU				
Manufacturer	Mitsubishi	Mitsubishi	Mitsubishi				
MODEL	PURY-EP250YNW-A	PUMY-P200YKM2	SUZ-KA35VA6				
NO. OF INDOOR UNITS	9	7	1				
MAXIMUM COOLING CAPACITY (kW)	28	22.4	3.3				
HEATING (NOMINAL) CAPACITY (kW)	28	25	TBA				
COP/ EER	5.26/ 4.98	4.28/ 3.70	TBA				
AIR FLOW (m³/min)	185	141	TBA				
SOUNDS POWER LEVEL (dBa) @ 100% (CLG)	78.5/ 80 (Htg/ Clg)	75	62				
ELECTRICAL DETAILS							
ELECTRICAL SUPPLY (V/Ph/Hz)	380-415/3/50-60	380-415/3/50	230/1/50				
STARTING CURRENT (A)	TBA	7	5.2				
MAXIMUM RUNNING CURRENT (A) Htg/ Clg [MAX]	10/ 9.4	8.74/ 9.05 [19]	3.5/ 3.8 [7.4]				
FUSE RATING (A)	1 No. 20	1 No. 20	1 No. 10				
UNIT DETAILS							
WEIGHT (kg)	234	141	35				
DIMENSIONS WxDxH (mm)	920x 760 x 1710	1050 x 370 x 1338	800 x 285 x 550				