

Project name

14 Bedford Row Existing

As built

Date: Mon Apr 29 08:17:59 2024

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 268.08The CO₂ emission and primary energy rates of the building must not exceed the targets

The building does not comply with England Building Regulations Part L 2021

Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum	51.86
Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum	68.4
Target primary energy rate (TPER), kWh _{PE} /m ² annum	281.41
Building primary energy rate (BPER), kWh _{PE} /m ² annum	380.19
Do the building's emission and primary energy rates exceed the targets?	BER > TER BPER > TPER

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U _{a-Limit}	U _{a-Calc}	U _{i-Calc}	First surface with maximum value
Walls*	0.26	0.35	1.43	F2000000:Surf[20]
Floors	0.18	0.25	0.25	GF000004:Surf[0]
Pitched roofs	0.16	0.18	0.18	F4000001:Surf[10]
Flat roofs	0.18	0.18	0.18	F3000000:Surf[1]
Windows** and roof windows	1.6	1.42	1.6	F2000000:Surf[1]
Rooflights***	2.2	2.3	2.3	GF000004:Surf[1]
Personnel doors [^]	1.6	2.2	2.2	F2000006:Surf[2]
Vehicle access & similar large doors	1.3	-	-	No vehicle access doors in building
High usage entrance doors	3	-	-	No high usage entrance doors in building

U_{a-Limit} = Limiting area-weighted average U-values [W/(m²K)]U_{i-Calc} = Calculated maximum individual element U-values [W/(m²K)]U_{a-Calc} = Calculated area-weighted average U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.

[^] For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m ³ /(h.m ²) at 50 Pa	8	25

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	YES
Whole building electric power factor achieved by power factor correction	<0.9

1- Existing main system

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	0.91	-	0.04	-	0.7
Standard value	0.93*	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for gas single boiler systems <=2 MW output and overall for multi-boiler systems. For single boiler systems >2 MW or any individual boiler in a multi-boiler system, limiting efficiency is 0.88.					

"No HWS in project, or hot water is provided by HVAC system"

"No zones in project where local mechanical ventilation, exhaust, or terminal unit is applicable"

General lighting and display lighting Zone name	General luminaire	Display light source	
	Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
Standard value	95	80	0.3
F4 - Plant	50	-	-
GF - Corridor	106	-	-
F2 - Stair	81	-	-
F1 - Stair	89	-	-
F3 - Stair	79	-	-
GF - Stairs	86	-	-
F -1 - Stair	80	-	-
F1 - (1) - Stairs	71	-	-
F2 - Stair	115	-	-
F -1 - Corridor	115	-	-
GF - Data room	73	-	-
GF - Corridor	134	-	-
GF - Bike Store	49	-	-
GF - Store room	52	-	-
F -1 - Corridor	78	-	-
F -1 - corridor	99	-	-
F -1 - Office	65	-	-
F -1 - Office	62	-	-
F -1 - corridor	94	-	-
F -1 - Meeting room	63	-	-
F -1 - Showers	65	-	-
F -1 - Plant	49	-	-
F -1 - Plant	46	-	-
F -1 - Plant	43	-	-
F -1 - store	44	-	-
F -1 - Stair + corridor	69	-	-
GF - Entrance corridor	76	-	-

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
	Standard value	95	80	0.3
GF - Stairs		69	-	-
GF - Corridor		94	-	-
GF - Office		63	-	-
GF - Corridor		85	-	-
GF - WC		112	-	-
GF - WC		91	-	-
GF - Medic Space		77	-	-
GF - Meeting Hall		61	-	-
Store		121	-	-
GF - Corridor		87	-	-
GF - Office		69	-	-
GF - Office		68	-	-
GF - WC		106	-	-
F1 - (1) - Small Office		68	-	-
GF - Stairs		68	-	-
GF - Corridor		108	-	-
F1 - Store		83	-	-
F1 - Small Office		73	-	-
F1 - Office		59	-	-
F1 - Meeting room		74	-	-
F1 - Store		69	-	-
F1 - office		63	-	-
F1 - office		71	-	-
F1 - Office		61	-	-
F1 - Corridor		84	-	-
F1 - Office		72	-	-
F1 - office		68	-	-
F1 - office		73	-	-
F1 - Store		121	-	-
F1 - Corridor		124	-	-
F1 - Corridor		87	-	-
F2 - Corridor		87	-	-
F2 - Office		67	-	-
F2 - office		70	-	-
F2 - Office		64	-	-
F2 - Small Office		73	-	-
F2 - Small Office		72	-	-
F1 - WC		70	-	-
F1 - Stair		70	-	-
F2 - Stair		70	-	-
F2 - Store		83	-	-
F2 - WC		70	-	-
F2 - Small Office		68	-	-

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
	Standard value	95	80	0.3
F2 - Office		58	-	-
F2 - Store		65	-	-
F2 - small office		78	-	-
F2 - Small office		84	-	-
F2		95	-	-
F2		80	-	-
F2 - Office		68	-	-
F2 - Office		62	-	-
F3 - WC		73	-	-
F3 - Corridor		174	-	-
F3 - Store		66	-	-
F3 - Office		59	-	-
F3 - Small Office		75	-	-
F3 - Office		62	-	-
F3 - Office		65	-	-
F3 - Corridor		88	-	-
F3 - Corridor		107	-	-
F3 - Small Office		76	-	-
F3 - Office		64	-	-
F3 - office		67	-	-
F3 - Small Office		78	-	-
F3 - Corridor		92	-	-
F3 - small office		83	-	-
F4 - Office		61	-	-
F4 - Stair		72	-	-
F4 - HWT Plant		55	-	-
F4 - store		53	-	-
F -1 - Meeting Room		62	-	-
F1 - WC		129	-	-
F1 - WC		161	-	-
F1 - WC		128	-	-
GF - Corridor		85	-	-
GF - Enterance		67	-	-

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
F -1 - Office	NO (-87.9%)	NO
F -1 - Office	NO (-75.5%)	NO
F -1 - Meeting room	N/A	N/A
GF - Office	NO (-62.9%)	NO
GF - Medic Space	N/A	N/A
GF - Meeting Hall	YES (+16.8%)	NO
GF - Office	NO (-93.7%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
GF - Office	NO (-48.8%)	NO
F1 - (1) - Small Office	NO (-66.6%)	NO
F1 - Small Office	NO (-65.2%)	NO
F1 - Office	NO (-39.8%)	NO
F1 - Meeting room	N/A	N/A
F1 - office	N/A	N/A
F1 - office	NO (-53.9%)	NO
F1 - Office	NO (-55.1%)	NO
F1 - Office	NO (-25.8%)	NO
F1 - office	NO (-27.6%)	NO
F1 - office	NO (-64.3%)	NO
F2 - Office	NO (-52.8%)	NO
F2 - office	NO (-51.8%)	NO
F2 - Office	NO (-47.9%)	NO
F2 - Small Office	NO (-47.8%)	NO
F2 - Small Office	NO (-48.9%)	NO
F2 - Small Office	NO (-59.8%)	NO
F2 - Office	NO (-37.6%)	NO
F2 - small office	NO (-44.4%)	NO
F2 - Small office	NO (-38.3%)	NO
F2	N/A	N/A
F2	NO (-23.7%)	NO
F2 - Office	NO (-32.9%)	NO
F2 - Office	NO (-55.6%)	NO
F3 - Office	NO (-34.6%)	NO
F3 - Small Office	N/A	N/A
F3 - Office	NO (-37.9%)	NO
F3 - Office	NO (-42.7%)	NO
F3 - Small Office	NO (-40%)	NO
F3 - Office	NO (-62.8%)	NO
F3 - office	NO (-27.7%)	NO
F3 - Small Office	NO (-6.6%)	NO
F3 - small office	NO (-33.9%)	NO
F4 - Office	NO (-75.4%)	NO
F -1 - Meeting Room	NO (-88%)	NO

Regulation 25A: Consideration of high efficiency alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	NO
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	NO

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

	Actual	Notional
Floor area [m ²]	2144.7	2144.7
External area [m ²]	2489.5	2489.5
Weather	LON	LON
Infiltration [m ³ /hm ² @ 50Pa]	25	3
Average conductance [W/K]	1126.33	983.91
Average U-value [W/m ² K]	0.45	0.4
Alpha value* [%]	25.2	10

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

% Area Building Type

Retail/Financial and Professional Services
Restaurants and Cafes/Drinking Establishments/Takeaways
Offices and Workshop Businesses
General Industrial and Special Industrial Groups
Storage or Distribution
100 Hotels
Residential Institutions: Hospitals and Care Homes
Residential Institutions: Residential Schools
Residential Institutions: Universities and Colleges
Secure Residential Institutions
Residential Spaces
Non-residential Institutions: Community/Day Centre
Non-residential Institutions: Libraries, Museums, and Galleries
Non-residential Institutions: Education
Non-residential Institutions: Primary Health Care Building
Non-residential Institutions: Crown and County Courts
General Assembly and Leisure, Night Clubs, and Theatres
Others: Passenger Terminals
Others: Emergency Services
Others: Miscellaneous 24hr Activities
Others: Car Parks 24 hrs
Others: Stand Alone Utility Block

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	95.37	53.71
Cooling	0	0
Auxiliary	4.63	2.81
Lighting	12.84	5.91
Hot water	218.77	190.16
Equipment*	30.24	30.24
TOTAL**	331.61	252.59

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	0	4.11
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>0</i>	<i>4.11</i>

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	278.79	175.04
Primary energy [kWh _{PE} /m ²]	380.19	281.41
Total emissions [kg/m ²]	68.4	51.86

HVAC Systems Performance

System Type	Heat dem MJ/m ²	Cool dem MJ/m ²	Heat con kWh/m ²	Cool con kWh/m ²	Aux con kWh/m ²	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER
[ST] Central heating using water: radiators, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity									
Actual	278.8	0	95.4	0	4.6	0.81	0	0.91	0
Notional	175	0	53.7	0	2.2	0.91	0	----	----
[ST] No Heating or Cooling									
Actual	0	0	0	0	0	0	0	0	0
Notional	0	0	0	0	0	0	0	----	----

Key to terms

Heat dem [MJ/m ²]	= Heating energy demand
Cool dem [MJ/m ²]	= Cooling energy demand
Heat con [kWh/m ²]	= Heating energy consumption
Cool con [kWh/m ²]	= Cooling energy consumption
Aux con [kWh/m ²]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type