

Project name

14 Bedford Row + 12-14 Jockey's Fields - Be Lean

As designed

Date: Mon Apr 29 07:38:29 2024

Administrative information

Building Details

Address: 14 Bedford row + 12 - 14 Jockey's Fields,
London, WC1R 4ED

Certifier details

Name: Mohanad Alnaimy

Telephone number: Phone

Address: The Lab, 18 Wenlock Rd, London, N1 7TA

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 290.52

The CO₂ emission and primary energy rates of the building must not exceed the targets

The building does not comply with England Building Regulations Part L 2021

| | |
|---|-------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum | 55.57 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum | 64.21 |
| Target primary energy rate (TPER), kWh _{PE} /m ² annum | 300.99 |
| Building primary energy rate (BPER), kWh _{PE} /m ² annum | 350.36 |
| Do the building's emission and primary energy rates exceed the targets? | BER > TER BPER > TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|-------------------------------------|
| Walls* | 0.26 | 0.25 | 0.31 | F4000004:Surf[0] |
| Floors | 0.18 | 0.56 | 1.45 | GF000022:Surf[5] |
| Pitched roofs | 0.16 | 0.11 | 0.11 | F4000001:Surf[0] |
| Flat roofs | 0.18 | 0.12 | 0.18 | GF00000C:Surf[0] |
| Windows** and roof windows | 1.6 | 1.49 | 1.6 | F2000006:Surf[4] |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors [^] | 1.6 | - | - | No personnel doors in building |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | 1.56 | 1.56 | F2000006:Surf[2] |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]

U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.

[^] For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 8 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|---|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- Lean: Combined

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|---|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 0.91 | - | 0.2 | - | 0.85 |
| Standard value | 0.93* | N/A | N/A | N/A | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | NO |
| * Standard shown is for gas single boiler systems <=2 MW output and overall for multi-boiler systems. For single boiler systems >2 MW or any individual boiler in a multi-boiler system, limiting efficiency is 0.88. | | | | | |

1- Lean: Combined

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|-----------------------|--------------------------|---|
| This building | 0.91 | 0.005 |
| Standard value | 0.91 | N/A |

"No zones in project where local mechanical ventilation, exhaust, or terminal unit is applicable"

| General lighting and display lighting Zone name | General luminaire | Display light source | |
|--|-------------------|----------------------|-----------------------------------|
| | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] |
| Standard value | 95 | 80 | 0.3 |
| F (4) - Plant - N/A | 95 | - | - |
| F (2) - Stair A - 201 | 95 | - | - |
| F (1) - Stair A - 101 | 95 | - | - |
| F (4) - Stair A - 401 | 95 | - | - |
| F (3) - Stair A - 301 | 95 | - | - |
| GF - Stair A - G01 | 95 | - | - |
| F (-1) - Stair A - B01 | 95 | - | - |
| F (1) - Stair B - 102 | 95 | - | - |
| F (3) - Stair B - 302 | 95 | - | - |
| F (-1) - Studio - B14 | 100 | - | - |
| F (-1) - Corridor - B13 | 95 | - | - |
| F (-1) - Studio - B21 | 100 | - | - |
| F (-1) - Studio - B20 | 100 | - | - |
| F (-1) - CS - B18 | 95 | - | - |
| F (-1) - Studio - B27 | 100 | - | - |
| F (-1) - Studio - B26 | 100 | - | - |
| F (-1) - Studio - B25 | 100 | - | - |
| F (-1) - Studio - B19 | 100 | - | - |
| F (-1) - Stair B - B02 | 95 | - | - |
| F (-1) - Studio - B34 | 100 | - | - |
| F (-1) - Elec Intake - B40 | 95 | - | - |
| F (-1) - Breakout - B33 | 95 | - | - |
| F (-1) - DDA/WC - B39 | 95 | - | - |
| F (-1) - Amenity - B32 | 95 | - | - |

| General lighting and display lighting | | General luminaire | Display light source | |
|---------------------------------------|-----------------------|-------------------|----------------------|-----------------------------------|
| Zone name | | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] |
| | Standard value | 95 | 80 | 0.3 |
| F (-1) - Cycle Store - G35 | | 95 | - | - |
| F (-1) - Server -- B33 | | 95 | - | - |
| F (-1) - Corridor - G31 | | 95 | - | - |
| F (-1) - Stair C - G03 | | 95 | - | - |
| F (-1) - Corridor - B17 | | 95 | - | - |
| GF - Amenity - G13 | | 95 | - | - |
| GF - Studio -G15 | | 100 | - | - |
| GF - Corridor - G23 | | 95 | - | - |
| GF - Studio - G25 | | 100 | - | - |
| GF - Studio - G22 | | 100 | - | - |
| GF - Studio - G24 | | 100 | - | - |
| GF - Corridor - G27 | | 95 | - | - |
| GF - Refuse - G28 | | 95 | - | - |
| GF - Studio - G29 | | 100 | - | - |
| GF - Stair B - G26 | | 95 | - | - |
| GF - Enterance - G26 | | 95 | - | - |
| GF - Plant - G32 | | 95 | - | - |
| F (2) - Stair C - 203 | | 95 | - | - |
| F (2) - Studio - 233 | | 100 | - | - |
| F (2) - Studio - 228 | | 100 | - | - |
| F (2) - Studio - 227 | | 100 | - | - |
| F (2) - Studio - 229 | | 100 | - | - |
| F (2) - Studio - 230 | | 100 | - | - |
| F (2) - Corridor - 226 | | 95 | - | - |
| F (2) - Studio - 224 | | 100 | - | - |
| F (2) - Studio - 222 | | 100 | - | - |
| F (2) - Studio - 223 | | 100 | - | - |
| F (1) - Studio - 116 | | 100 | - | - |
| F (1) - Studio - 117 | | 100 | - | - |
| F (1) - Studio - 114 | | 100 | - | - |
| F (1) - Studio - 115 | | 100 | - | - |
| F (1) - Corridor - 113 | | 95 | - | - |
| F (1) - Studio - 121 | | 100 | - | - |
| F (1) - Studio - 122 | | 100 | - | - |
| F (1) - Studio - 123 | | 100 | - | - |
| F (1) - Studio - 131 | | 100 | - | - |
| F (1) - Stair C - 103 | | 95 | - | - |
| F (1) - Corridor - 124 | | 95 | - | - |
| F (2) - Studio - 231 | | 100 | - | - |
| F (2) - Studio - 232 | | 100 | - | - |
| F (1) - Studio - 130 | | 100 | - | - |
| F (1) - Studio - 129 | | 100 | - | - |
| F (1) - Studio - 128 | | 100 | - | - |

| General lighting and display lighting | | General luminaire | Display light source | |
|---------------------------------------|-----------------------|-------------------|----------------------|-----------------------------------|
| Zone name | | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] |
| | Standard value | 95 | 80 | 0.3 |
| F (1) - Studio - 127 | | 100 | - | - |
| F (1) - Studio - 125 | | 100 | - | - |
| F (1) - Studio - 126 | | 100 | - | - |
| F (3) - Stair C - 303 | | 95 | - | - |
| F (3) - Studio - 325 | | 100 | - | - |
| F (3) - Studio - 326 | | 100 | - | - |
| F (3) - Studio - 327 | | 100 | - | - |
| F (3) - Studio - 328 | | 100 | - | - |
| F (3) - Corridor - 320 | | 95 | - | - |
| F (3) - Studio - 329 | | 100 | - | - |
| F (3) - Studio - 323 | | 100 | - | - |
| F (3) - Studio - 324 | | 100 | - | - |
| F (2) - Studio - 214 | | 100 | - | - |
| F (2) - Studio - 215 | | 100 | - | - |
| F (2) - Studio - 216 | | 100 | - | - |
| F (2) - Studio - 217 | | 100 | - | - |
| F (3) - Studio - 314 | | 100 | - | - |
| F (3) - Studio - 315 | | 100 | - | - |
| F (2) - Corridor - 213 | | 95 | - | - |
| F (3) - Studio - 316 | | 100 | - | - |
| F (3) - Studio - 318 | | 100 | - | - |
| F (3) - Corridor - 313 | | 95 | - | - |
| F (4) - Studio - 415 | | 100 | - | - |
| F (4) - Studio - 414 | | 100 | - | - |
| F (4) - Studio - 416 | | 100 | - | - |
| F (4) - Corridor - 413 | | 95 | - | - |
| F (-1) - Corridor - B30 | | 95 | - | - |
| F (1) - Corridor - 119 | | 95 | - | - |
| F (1) - Studio - 120 | | 100 | - | - |
| F (2) - Studio - 221 | | 100 | - | - |
| F (2) - Corridor - 220 | | 95 | - | - |
| F (3) - Studio - 322 | | 100 | - | - |
| F (3) - Corridor - 321 | | 95 | - | - |
| F (-1) - Studio - B23 | | 100 | - | - |
| F(1) - WC | | 95 | - | - |
| F (1) - Studio - 118 | | 100 | - | - |
| F (2) - Studio - 218 | | 100 | - | - |
| F (3) - Studio - 319 | | 100 | - | - |
| F (4) - Studio - 417 | | 100 | - | - |
| GF - Studio - G21 | | 100 | - | - |
| GF - Studio - G18 | | 100 | - | - |
| GF - Corridor - G 14,16,17,20 | | 95 | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-------------------------|---------------------------------------|------------------------------|
| F (-1) - Studio - B14 | NO (-68.1%) | NO |
| F (-1) - Studio - B21 | NO (-55%) | NO |
| F (-1) - Studio - B20 | NO (-61.5%) | NO |
| F (-1) - Studio - B27 | NO (-79.8%) | NO |
| F (-1) - Studio - B26 | NO (-73.2%) | NO |
| F (-1) - Studio - B25 | NO (-72.2%) | NO |
| F (-1) - Studio - B19 | NO (-86%) | NO |
| F (-1) - Studio - B34 | NO (-95.7%) | NO |
| F (-1) - Breakout - B33 | N/A | N/A |
| GF - Studio - G15 | NO (-27.1%) | NO |
| GF - Studio - G25 | NO (-69.6%) | NO |
| GF - Studio - G22 | NO (-34%) | NO |
| GF - Studio - G24 | NO (-59.3%) | NO |
| GF - Refuse - G28 | NO (-66.3%) | NO |
| GF - Studio - G29 | NO (-67.4%) | NO |
| GF - Enterance - G26 | N/A | N/A |
| F (2) - Studio - 233 | NO (-47.2%) | NO |
| F (2) - Studio - 228 | NO (-35.8%) | NO |
| F (2) - Studio - 227 | NO (-52.3%) | NO |
| F (2) - Studio - 229 | NO (-33.5%) | NO |
| F (2) - Studio - 230 | YES (+19.2%) | NO |
| F (2) - Studio - 224 | NO (-21.5%) | NO |
| F (2) - Studio - 222 | NO (-23.6%) | NO |
| F (2) - Studio - 223 | NO (-18.7%) | NO |
| F (1) - Studio - 116 | YES (+35.7%) | NO |
| F (1) - Studio - 117 | NO (-20.9%) | NO |
| F (1) - Studio - 114 | YES (+23.3%) | NO |
| F (1) - Studio - 115 | NO (-20.9%) | NO |
| F (1) - Studio - 121 | NO (-11%) | NO |
| F (1) - Studio - 122 | NO (-29.1%) | NO |
| F (1) - Studio - 123 | NO (-30.3%) | NO |
| F (1) - Studio - 131 | NO (-59.6%) | NO |
| F (2) - Studio - 231 | YES (+20.8%) | NO |
| F (2) - Studio - 232 | NO (-15.4%) | NO |
| F (1) - Studio - 130 | NO (-28.6%) | NO |
| F (1) - Studio - 129 | YES (+3.7%) | NO |
| F (1) - Studio - 128 | YES (+2.2%) | NO |
| F (1) - Studio - 127 | NO (-44.1%) | NO |
| F (1) - Studio - 125 | NO (-63.6%) | NO |
| F (1) - Studio - 126 | NO (-45.6%) | NO |
| F (3) - Studio - 325 | NO (-13.5%) | NO |
| F (3) - Studio - 326 | NO (-63%) | NO |
| F (3) - Studio - 327 | NO (-39.8%) | NO |
| F (3) - Studio - 328 | YES (+12.4%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-----------------------|--------------------------------|-----------------------|
| F (3) - Studio - 329 | NO (-45.9%) | NO |
| F (3) - Studio - 323 | NO (-6.5%) | NO |
| F (3) - Studio - 324 | NO (-10.2%) | NO |
| F (2) - Studio - 214 | YES (+5.5%) | NO |
| F (2) - Studio - 215 | NO (-32.2%) | NO |
| F (2) - Studio - 216 | YES (+15.7%) | NO |
| F (2) - Studio - 217 | NO (-32.4%) | NO |
| F (3) - Studio - 314 | YES (+9.4%) | NO |
| F (3) - Studio - 315 | NO (-29.8%) | NO |
| F (3) - Studio - 316 | YES (+20.9%) | NO |
| F (3) - Studio - 318 | NO (-25.6%) | NO |
| F (4) - Studio - 415 | NO (-69.7%) | NO |
| F (4) - Studio - 414 | NO (-62.6%) | NO |
| F (4) - Studio - 416 | NO (-69.4%) | NO |
| F (1) - Studio - 120 | N/A | N/A |
| F (2) - Studio - 221 | NO (-23.4%) | NO |
| F (3) - Studio - 322 | NO (-4.3%) | NO |
| F (-1) - Studio - B23 | NO (-72.7%) | NO |
| F(1) - WC | N/A | N/A |
| F (1) - Studio - 118 | NO (-8.1%) | NO |
| F (2) - Studio - 218 | NO (-15.2%) | NO |
| F (3) - Studio - 319 | NO (-23.7%) | NO |
| F (4) - Studio - 417 | NO (-65.1%) | NO |
| GF - Studio - G21 | NO (-32.6%) | NO |
| GF - Studio - G18 | NO (-60.9%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|---|-----|
| Were alternative energy systems considered and analysed as part of the design process? | YES |
| Is evidence of such assessment available as a separate submission? | YES |
| Are any such measures included in the proposed design? | YES |

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

| | Actual | Notional |
|---|---------|----------|
| Floor area [m ²] | 2033.6 | 2033.6 |
| External area [m ²] | 2395.8 | 2395.8 |
| Weather | LON | LON |
| Infiltration [m ³ /hm ² @ 50Pa] | 8 | 3 |
| Average conductance [W/K] | 1112.77 | 994.77 |
| Average U-value [W/m ² K] | 0.46 | 0.42 |
| Alpha value* [%] | 25.34 | 10 |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

% Area Building Type

| |
|---|
| Retail/Financial and Professional Services |
| Restaurants and Cafes/Drinking Establishments/Takeaways |
| Offices and Workshop Businesses |
| General Industrial and Special Industrial Groups |
| Storage or Distribution |
| 100 Hotels |
| Residential Institutions: Hospitals and Care Homes |
| Residential Institutions: Residential Schools |
| Residential Institutions: Universities and Colleges |
| Secure Residential Institutions |
| Residential Spaces |
| Non-residential Institutions: Community/Day Centre |
| Non-residential Institutions: Libraries, Museums, and Galleries |
| Non-residential Institutions: Education |
| Non-residential Institutions: Primary Health Care Building |
| Non-residential Institutions: Crown and County Courts |
| General Assembly and Leisure, Night Clubs, and Theatres |
| Others: Passenger Terminals |
| Others: Emergency Services |
| Others: Miscellaneous 24hr Activities |
| Others: Car Parks 24 hrs |
| Others: Stand Alone Utility Block |

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|---------------|---------------|
| Heating | 77.75 | 59.37 |
| Cooling | 0 | 0 |
| Auxiliary | 3.17 | 2.91 |
| Lighting | 5.82 | 6 |
| Hot water | 222.73 | 202.41 |
| Equipment* | 20.62 | 20.62 |
| TOTAL** | 309.47 | 270.69 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|------------------------------|-------------|------------|
| Photovoltaic systems | 1.08 | 4.7 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| <i>Displaced electricity</i> | <i>1.08</i> | <i>4.7</i> |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 249.12 | 193.48 |
| Primary energy [kWh _{PE} /m ²] | 350.36 | 300.99 |
| Total emissions [kg/m ²] | 64.21 | 55.57 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|--|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Central heating using water: radiators, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity | | | | | | | | | |
| Actual | 249.1 | 0 | 77.8 | 0 | 3.2 | 0.89 | 0 | 0.91 | 0 |
| Notional | 193.5 | 0 | 59.4 | 0 | 2.3 | 0.91 | 0 | ---- | ---- |
| [ST] No Heating or Cooling | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Notional | 0 | 0 | 0 | 0 | 0 | 0 | 0 | ---- | ---- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |