


**Proposed Installation of
Mechanical Plant**

**63 Netherhall Gardens,
London, NW3 5RE**

Environmental Noise Assessment



Author: Phil Huffer B.Sc. (Hons) MIOA
Principal Consultant

Doc Ref: 104595.ph.Issue1



Proposed Installation of Mechanical Plant	
Project Address:	63 Netherhall Gardens London NW3 5RE
Project Reference:	104595

Issue/Revision Record			
Issue:	Date:	Remarks:	Author:
1	27/03/2024	First Issue	Phil Huffer

	Signature:	Print:	Title:	Date:
Author:		Phil Huffer	Principal Consultant	27/03/2024
Reviewer:		Andy Dodd	Senior Consultant	27/03/2024

1. INTRODUCTION

- 1.1 Acoustics Plus Ltd (APL) is an independent firm of multi-disciplinary acoustic engineers. APL is engaged by both private and public sector clients. APL is a registered member of The Association of Noise Consultants (ANC) and the author is a corporate member of The Institute of Acoustics (IOA).
- 1.2 APL has been instructed by Fraher & Findlay Architects (on behalf of the applicant), to consider and advise upon the noise implications of a proposed installation of mechanical plant.
- 1.3 It is understood that it is the intention to install a new climate control system which will consist of an externally located air source heat pump.
- 1.4 It is understood the London Borough of Camden (LBC) require further information on noise levels from the proposed installation in order to fully assess the noise impact upon the surrounding neighbourhood. This report provides the response to the LBC, on behalf of the Applicant.
- 1.5 This report has been prepared by Acoustics Plus Limited (APL) with all reasonable skill, care, and diligence in accordance with generally accepted acoustic consultancy principles and taking account the services and terms agreed between APL and our client.
- 1.6 Any information provided by third-parties and referred to herein may not have been checked or verified by APL unless expressly stated otherwise. Certain statements made in the report are predictions based on reasonable assumptions and good industry practice.
- 1.7 Such statements involve risk and uncertainty which could cause measured and predicted results to differ materially. APL does therefore not guarantee or warrant any prediction contained in this report.

2. BASELINE SITUATION

- 2.1 The Application Site (the “site”) is situated at 63 Netherhall Gardens, London, NW3 5RE. A location plan is shown in Diagram 1. The rear of the site and surrounding area is shown in Figures 1 to 8 attached.




Diagram 1

- 2.2 The site is an existing residential building arranged over lower ground, ground and two upper levels. The site accommodates a garden flat (No.63) and two flats above (No.63A and No.63B).
- 2.3 It is the proposal to redevelop the garden flat at No.63 which will include the addition of a new mechanical climate control system to service the property. This will require the installation of 1No. external air source heat pump. The unit will be located within a proprietary acoustic enclosure that will be sited in the rear garden and concealed with planting. The details of the acoustic enclosure are contained in Appendix A.

- 2.1 The proposed air source heat pump unit is a Mitsubishi PUHZ-W112VHA.
- 2.2 It is anticipated that the nearest noise sensitive façade to the proposed acoustic enclosure is located as indicated in Diagram 2 below. This façade belongs to The Cottage, 67 Fitzjohn's Avenue which is approximately 6m from the proposed location of the enclosure. Direct line of sight between this property and the enclosure is obscured with dense vegetation.



Diagram 2

3. NOISE OUTLINE

- 3.1 In order to produce an environmental noise assessment, consideration must be given to the prevailing background noise in the locality of the installation.
- 3.2 Measurements of background noise were obtained over a 24 hour period at a location deemed representative of background noise levels experienced at the nearest noise sensitive façade. Noise monitoring equipment was installed at the rear of the garden of 63 Netherhall Gardens, adjacent to the noise sensitive property.
- 3.3 The particulars of the measurement exercise are recorded below:

Date: 13th – 14th March 2024
 Start Time: 14:00 hrs
 Location: Rear garden of 63 Netherhall Gardens.
 Weather: Appropriate to monitor environmental noise (see Diagram 3)
 – weather data obtained from local weather station.




Diagram 3

- 3.4 Minimum background and average noise levels obtained at the rear of the site are shown in Table 1 below with the full level vs time history shown in Diagram 4 (L_{Aeq} and L_{A90}).

Measurements obtained in rear garden		
Time period	Lowest $L_{A90,15min}$	Average $L_{Aeq,T}$
07:00-23:00hrs	41dB	56dB
23:00-07:00hrs	34dB	43dB

Table 1




Diagram 4

4. EQUIPMENT

4.1 All measurements were obtained using the following equipment:

- NTi XL2 Sound Level Meter Class 1 Serial No. A2A-14612-E0, FW4.71
- Rion Calibrator Type NC-74 Class 1 Serial No. 00410215

4.2 The relevant equipment carries full and current traceable calibration. The equipment, where necessary, was calibrated prior to and after the measurements were carried out.

5. DESIGN CRITERIA

- 5.1 Information regarding the noise levels not to be exceeded by the proposed installation was extracted from the London Borough of Camden's Local Plan Policy A4 adopted 3 July 2017 (Appendix 3 Noise thresholds). Please see extract below:

"Industrial and Commercial Noise Sources

A relevant standard or guidance document should be referenced when determining values for LOAEL and SOAEL for non-anonymous noise. Where appropriate and within the scope of the document it is expected that British Standard 4142:2014 'Methods for rating and assessing industrial and commercial sound' (BS 4142) will be used. For such cases a 'Rating Level' of 10 dB below background (15dB if tonal components are present) should be considered as the design criterion).

Table C: Noise levels applicable to proposed industrial and commercial developments (including plant and machinery)

Existing noise sensitive receptor	Assessment Location	Design Period	LOAEL (green)	LOAEL to SOAEL (Amber)	SOAL (Red)
Dwellings**	Garden used for main amenity (free field) and outside living or dining or bedroom window (façade)	Day	'Rating level' 10dB* below background	'Rating level' between 9dB below and 5dB above background	'Rating level' greater than 5dB above background
Dwellings**	Outside bedroom window (façade)	Night	'Rating level' 10dB* below background and no events exceeding 57dB L _{Amax}	'Rating level' between 9dB below and 5dB above background or noise events between 57dB and 88dB L _{Amax}	'Rating level' greater than 5dB above background and/or events exceeding 88dB L _{Amax}

*10dB should be increased to 15dB if the noise contains audible tonal elements. (day and night). However, if it can be demonstrated that there is no significant difference in the character of the residual background noise and the specific noise from the proposed development then this reduction may not be required. In addition, a frequency analysis (to include, the use of Noise Rating (NR) curves or other criteria curves) for the assessment of tonal or low frequency noise may be required.

**levels given are for dwellings, however, levels are use specific and different levels will apply dependent on the use of the premises.

The periods in Table C correspond to 0700 hours to 2300 hours for the day and 2300 hours to 0700 hours for the night. The Council will take into account the likely times of occupation for types of development and will be amended according to the times of operation of the establishment under consideration."

- 5.2 The procedure contained in BS4142 is to quantify the “specific sound level”, which is the measured or predicted level of sound from the source in question over a one-hour period for the daytime and a 15 minute period for the night-time. Daytime is defined in the standard as 07:00 to 23:00 hours, and night-time as 23:00 to 07:00 hours.
- 5.3 The specific sound level is converted to a rating level by adding penalties to account for either tonality or impulsivity. The standard sets out objective methods for determining the presence of tones or impulsive elements but notes that it is acceptable to subjectively determine these effects.
- 5.4 The penalty for tonal elements is between 0dB and 6dB, and the standard notes:
“Subjectively, this can be converted to a penalty of 2 dB for a tone which is just perceptible at the noise receptor, 4 dB where it is clearly perceptible, and 6 dB where it is highly perceptible.”
- 5.5 The penalty for impulsive elements is between 0dB and 9dB, and the standard notes:
“Subjectively, this can be converted to a penalty of 3 dB for impulsivity which is just perceptible at the noise receptor, 6 dB where it is clearly perceptible, and 9 dB where it is highly perceptible.”
- 5.6 Where the specific sound features characteristics that are neither tonal nor impulsive, nor intermittent, though otherwise are readily distinctive against the residual acoustic environment, a penalty of 3 dB can be applied.
- 5.7 The background sound level should be established in terms of the LA90 noise index. The standard states that the background sound level should be measured over a period of sufficient length to obtain a representative value. This should not normally be less than 15-minute intervals. The standard states that:
“A representative level ought to account for the range of background sound levels and ought not automatically to be assumed to be either the minimum or modal value.”
- 5.8 The assessment outcome results from a comparison of the rating level with the background sound level. The standard states:
*a) Typically, the greater this difference, the greater the magnitude of the impact.
b) A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context.
c) A difference of around +5 dB is likely to be an indication of an adverse impact, depending on the context.
d) The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context.
Adverse impacts include, but are not limited to, annoyance and sleep disturbance. Not all adverse impacts will lead to complaints and not every complaint is proof of an adverse impact.”*

5.9 The standard goes on to note that:

“Where background sound levels and rating levels are low, absolute levels might be as, or more, relevant than the margin by which the rating level exceeds the background. This is especially true at night.”

5.10 In addition to the margin by which the Rating Level of the specific sound source exceeds the Background Sound Level, the 2014 edition places emphasis upon an appreciation of the context, as follows:

“An effective assessment cannot be conducted without an understanding of the reason(s) for the assessment and the context in which the sound occurs/will occur. When making assessments and arriving at decisions, therefore, it is essential to place the sound in context.”

5.11 The background noise levels were assessed using statistical analysis of the measured data, as directed in BS4142. The histogram of L_{A90} noise levels obtained during the more noise sensitive night-time period of the proposed plant operation can be seen in Diagram 5.




Diagram 5

5.12 In this instance the most commonly occurring night-time background noise level was 1dB higher than the lowest background noise level. In the context in which the sound occurs, the lowest value of 34dB $L_{A90,15min}$ is considered as representative for night-time noise levels at the nearest noise sensitive façade.

5.13 The plant noise emission criteria that should not be exceeded is therefore based on the statistical analysis and is shown in Table 2 below. This level should not be exceeded at the nearest noise sensitive façade and is representative of the LOAEL green value.

Noise emission limit for mechanical plant
$L_{Aeq} \leq 24dB$

Table 2

6. NOISE IMPACT OF PLANT

- 6.1 Where necessary, mitigation measures have been incorporated into the calculation exercise to ensure that compliance with the local planning criteria is obtained. These mitigation measures are identified separately in the body of the report and are an essential requirement in meeting the LBC criteria.
- 6.2 In order to predict the noise impact of the proposed installation of plant, consideration has been given to noise egress from the acoustic enclosure to the nearest noise sensitive façade. It has been assumed that the unit will be operational at any time during the daytime or night-time period.
- 6.3 The calculation exercise utilised information provided by Mitsubishi and Environ Group. A copy of the data sheets are provided in Appendix A.
- 6.4 Environ Group state that their acoustic enclosure will reduce the stated output of the air source heat pump unit from 53dBA to 27dBA.

unity			environ group		
acoustic enclosures			+44 (0) 20 3540 7179		
DATA SHEET			www.environgroup.co.uk		
EG-U139-ME35			28 March 2024		
Acoustic enclosure for AC Split Systems					
CUSTOMER:			SITE / LOCATION / REFERENCE		
Acoustics Plus			63 Netherhall Gardens		
ORIGINAL EQUIPMENT MANUFACTURERS PUBLISHED DATA					
MAKE, MODEL, DIMENSIONS, AIR FLOW & SOUND PRESSURE LEVEL @1.0M FREE FIELD					
MAKE		MODEL		AIR IN	
Mitsubishi Electric		PUHZ-W112VHA		H - 2 Side	
H - Front					
WIDTH (MM)	DEPTH (MM)	HEIGHT (MM)	AIRFLOW (M ³ S ⁻¹)	DISTANCE (M)	SPW dB(A)
1020	330 + 30	1350	1.67	1	53
INNER CUBE DIMENSION			ENCLOSURE DETAIL		
WIDTH (MM)	DEPTH (MM)	HEIGHT (MM)	WIDTH (MM)	DEPTH (MM)	HEIGHT (MM)
1150	450	1720	1850	1050	1785
AIRFLOW (M ³ S ⁻¹)	DISTANCE (M)	SPL dB(A)	AIRFLOW (M ³ S ⁻¹)	DISTANCE (M)	SPL dB(A)
1.67	1.0	53	1.67	1.0	27
INLET AIRWAYS			DESIGN CRITERIA		
WIDTH (MM)	HEIGHT (MM)	NO.	UNIT SIZE	INTLET	OUTLET
275	1720	1	OK	OK	OK
OUTLET AIRWAYS			AIRFLOW INFORMATION		
WIDTH (MM)	HEIGHT (MM)	NO.	PD (MM ²)	INLET (M ³ S ⁻¹)	OUTLET (M ³ S ⁻¹)
275	1720	1	15	3.5	3.5
ENCLOSURE INFORMATION					
WIDTH (MM)	DEPTH (MM)	HEIGHT (MM)			
275		1720			
INLET AIRWAY					
275		1720			
OUTLET AIRWAY					
1850	1050	1785			
EXTERNAL SIZE					
27			***SPW dB(A) SOUND PRESSURE		

Diagram 6

- 6.5 The following acoustic feature corrections were used to determine a rating level:

Results	Penalty	Relevant clause	Commentary
Acoustic feature corrections BS4142	+3dB	9.2	Other acoustic characteristics

Table 3

6.6 The noise impact assessment of the proposed installation is shown in Table 4.

Air source heat pump noise impact	Noise impact calculation
Mitsubishi PUHZ-W112VHA (heating)	53dBA @ 1m
Mitsubishi PUHZ-W112VHA (in enclosure)	27dBA @ 1m
Distance attenuation over 6m	-16dB
BS4142 Acoustic corrections	+3dB
Total Rated Level	14dBA
LPA requirement (based on night-time LA90)	≤24dB

Table 4

- 6.7 Any noise from the installation of the air source heat pump and enclosure (related to the climate control of the house) should not exceed a level of 24dBA at the nearest noise sensitive façade.
- 6.8 The calculation exercise (Table 4) demonstrates that the plant noise impact meets Local Plan Policy A4 adopted 3 July 2017 (Appendix 3 Noise thresholds) as reproduced in para 4.1 above. The noise impact meets the LOAEL green LPA criteria.

7. CONCLUSION

- 7.1 The foregoing assessment indicates that the proposed installation will meet the specific noise threshold requirements from Appendix 3 of Camden Council's Local Plan referenced in Policy A4. Further mitigation measures, other than those identified, will not be required. The mitigation measures that must be implemented are as follows:
- The air source heat pump unit should be located within a proprietary acoustic enclosure as specified (or equivalent performance).
- 7.2 The acoustic enclosures are often supplied flat packed and require assembling on site. Careful attention should be paid to the manufacturers assembly instructions to ensure that unwanted panel resonance is not introduced.
- 7.3 If an alternative supplier/manufacturer of air source heat pump unit is chosen, the acoustic performance should be checked prior to installation to ensure that the installation will still meet the requirements imposed by the LPA.

Figures

63 Netherhall Gardens, London, NW3 5RE



Figure 1



Figure 2



Figure 3



Figure 4



Figure 5



Figure 6



Figure 7



Figure 8

Appendix A

June 2014

No. OCH562

SERVICE MANUAL

R410A

Outdoor unit
[Model Name]

PUHZ-W112VHA

Salt proof model

PUHZ-W112VHA-BS


[Service Ref.]

PUHZ-W112VHA

PUHZ-W112VHA-BS

Note:

- This manual describes service data of outdoor unit only.



CONTENTS

1. SAFETY PRECAUTION.....	2
2. SPECIFICATIONS.....	5
3. DATA	7
4. OUTLINES AND DIMENSIONS.....	9
5. WIRING DIAGRAM.....	10
6. WIRING SPECIFICATIONS	11
7. REFRIGERANT SYSTEM DIAGRAM	12
8. TROUBLESHOOTING	13
9. DISASSEMBLY PROCEDURE.....	41



PARTS CATALOG (OCB562)

3-1. NOISE CRITERION CURVES

PUHZ-W112VHA

PUHZ-W112VHA-BS

MODE	SPL(dB)	LINE
COOLING	53	○—○
HEATING	53	●—●



DATA SHEET

www.environgroup.co.uk

EG-U139-ME35

Acoustic enclosure for AC Split Systems

28 March 2024

CUSTOMER:

SITE / LOCATION / REFERENCE

Acoustics Plus	TBC
----------------	-----

ORIGINAL EQUIPMENT MANUFACTURERS PUBLISHED DATA
MAKE, MODEL, DIMENSIONS, AIR FLOW & SOUND PRESSURE LEVEL @1.0M FREE FIELD

MAKE			MODEL	AIR IN	AIR OUT
Mitsubishi Electric			PUZH-W112VHA	H - 2 Side	H - Front
WIDTH (MM)	DEPTH (MM)	HEIGHT (MM)	AIRFLOW (M ³ S ⁻¹)	DISTANCE (M)	SPW dB(A)
1020	330 + 30	1350	1.67	1	53
INNER CUBE DIMENSION			ENCLOSURE DETAIL		
WIDTH (MM)	DEPTH (MM)	HEIGHT (MM)	WIDTH (MM)	DEPTH (MM)	HEIGHT (MM)
1150	450	1720	1850	1050	1785
AIRFLOW (M ³ S ⁻¹)	DISTANCE (M)	SPL dB(A)	AIRFLOW (M ³ S ⁻¹)	DISTANCE (M)	SPL dB(A)
1.67	1.0	53	1.67	1.0	27
INLET AIRWAYS			DESIGN CRITERIA		
WIDTH (MM)	HEIGHT (MM)	NO.	UNIT SIZE	INTLET	OUTLET
275	1720	1	OK	OK	OK
OUTLET AIRWAYS			AIRFLOW INFORMATION		
WIDTH (MM)	HEIGHT (MM)	NO.	PD (NM ²)	INLET (MS ⁻¹)	OUTLET (MS ⁻¹)
275	1720	1	15	3.5	3.5

ENCLOSURE INFORMATION
INLET AIRWAY
OUTLET AIRWAY
EXTERNAL SIZE
INDICATIVE NOISE LEVEL



WIDTH (MM)	DEPTH (MM)	HEIGHT (MM)
275		1720
275		1720
1850	1050	1785
27	**SPW dB(A) SOUND PRESSURE	

NOTES CONCERNING ENCLOSURE DESIGN

Minimum Space Required in front of airways - 300mm

Unity Access Panels Lift Off or Hinged for Maintenance/Service

** Noise level above based on Free Field condition - actual noise levels will be dependant on site conditions




DATA SHEET


EG-U139-ME35

Acoustic enclosure for AC Split Systems


28 March 2024



Exterior Colour
Any RAL/BS Colour
Special Finishes Available




Service/Maintenance Access



OPTIONAL EXTRAS

Anti Vibration Mounts
Condensate Drain Pan
Drain Pan Heater Tape
Invisible' Wall Mounting Frame



Balanced Air Flow
Internal Plenum Seals stop
Air Recirculation

