



- NOTES:**  
DO NOT SCALE FROM THIS DRAWING.
- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE MECHANICAL SPECIFICATION, THE ARCHITECTS DIMENSIONED LAYOUTS AND ALL OTHER RELEVANT CONTRACT DOCUMENTATION.
  - ALL MECHANICAL VENTILATION DUCTWORK SHALL BE GALVANISED SHEET METAL DUCTWORK SUPPLIED AND INSTALLED IN ACCORDANCE WITH HVCA DW/144
  - ANY DUCTWORK PENETRATING A FIRE RATED BARRIER OR STRUCTURE SHALL INCORPORATE A SUITABLY RATED FIRE DAMPER
  - ALL FIRE DAMPERS TO BE FULLY ACCESSIBLE. THIS ACCESS WILL REQUIRE DUCT ACCESS DOORS AND WHERE REQUIRED REMOVABLE CEILING SECTIONS
  - THE CONTRACTOR SHALL ALLOW FOR TESTING, COMMISSIONING AND SETTING TO WORK ALL VENTILATION SYSTEMS IN ACCORDANCE WITH THE CIBSE COMMISSIONING CODE 'A' AND THE RELEVANT BSRIA APPLICATION GUIDES
  - THE MECHANICAL CONTRACTOR SHALL BE RESPONSIBLE FOR THE CO-ORDINATION OF THEIR WORKS WITH ALL OTHER TRADES

**LEGEND:**

- FRESH AIR DUCTWORK
- EXHAUST AIR DUCTWORK
- SUPPLY AIR DUCTWORK
- EXTRACT AIR DUCTWORK
- FUME EXHAUST AIR DUCTWORK
- TENANT FIT-OUT DUCTWORK
- X DUCT ACCESS DOOR
- VAV VAV BOX
- CAV CAV BOX
- FD FIRE DAMPER
- SD SMOKE DAMPER
- [Wavy Line] DUCT ATTENUATOR
- [Cross-hatched] CROSSTALK ATTENUATOR
- [Dashed] VOLUME CONTROL DAMPER
- [Circle] BOOSTER FAN
- [Square] RETURN AIR GRILLE
- [Orange Box] FUME CUPBOARD/BSC

S4-P01	26/01/2024	STAGE 3 CAT-B ISSUE	TE	AG
SUIT-REV	DATE	DESCRIPTION	DRN	CHK
STATUS				

**STAGE 3**

THIS DRAWING IS COPYRIGHT. DO NOT SCALE FROM DRAWING. THE CONTRACTOR AND THEIR SUB-CONTRACTORS ARE TO VERIFY ALL DIMENSIONS ON SITE BEFORE MAKING SHOP DRAWINGS OR COMMENCING MANUFACTURE.

**KJ TAIT**  
ENGINEERS

1 Fitzroy Square  
London W1T 5HF  
T +44 (0) 207 388 0952  
E london@kjtait.com  
W www.kjtait.com

PROJECT INFORMATION			
CLIENT	OXFORD VICTORIA HOUSE DEVELOPMENT LTD		
PROJECT	LONDON, WC1B 4DA		
DRAWING INFORMATION			
DRAWING TITLE	MECHANICAL SERVICES 5TH FLOOR VENTILATION LAYOUT SHEET 1 of 2		
DESIGNED BY	TE	DATE	JAN 2024
DRAWN BY	MZ	KJT JOB No.	
SCALE	1 : 100 @ A1	L3221	
JOB CODE	ORIGIN-VOL-LEVEL-TYPE-ROLE-CLASS NUMBER	SUIT-REV	
L3221	KJT-01-05-DR-M-5710	S4 - P01	