



- NOTES:**  
 DO NOT SCALE FROM THIS DRAWING.
- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE MECHANICAL SPECIFICATION, THE ARCHITECTS DIMENSIONED LAYOUTS AND ALL OTHER RELEVANT CONTRACT DOCUMENTATION.
  - ALL MECHANICAL VENTILATION DUCTWORK SHALL BE GALVANISED SHEET METAL DUCTWORK SUPPLIED AND INSTALLED IN ACCORDANCE WITH HVCA DW/144
  - ANY DUCTWORK PENETRATING A FIRE RATED BARRIER OR STRUCTURE SHALL INCORPORATE A SUITABLY RATED FIRE DAMPER
  - ALL FIRE DAMPERS TO BE FULLY ACCESSIBLE. THIS ACCESS WILL REQUIRE DUCT ACCESS DOORS AND WHERE REQUIRED REMOVABLE CEILING SECTIONS
  - THE CONTRACTOR SHALL ALLOW FOR TESTING, COMMISSIONING AND SETTING TO WORK ALL VENTILATION SYSTEMS IN ACCORDANCE WITH THE CIBSE COMMISSIONING CODE 'A' AND THE RELEVANT BSRIA APPLICATION GUIDES
  - THE MECHANICAL CONTRACTOR SHALL BE RESPONSIBLE FOR THE CO-ORDINATION OF THEIR WORKS WITH ALL OTHER TRADES

- LEGEND:**
- FRESH AIR DUCTWORK
  - EXHAUST AIR DUCTWORK
  - SUPPLY AIR DUCTWORK
  - EXTRACT AIR DUCTWORK
  - FUME EXHAUST AIR DUCTWORK
  - TENANT FIT-OUT DUCTWORK
  - X DUCT ACCESS DOOR
  - VAV VAV BOX
  - CAV CAV BOX
  - FD FIRE DAMPER
  - SD SMOKE DAMPER
  - [Wavy Line] DUCT ATTENUATOR
  - [Sawtooth Line] CROSSTALK ATTENUATOR
  - [Damper Symbol] VOLUME CONTROL DAMPER
  - [Fan Symbol] BOOSTER FAN
  - RETURN AIR GRILLE
  - FUME CUPBOARD/BSC

SUIT-REV	DATE	DESCRIPTION	TE	AG
S4-P01	26/01/2024	STAGE 3 CAT -B ISSUE	TE	AG

**STAGE 3**

THIS DRAWING IS COPYRIGHT. DO NOT SCALE FROM DRAWING. THE CONTRACTOR AND THEIR SUB-CONTRACTORS ARE TO VERIFY ALL DIMENSIONS ON SITE BEFORE MAKING SHOP DRAWINGS OR COMMENCING MANUFACTURE.

**KJ TAIT**  
 ENGINEERS

1 Fitzroy Square  
 London W1T 5HF  
 T +44 (0) 207 388 0952  
 E london@kjtait.com  
 W www.kjtait.com

PROJECT INFORMATION			
CLIENT	OXFORD VICTORIA HOUSE DEVELOPMENT LTD LONDON, WC1B 4DA		
DRAWING INFORMATION			
DRAWING TITLE	MECHANICAL SERVICES 6TH FLOOR VENTILATION LAYOUT SHEET 1 of 2		
DESIGNED BY	TE	DATE	JAN 2024
DRAWN BY	MZ	KJT JOB No.	L3221
SCALE	1 : 100 @ A1		L3221
JOB CODE	ORIGIN-VOL-LEVEL-TYPE-ROLE-CLASS NUMBER	SUIT-REV	
L3221	KJT-01-06-DR-M-5710	S4 - P01	