



MYCO Ltd
3rd Floor, 21 Godliman Street
London EC4V 5BD
www.mycold.co.uk

24/05/24

MC035 Acorn House – Condition 24 External Lighting Strategy

External lighting is located at the Lower Ground, Ground, 6th, 9th floor and all apartment balconies.

Ground Floor entrances shall be controlled via timeclock with photocell link. In active mode (dusk till dawn) the lights shall be fully switched on via timeclock or photocell and shall remain on until local photocell or astronomical time clock switches the lights to standby mode. The lights shall be off in standby mode (Dawn till dusk).

The communal external lighting - 6F playspace & 9F roof terrace will be via presence detection. With deactivation approximately 15 minutes after no movement is detected.

9F Plant side to be locally switched.

For individual apartment balcony lights and office lightwell this will be locally switched (non-dimmable).

Refer to Luminaire schedule, item D; D/E – Wall mounted tower light at approximately 1800mm high.