

	Work Order Number
--	-------------------



Optimum Group Services plc
 Jebson House
 53-61 High Street
 Ruislip
 Middlesex

Tel: 0870 850 3131
 Fax: 0870 850 3132
 Email: hello@weareoptimum.com
 Web: www.weareoptimum.com

123984



Job Sheet

Customer Name	Regents Place	Location of Plant	Gas Meter Room	
Address	1,4, 7 Triton Square	Boiler Number	Fuel	NG
		Manufacturer	Gas Pipework	
		Model	NA	
Contact Name	Danny Noakes	Serial Number	NA	
Contact Number		Burner	NA	
Contact Email		KW Rating	NA	
Reason for Visit	Site Attendance	Condition of Plant	Off	

	Yes / No
Has a Permit to Work Been issued?	Yes
Has a Dynamic Risk Assessment Been carried out?	Yes

Description of Works Carried Out:

Attended site, isolated boilers (electrically and gas) in main boiler room and gym boiler room.
 Isolated ECV on both pipework installations
 Carried out tightness test on both pipework installations as per IGE UP/1, all satisfactory
 Left isolated and paperwork issued

	Yes / No		Yes / No		Yes / No
Job Completed?	Yes	FPQ Required?	Yes	Gas Sheet Completed?	Yes

Date	Time on Site	Time Off Site	Hours on Site	Hours x 1	Hours x 1.5	Hours x 2	Travel	Parking
28/02/2018	14:00	17:30	3	2 1/2	1/2			32

Engineer Signature	<i>N Farrant</i>
Engineer Name	N Farrant
Client Signature	Unavailable
Date	28/02/2018