

Date sent	Subject	Sent By	Attachments
27/07/2021 15:14	FR - Survey Cellar Cooling	Paul Phillips	1 [image.jpg]

## Details

Part 1	
Webuser	
Location	Below Ground
Dimensions Length	6
Dimensions Width	4.5
Dimensions Height	2.2
Heat Load	no other heat load
Is the pipework suitable for re-use?	Yes
What is the suction pipe size?	7/8 in
What is the liquid line size?	1/2 in
Length Horizontal	5
Length Vertical	10
Total Run Length	15
Part 2	
Evaporator Location	Wall Mounted
Qty Evaporators on System	1
Drainage Type	Gravity
Supply Available Evaporator	1 Phase
Supply Available Condensing Unit	1 Phase
Circuit Breaker or Fuse Size	16A
Supply Locations	in room and roof
Condensing Unit Location	Roof
Label	How high? (mm)
How high? (mm)	
Remote Condenser Required	Yes
Water Cooled Condenser Required	No
Label	Location of Water Supply
If Water Cooled, Location of Water Supply	
Condensing Unit Mounting	Brackets
Specialist Equipment for Access or Egress DD	Ladders
Label 1	Other
Specialist Equipment For Access Or Egress	
Specialist Equipment for Siting Equipment DD	Ladders
Label 2	Other
Specialist Equipment For Siting Equipment	

Does any existing equipment require removal?	Yes
Label 3	Please Enter Requirements
Does Any Existing Equipment Require Removal	full kit removal
Any Other Details DD	No
Label 4	Please Enter
Any Other Details	
Make of Existing Machine	BEERMASTER
Model of Existing Machine	bmi407-69

## Attachments



To view and open attachments, select 'view' > 'Navigation Panels' > 'Attachments' from the main menu of Adobe Reader. Attachment support is only available in Adobe Reader