



Anderson  
Green

building services consultants

# Ventilation Calculations *For* Camden Hostels, Camden Road

*On behalf of*  
**MORGAN**  
**SINDALL**

DOCUMENT NUMBER: 123007-AGL-CA-XX-CA-M-0001					
REV	DESCRIPTION	CHECKED		STATUS	DATE
		DESIGN	QA		
P01	Stage 4 – Issued for Comment	E Thornton	A Moss	S3	22.02.24

11 United Business Park, Lowfields Road, Leeds, LS12 6UB  
Tel: 0113 243 2672 Visit: [AndersonGreen.co.uk](http://AndersonGreen.co.uk)

Registered in England & Wales No 4309499 VAT reg no 788 9812 47

Project Name	Camden Road
Project No.	LE0270
Title	ESP Calculations.xlsx
Date:	27/10/2023
By	Leon Amoah
QA'd By	

Unit Chosen  
Q-AIRE-V125 (Valve - Filterless) 125  
Maximum Pa of Unit 175

LGH-RVXT-E\_-PL\_2022 200

**External Static Pressure Calculations**

Apartment	Ductwork Pressure Losses (Index Run)	Total Bend Pressure Losses	Attenuator Pressure Loss (Index Run)	Louvre / Air Brick Pressure Loss	Ceiling Grille Pressure Loss	Total ESP	10% Margin
Landlord Area	11.0	5.5	20	?	3.4	39.9	43.9
	9.7	10.7	20		2	42.4	Pa
	15.1	14.4	20		13	62.5	Pa
	9.5	13.5	20		3.7	46.7	Pa

**Landlord Area Index Run - Extract**

Index Run Ductwork Section	Duct Size	Air Flow Rate (l/s)	Duct Length (m)	Pressure Loss / metre (Pa/m)	Pressure Loss (Pa)
Section 1	150Ø		32	2.14	0.37
Section 2	150Ø		32	11.4	0.37
Section 3	150Ø		32	0.96	0.37
Section 4	200Ø		64	3.61	0.32
Section 5	250Ø		79	6.45	0.16
Section 6	250Ø		109	3.7	0.28
Section 7	250Ø		109	0.74	0.28
Section 8	250Ø		109	0.51	0.28
Section 9	250Ø		109	0.86	0.28
Section 10	250Ø		109	1.8	0.28
Section 11	250Ø		109	4.8	0.28
<b>TOTAL</b>					<b>11.0 Pa</b>

**Landlord Area - Bends**

Bend	Air Flow Rate (l/s)	Pressure Loss (Pa)
1 - Bend	32	0.5 Pa
2 - Bend	32	0.5 Pa
3 - T Bend	64	0.5 Pa
4 - T Bend	79	0.5 Pa
5 - T Bend	109	0.5 Pa
6 - Bend	109	0.5 Pa
7 - Bend	109	0.5 Pa
8 - Adapter	109	0.5 Pa
9 - Adapter	109	0.5 Pa
10 - Bend	109	0.5 Pa
11 - Bend	109	0.5 Pa
<b>TOTAL</b>		<b>5.5 Pa</b>

**Camden Studio Index Run**

Index Run Ductwork Section	Duct Size	Air Flow Rate (l/s)	Duct Length (m)	Pressure Loss / metre (Pa/m)	Pressure Loss (Pa)
Section 1	204x60		21	0.41	0.9
Section 2	204x60		21	5.85	0.9
Section 3	204x60		21	0.52	0.9
Section 4	204x60		21	1.2	0.9
Section 5	204x60		21	2.83	0.9
<b>TOTAL</b>					<b>9.7 Pa</b>

**Camden Studio Apartment**

Bend	Air Flow Rate (l/s)	Pressure Loss (Pa)
1 - Spigot	21	3
2 - Bend	21	2.9 Pa
3 - Adapter	21	1
4 - Adapter	21	1
5 - Bend	21	2.9 Pa
6 - Bend	21	2.9 Pa
<b>TOTAL</b>		<b>10.7 Pa</b>

**Camden 2Bed Apartment**

Index Run Ductwork Section	Duct Size	Air Flow Rate (l/s)	Duct Length (m)	Pressure Loss / metre (Pa/m)	Pressure Loss (Pa)
Section 1	204x60		7	5.12	0.2
Section 2	204x60		7	1.92	0.2
Section 3	204x60		14	3.83	0.5
Section 4	204x60		21	1.42	0.9
Section 5	204x60		21	2.25	0.9
Section 6	204x60		21	1.22	0.9
Section 7	204x60		21	6.41	0.9
Section 8	204x60		21	1.82	0.9
<b>TOTAL</b>					<b>15.1 Pa</b>

**Camden 2Bed Bends Apartment**

Bend	Air Flow Rate (l/s)	Pressure Loss (Pa)
1 - Spigot	7	0.6 Pa
2 - Bend	7	0.2 Pa
3 - T Bend	14	1.1 Pa
4 - T Bend	21	2.1 Pa
5 - Bend	21	3 Pa
6 - Bend	21	3 Pa
7 - Adapter	21	1 Pa
8 - Adapter	21	1 Pa
9 - Bend	21	3 Pa
<b>TOTAL</b>		<b>14.4 Pa</b>

**Camden - Wheelchair Unit**

Index Run Ductwork Section	Duct Size	Air Flow Rate (l/s)	Duct Length (m)	Pressure Loss / metre (Pa/m)	Pressure Loss (Pa)
Section 1	204x60		11	0.41	0.3
Section 2	204x60		11	3.5	0.3
Section 3	204x60		22	0.98	0.8
Section 4	204x60		22	2.04	0.8
Section 5	204x60		22	3.52	0.8
Section 6	204x60		22	2.98	0.8
Section 7	204x60		22	0.85	0.8
<b>TOTAL</b>					<b>9.5 Pa</b>

**Camden - Wheelchair Unit Bends**

Bend	Air Flow Rate (l/s)	Pressure Loss (Pa)
1 - Spigot	11	0.7 Pa
2 - Bend	11	1 Pa
3 - T Bend	22	0.6 Pa
4 - Bend	22	3 Pa
5 - Adapter	22	1.1 Pa
6 - Adapter	22	1.1 Pa
7 - Bend	22	3 Pa
8 - Bend	22	3 Pa
<b>TOTAL</b>		<b>13.5 Pa</b>

**Camden Road  
New Dwelling Ventilation Rates**

Continuous Extract Rates  
Part F Table 1.2a

Ref	Kitchen	Bathroom	En-suite	Utility	Total l/s
Studio	1	1	0	0	21
Wheelchair Unit	1	1	0	0	21

Extract Ventilation rates

Kitchen	13 l/s
Bathroom	8 l/s
En-suite	8 l/s
Utility	8 l/s

**Table 1.2 Minimum extract ventilation rates for continuous extract systems<sup>(1)</sup>**

Room	High rate (l/s)	Continuous rate
Kitchen	13	The sum of all extract ventilation in the dwelling on its continuous rate should be at least the whole dwelling ventilation rate given in Table 1.3
Utility room	8	
Bathroom	8	
Sanitary accommodation	6	

**NOTE:**

1. If the continuous rate of ventilation provided in a room is equal to or higher than the minimum high rate specified in the table, no extra ventilation is needed.

Whole Dwelling Ventilation Rates  
Part F Claus 1.24

Ref	No. of Bedrooms	Total l/s
Studio	1	19
Wheelchair Unit	1	19

Minimum Ventilation Rate  
Part F Table 1.3


Ref	Area	Total l/s
Studio	29	9
Wheelchair Unit	59.86	18

**Table 1.3 Minimum whole dwelling ventilation rates determined by the number of bedrooms**

Number of bedrooms <sup>(1)(2)</sup>	Minimum ventilation rate by number of bedrooms (l/s)
1	19
2	25
3	31
4	37
5	43

**NOTES:**

1. If the dwelling only has one habitable room, a minimum ventilation rate of 13l/s should be used.
2. For each additional bedroom, add 6l/s to the values in Table 1.3.



Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0270\_MSC\_Camden Hostels Camden Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Supply duct sizing - Landlord Supply**

Section	Duct type	Flow rate (m <sup>3</sup> /s)	Size (mm)	Velocity (m/s)	Length (m)	Pressure drop (N/m <sup>2</sup> )
1	Circular	0.109	250	2.22	5	43.52
2	Circular	0.016	150	0.91	3.75	12.78
3	Circular	0.093	250	1.89	1.5	3.18
4	Circular	0.064	200	2.04	2.75	1
5	Circular	0.029	150	1.64	2	16.68
6	Circular	0.032	150	1.81	2	14.52
7	Circular	0.032	150	1.81	3.25	18.78

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0270\_MSC\_Camden Hostels Camden Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

**Duct system Supply : index run**

System resistance 66.48 N/m<sup>2</sup>  
Total flow rate 0.109 m<sup>3</sup>/s  
Index run to outlet S1  
on floor 0

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0270\_MSC\_Camden Hostels Camden Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Supply duct damper losses - Landlord Supply**

Section	Available pressure	Required pressure	Additional loss required (N/m <sup>2</sup> )	Damper specified
2	22.96	12.78	10.18	Yes
5	19.78	16.68	3.1	Yes
6	18.78	14.52	4.26	Yes
7	18.78	18.78	0	Yes

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0270\_MSC\_Camden Hostels Camden Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Ductwork quantities, supply system : Landlord Supply**

Component type	Description	Size mm	Quantity
Tee	Circular Standard tee	250 : 150 : 250	1
Adaptor	Circular Ceiling diffuser	150	4
Tee	Circular Standard tee	250 : 200 : 150	1
Tee	Circular Standard tee	200 : 150 : 150	1
Bend 90	Circular 1 piece long	250	3
Fitting	Circular Attenuator	250	2
Fitting	Circular Damper	150	5
Bend 90	Circular 1 piece long	150	4
Ductwork	Circular	250	6.50
Ductwork	Circular	150	11.00
Ductwork	Circular	200	2.75



Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0270\_MSC\_Camden Hostels Camden Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

Project no. -  
 Date checked

**Supply duct sizing : Data input - Landlord Supply**

Section no.	Duct type	End fitting	Upstream duct no.	Length (m)	Size limit	Additional loss	Maximum velocity	Fittings
1	Circular	Tee : Std	-	5	250	PD=40	-	3x1LG, 2xATT
2	Circular	Diffuser	1	3.75	150	PD=10	-	DMN, 1LG
3	Circular	Tee : Std	1	1.5	250	-	-	
4	Circular	Tee : Std	3	2.75	200	-	-	
5	Circular	Diffuser	3	2	150	PD=10	-	DMN, 1LG
6	Circular	Diffuser	4	2	150	PD=10	-	DMN, 1LG
7	Circular	Diffuser	4	3.25	150	PD=10	-	2xDMN, 1LG

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0270\_MSC\_Camden Hostels Camden Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Extract duct sizing - Landlord**

Section	Duct type	Flow rate (m³/s)	Size (mm)	Velocity (m/s)	Length (m)	Pressure drop (N/m²)
1	Circular	0.109	250	2.22	7.75	30
2	Circular	0.079	250	1.61	3.25	1.55
3	Circular	0.03	150	1.7	1.5	1.71
4	Circular	0.064	200	2.04	2.25	1.5
5	Circular	0.015	150	0.85	1.5	10.83
6	Circular	0.016	150	0.91	5	12.4
7	Circular	0.014	150	0.79	2	11.41
8	Circular	0.032	150	1.81	9	20.72
9	Circular	0.032	150	1.81	2.25	15.98

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0270\_MSC\_Camden Hostels Camden Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

**Duct system Exhaust : index run**

System resistance	53.78 N/m <sup>2</sup>
Total flow rate	0.109 m <sup>3</sup> /s
Index run to inlet	X1
on floor	0

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0270\_MSC\_Camden Hostels Camden Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Extract duct damper losses - Landlord**

Section	Available pressure	Required pressure	Additional loss required (N/m <sup>2</sup> )	Damper specified
3	23.78	14.11	9.67	No
5	22.23	10.83	11.39	Yes
6	12.4	12.4	0	Yes
7	12.4	11.41	0.99	Yes
8	20.72	20.72	0	Yes
9	20.72	15.98	4.74	Yes

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0270\_MSC\_Camden Hostels Camden Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Ductwork quantities, extract system : Landlord**

Component type	Description	Size mm	Quantity
Tee	Circular Standard tee	250 : 250 : 150	1
Tee	Circular Standard tee	250 : 200 : 150	1
Tee	Circular Standard tee	150 : 150 : 150	1
Tee	Circular Standard tee	200 : 150 : 150	1
Adaptor	Circular Ceiling diffuser	150	5
Fitting	Circular Attenuator	250	2
Bend 90	Circular 1 piece long	250	4
Fitting	Circular Damper	150	6
Bend 90	Circular 1 piece long	150	8
Ductwork	Circular	250	11.00
Ductwork	Circular	150	21.25
Ductwork	Circular	200	2.25

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0270\_MSC\_Camden Hostels Camden Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

Project no. -  
 Date checked

**Supply duct sizing : Data input - Landlord**

Section no.	Duct type	End fitting	Upstream duct no.	Length (m)	Size limit	Additional loss	Maximum velocity	Fittings
1	Circular	Tee : Std	-	7.75	-	PD=25	-	2xATT, 4x1LG
2	Circular	Tee : Std	1	3.25	250	-	-	
3	Circular	Tee : Std	1	1.5	150	-	-	
4	Circular	Tee : Std	2	2.25	-	-	-	
5	Circular	Diffuser	2	1.5	150	PD=10	-	DMN, 1LG
6	Circular	Diffuser	3	5	150	PD=10	-	2x1LG, DMN
7	Circular	Diffuser	3	2	150	PD=10	-	DMN, 1LG
8	Circular	Diffuser	4	9	150	PD=10	-	3x1LG, 2xDMN
9	Circular	Diffuser	4	2.25	150	PD=10	-	DMN, 1LG