



Anderson  
Green

building services consultants

# Ventilation Calculations *For* Camden Hostels, Chester Road

*On behalf of*  
**MORGAN**  
**SINDALL**

DOCUMENT NUMBER: 123007-AGL-CH-XX-CA-M-0001					
REV	DESCRIPTION	CHECKED		STATUS	DATE
		DESIGN	QA		
P01	Stage 4 – Issued for Comment	E Thornton	A Moss	S3	22.02.24

11 United Business Park, Lowfields Road, Leeds, LS12 6UB  
Tel: 0113 243 2672 Visit: [AndersonGreen.co.uk](http://AndersonGreen.co.uk)

Registered in England & Wales No 4309499 VAT reg no 788 9812 47

Project Name	Chester Road
Project No.	LE0271
Title	ESP Calculations.xlsx
Date:	02/11/2023
By	LA
QA'd By	

**External Static Pressure Calculations**

Apartment	Ductwork Pressure Losses (Index Run)	Total Bend Pressure Losses	Attenuator Pressure Loss (Index Run)	Louvre / Air Brick Pressure Loss	Ceiling Grille Pressure Loss	Total ESP	10% Margin
<b>Pressure Loss (Pa)</b>						<b>0.0.0</b>	
Wheelchair Type Apartment	10.9	16.4		8.5	11	48.8	53.7
Studio Type Apartment	8.7	17.5		0	13.3	48.7	53.6
1Bed Type Apartment	8.7	14.75		11	5.5	40.0	44.0
2 Bed (Special) Apartment	14.7	24.25		11	5.5	55.4	60.9
2 Bed Type Apartment	13.7	24.9		15	3.5	57.1	62.8

**Wheelchair Type**

**Index Run - Wheelchair Unit**

Index Run Ductwork Section	Duct Size	Air Flow Rate (l/s)	Duct Length (m)	Pressure Loss / metre (Pa/m)	Pressure Loss (Pa)
Section 1	204x60		11	0.59	0.4
Section 2	204x60		11	2.5	1.0
Section 3	204x60		22	1.5	1.2
Section 4	204x60		22	1.4	1.7
Section 5	204x60		22	0.33	0.4
Section 6	204x60		22	0.35	1.2
Section 7	204x60		22	4.5	5.4
			<b>TOTAL</b>		<b>10.9 Pa</b>

**Bends - Wheelchair Unit**

Bend	Air Flow Rate (l/s)	Pressure Loss (Pa)
1	11	0.5 Pa
T-Piece - 2	22	0.8 Pa
3	22	3.6 Pa
4	22	3.6 Pa
5	22	3.6 Pa
Transition	22	1.2 Pa
Transition	22	1.2 Pa
Spigot 125ø	22	3.9 Pa
<b>TOTAL</b>		<b>18.4 Pa</b>

**Studio Type Apartment**

**Index Run - Studio Apartment**

Index Run Ductwork Section	Duct Size	Air Flow Rate (l/s)	Duct Length (m)	Pressure Loss / metre (Pa/m)	Pressure Loss (Pa)
Section 1	204x60		21	3.5	4.2
Section 2	204x60		21	0.28	0.3
Section 3	204x60		21	0.47	0.6
Section 4	204x60		21	0.47	0.6
Section 5	204x60		21	0.42	0.5
Section 6	204x60		21	2.1	2.5
			<b>TOTAL</b>		<b>8.7 Pa</b>

**Bends - Studio Apartment**

Bend	Air Flow Rate (l/s)	Pressure Loss (Pa)
1	21	3 Pa
2	21	3 Pa
3	21	3 Pa
4	21	3 Pa
Transition	21	1.2 Pa
Transition	21	1.2 Pa
Spigot 125ø	21	3.1 Pa
<b>TOTAL</b>		<b>17.5 Pa</b>

**1 Bed Type Apartment**

Index Run Ductwork Section	Duct Size	Air Flow Rate (l/s)	Duct Length (m)	Pressure Loss / metre (Pa/m)	Pressure Loss (Pa)
Section 1	204x60		13	1.8	0.4
Section 2	204x60		26	4	5.2
Section 3	204x60		26	0.15	0.2
Section 4	204x60		26	0.4	0.5
Section 5	204x60		26	1.6	2.1
			<b>TOTAL</b>		<b>8.7 Pa</b>

**Bends - 1 Bed**

Bend	Air Flow Rate (l/s)	Pressure Loss (Pa)
T-Piece - 1	13	0.4 Pa
2	26	4.5 Pa
3	26	4.5 Pa
Transition	26	1.6 Pa
Transition	26	1.6 Pa
Spigot 125ø	26	2.15 Pa
<b>TOTAL</b>		<b>14.75 Pa</b>

**2 Bed (Special) Type Apartment**

**Index Run - 2 Bed (Special)**

Index Run Ductwork Section	Duct Size	Air Flow Rate (l/s)	Duct Length (m)	Pressure Loss / metre (Pa/m)	Pressure Loss (Pa)
Section 1	204x60		13	4.2	1.7
Section 2	204x60		26	3	3.9
Section 3	204x60		26	1.5	2.0
Section 4	204x60		26	0.45	0.6
Section 5	204x60		26	4	5.2
Section 6	204x60		26	0.45	0.6
Section 7	204x60		26	0.58	0.8
			<b>TOTAL</b>		<b>14.7</b>

**Bends - 2 Bed (Special)**

Bend	Air Flow Rate (l/s)	Pressure Loss (Pa)
T-Piece - 1	13	0.9 Pa
2	26	4.5 Pa
3	26	4.5 Pa
4	26	4.5 Pa
5	26	4.5 Pa
Transition	26	1.6 Pa
Transition	26	1.6 Pa
Spigot 125ø	26	2.15 Pa
<b>TOTAL</b>		<b>24.25 Pa</b>

**2 Bed Type Apartment**

**Index Run - 2 Bed Type Apartment**

Index Run Ductwork Section	Duct Size	Air Flow Rate (l/s)	Duct Length (m)	Pressure Loss / metre (Pa/m)	Pressure Loss (Pa)
Section 1	204x60		10	0.24	0.1
Section 2	204x60		10	2.7	0.8
Section 3	204x60		20	2.5	2.0
Section 4	204x60		30	1.6	4.5
Section 5	204x60		30	0.46	0.7
Section 6	204x60		30	0.59	0.9
Section 7	204x60		30	2.9	4.6
			<b>TOTAL</b>		<b>13.7</b>

**Bends - 2 Bed Type Apartment**

Bend	Air Flow Rate (l/s)	Pressure Loss (Pa)
1	10	0.9 Pa
T Bend - 2	20	0.6 Pa
T Bend - 3	30	5.3 Pa
4	30	6.3 Pa
5	30	6.3 Pa
Transition	30	1.2 Pa
Transition	30	1.2 Pa
Spigot 125ø	30	3.1 Pa
<b>TOTAL</b>		<b>24.9 Pa</b>



**Chester Road  
New Dwelling Ventilation Rates**

Continuous Extract Rates  
Part F Table 1.2

Ref	Kitchen	Bathroom	En-suite	Utility	Total l/s
1 Bed unit	1	1	0	0	21
Studio	1	1	0	0	21
2 Bed unit	1	1	1	0	29
2 Bed Unit G C8-C9	1	1	0	0	21
Wheelchair Unit 1	1	1	0	0	21
Wheelchair Unit 2	1	1	0	0	21

Extract Ventilation rates

Kitchen	13 l/s
Bathroom	8 l/s
En-suite	8 l/s
Utility	8 l/s

**Table 1.2 Minimum extract ventilation rates for continuous extract systems<sup>(1)</sup>**

Room	High rate (l/s)	Continuous rate
Kitchen	13	The sum of all extract ventilation in the dwelling on its continuous rate should be at least the whole dwelling ventilation rate given in Table 1.3
Utility room	8	
Bathroom	8	
Sanitary accommodation	6	

**NOTE:**  
1. If the continuous rate of ventilation provided in a room is equal to or higher than the minimum high rate specified in the table, no extra ventilation is needed.

Whole Dwelling Ventilation Rates  
Part F Table 1.3

Ref	No. of Bedrooms	Total l/s
1 Bed unit	2	25
Studio	1	19
2 Bed unit	2	25
2 Bed Unit G C8-C9	2	25
Wheelchair Unit 1	1	19
Wheelchair Unit 2	1	25

**Table 1.3 Minimum whole dwelling ventilation rates determined by the number of bedrooms**

Number of bedrooms <sup>(1)(2)</sup>	Minimum ventilation rate by number of bedrooms (l/s)
1	19
2	25
3	31
4	37
5	43

**NOTES:**

1. If the dwelling only has one habitable room, a minimum ventilation rate of 13l/s should be used.
2. For each additional bedroom, add 6l/s to the values in Table 1.3.

Minimum Ventilation Rate  
Part F Clause 1.24a

Ref	Area	Total l/s
1 Bed unit	37.35	11
Studio	26.32	8
2 Bed unit	54.48	16
2 Bed Unit G C8-C9	37.86	11
Wheelchair Unit 1	57.44	17
Wheelchair Unit 2	58	17



*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

### Supply duct sizing - Supply

Section	Duct type	Flow rate (m <sup>3</sup> /s)	Size (mm)	Velocity (m/s)	Length (m)	Pressure drop (N/m <sup>2</sup> )
1	Spiral	0.076	200	2.42	7.3	39.72
2	Spiral	0.028	125	2.28	1.55	16.21
3	Spiral	0.048	150	2.72	1.84	6.47
4	Spiral	0.016	100	2.04	0.85	14.76
5	Spiral	0.032	150	1.81	3.53	12.85

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

**Duct system HRU02 : index run**

System resistance 60.96 N/m<sup>2</sup>  
Total flow rate 0.076 m<sup>3</sup>/s  
Index run to outlet S2  
on floor 0

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

### Supply duct damper losses - Supply

Section	Available pressure	Required pressure	Additional loss required (N/m <sup>2</sup> )	Damper specified
2	21.23	16.21	5.02	No
5	14.76	12.85	1.91	No



Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Ductwork quantities, supply system : Supply**

Component type	Description	Size mm	Quantity
Tee	Spiral Standard tee	200 : 125 : 150	1
Adaptor	Spiral Ceiling diffuser	125	1
Tee	Spiral Standard tee	150 : 100 : 150	1
Adaptor	Spiral Ceiling diffuser	100	1
Adaptor	Spiral Ceiling diffuser	150	1
Fitting	Spiral Attenuator	200	3
Bend 89	Spiral 1 piece long	200	2
Bend 90	Spiral 1 piece long	125	1
Bend 90	Spiral 1 piece long	100	1
Bend 53	Spiral 1 piece long	150	1
Bend 90	Spiral 1 piece long	150	1
Ductwork	Spiral	200	7.30
Ductwork	Spiral	125	1.55
Ductwork	Spiral	150	5.36
Ductwork	Spiral	100	0.85

*Project* Data *Session* 0 *Checked by* *Project no.* -  
*Engineer* ET *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

**Supply duct sizing : Data input - Supply**

Section no.	Duct type	End fitting	Upstream duct no.	Length (m)	Size limit	Additional loss	Maximum velocity	Fittings
1	Spiral	Tee : Std	-	7.3	200	PD=35	-	3xATT, 2x1LG
2	Spiral	Diffuser	1	1.55	125	PD=10	-	1LG
3	Spiral	Tee : Std	1	1.84	150	-	-	
4	Spiral	Diffuser	3	0.85	100	PD=10	-	1LG
5	Spiral	Diffuser	3	3.53	150	PD=5	-	2x1LG

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Extract duct sizing - Extract**

Section	Duct type	Flow rate (m <sup>3</sup> /s)	Size (mm)	Velocity (m/s)	Length (m)	Pressure drop (N/m <sup>2</sup> )
1	Spiral	0.079	200	2.51	3.91	37.03
2	Spiral	0.063	200	2.01	6.25	3.51
3	Spiral	0.016	100	2.04	1.09	15.65
4	Spiral	0.048	150	2.72	6.01	7.28
5	Spiral	0.015	100	1.91	0.95	15.47
6	Spiral	0.016	100	2.04	4.26	21.53
7	Spiral	0.032	150	1.81	1.12	15.75

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

**Duct system HRU02 : index run**

System resistance	69.35 N/m <sup>2</sup>
Total flow rate	0.079 m <sup>3</sup> /s
Index run to inlet	X1
on floor	0

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

### Extract duct damper losses - Extract

Section	Available pressure	Required pressure	Additional loss required (N/m <sup>2</sup> )	Damper specified
3	32.32	15.65	16.67	No
5	28.81	15.47	13.34	No
7	21.53	15.75	5.78	No

Project Data Project no. -  
 Engineer ET Session 0 Checked by Date checked  
 File L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

**Ductwork quantities, extract system : Extract**

<b>Component type</b>	<b>Description</b>	<b>Size mm</b>	<b>Quantity</b>
Tee	Spiral Standard tee	200 : 200 : 100	1
Tee	Spiral Standard tee	200 : 150 : 100	1
Adaptor	Spiral Ceiling diffuser	100	3
Tee	Spiral Standard tee	150 : 100 : 150	1
Adaptor	Spiral Ceiling diffuser	150	1
Fitting	Spiral Attenuator	200	3
Bend 96	Spiral 1 piece long	200	1
Bend 89	Spiral 1 piece long	200	1
Bend 90	Spiral 1 piece long	100	3
Bend 93	Spiral 1 piece long	150	1
Bend 89	Spiral 1 piece long	150	1
Bend 77	Spiral 1 piece long	100	1
Bend 90	Spiral 1 piece long	150	1
Ductwork	Spiral	200	10.16
Ductwork	Spiral	100	6.30
Ductwork	Spiral	150	7.14

Project Data Project no. -  
 Engineer ET Session 0 Checked by Date checked  
 File L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

**Supply duct sizing : Data input - Extract**

Section no.	Duct type	End fitting	Upstream duct no.	Length (m)	Size limit	Additional loss	Maximum velocity	Fittings
1	Spiral	Tee : Std	-	3.91	200	PD=35	-	3xATT, 1LG
2	Spiral	Tee : Std	1	6.25	200	-	-	1LG
3	Spiral	Diffuser	1	1.09	100	PD=10	-	1LG
4	Spiral	Tee : Std	2	6.01	150	-	-	2x1LG
5	Spiral	Diffuser	2	0.95	100	PD=10	-	1LG
6	Spiral	Diffuser	4	4.26	100	PD=10	-	2x1LG
7	Spiral	Diffuser	4	1.12	150	PD=10	-	1LG

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

### Supply duct sizing - Supply

Section	Duct type	Flow rate (m <sup>3</sup> /s)	Size (mm)	Velocity (m/s)	Length (m)	Pressure drop (N/m <sup>2</sup> )
1	Spiral	0.056	180	2.2	2.5	41.01
2	Spiral	0.028	125	2.28	3.55	17.01
3	Spiral	0.028	125	2.28	2.49	19.93



*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

**Duct system HRU03 : index run**

System resistance 60.94 N/m<sup>2</sup>  
Total flow rate 0.056 m<sup>3</sup>/s  
Index run to outlet S3  
on floor 0

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

### Supply duct damper losses - Supply

Section	Available pressure	Required pressure	Additional loss required (N/m <sup>2</sup> )	Damper specified
2	19.93	17.01	2.92	No

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

Project no. -  
 Date checked

**Ductwork quantities, supply system : Supply**

<b>Component type</b>	<b>Description</b>	<b>Size mm</b>	<b>Quantity</b>
Tee	Spiral Standard tee	180 : 125 : 125	1
Adaptor	Spiral Ceiling diffuser	125	2
Fitting	Spiral Attenuator	180	3
Bend 93	Spiral 1 piece long	125	1
Bend 90	Spiral 1 piece long	125	2
Bend 97	Spiral 1 piece long	125	1
Ductwork	Spiral	180	2.50
Ductwork	Spiral	125	6.04

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

**Supply duct sizing : Data input - Supply**

Section no.	Duct type	End fitting	Upstream duct no.	Length (m)	Size limit	Additional loss	Maximum velocity	Fittings
1	Spiral	Tee : Std	-	2.5	-	PD=40	-	3xATT
2	Spiral	Diffuser	1	3.55	125	PD=10	-	2x1LG
3	Spiral	Diffuser	1	2.49	125	PD=10	-	2x1LG

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

### Extract duct sizing - Extract

Section	Duct type	Flow rate (m <sup>3</sup> /s)	Size (mm)	Velocity (m/s)	Length (m)	Pressure drop (N/m <sup>2</sup> )
1	Spiral	0.056	180	2.2	2.5	41.01
2	Spiral	0.028	125	2.28	3.36	18.96
3	Spiral	0.028	125	2.28	2.14	18.43

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

**Duct system HRU03 : index run**

System resistance	59.97 N/m <sup>2</sup>
Total flow rate	0.056 m <sup>3</sup> /s
Index run to inlet	X6
on floor	0

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

### Extract duct damper losses - Extract

Section	Available pressure	Required pressure	Additional loss required (N/m <sup>2</sup> )	Damper specified
3	18.96	18.43	0.54	No

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Ductwork quantities, extract system : Extract**


<b>Component type</b>	<b>Description</b>	<b>Size mm</b>	<b>Quantity</b>
Tee	Spiral Standard tee	180 : 125 : 125	1
Adaptor	Spiral Ceiling diffuser	125	2
Fitting	Spiral Attenuator	180	3
Bend 99	Spiral 1 piece long	125	1
Bend 90	Spiral 1 piece long	125	2
Bend 79	Spiral 1 piece long	125	1
Ductwork	Spiral	180	2.50
Ductwork	Spiral	125	5.49



*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

**Supply duct sizing : Data input - Extract**

Section no.	Duct type	End fitting	Upstream duct no.	Length (m)	Size limit	Additional loss	Maximum velocity	Fittings
1	Spiral	Tee : Std	-	2.5	-	PD=40	-	3xATT
2	Spiral	Diffuser	1	3.36	125	PD=10	-	2x1LG
3	Spiral	Diffuser	1	2.14	125	PD=10	-	2x1LG



Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Extract duct sizing - Basement Exhaust**

Section	Duct type	Flow rate (m <sup>3</sup> /s)	Size (mm)	Velocity (m/s)	Length (m)	Pressure drop (N/m <sup>2</sup> )
1	Circular	0.091	224	2.31	7.5	66.58
2	Circular	0.051	250	1.04	3.4	1.88
3	Circular	0.04	150	2.26	1.36	18.28
4	Circular	0.036	140	2.34	2.11	1.96
5	Circular	0.015	100	1.91	2.15	18.52
6	Circular	0.021	100	2.67	9.8	15.94
7	Circular	0.015	100	1.91	1.51	16.31
8	Circular	0.01	100	1.27	3.35	15.2
9	Circular	0.011	100	1.4	1.51	14.55

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

**Duct system Exhaust : index run**

System resistance 101.56 N/m<sup>2</sup>  
Total flow rate 0.091 m<sup>3</sup>/s  
Index run to inlet X5  
on floor 0

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

Project no. -  
 Date checked

**Extract duct damper losses - Basement Exhaust**

Section	Available pressure	Required pressure	Additional loss required (N/m <sup>2</sup> )	Damper specified
3	34.98	18.28	16.7	Yes
5	33.1	18.52	14.59	Yes
7	31.14	16.31	14.82	Yes
8	15.2	15.2	0	Yes
9	15.2	14.55	0.65	Yes

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Ductwork quantities, extract system : Basement Exhaust**

Component type	Description	Size mm	Quantity
Tee	Circular Standard tee	224 : 250 : 150	1
Tee	Circular Standard tee	250 : 140 : 100	1
Adaptor	Circular Ceiling diffuser	150	1
Tee	Circular Standard tee	140 : 100 : 100	1
Adaptor	Circular Ceiling diffuser	100	4
Tee	Circular Standard tee	100 : 100 : 100	1
Fitting	Circular Attenuator	224	2
Bend 87	Circular 1 piece long	224	1
Bend 95	Circular 1 piece long	224	1
Bend 94	Circular 1 piece long	250	1
Fitting	Circular Damper	150	1
Bend 90	Circular 1 piece long	150	1
Fitting	Circular Damper	100	4
Bend 91	Circular 1 piece long	100	1
Bend 90	Circular 1 piece long	100	4
Bend 88	Circular 1 piece long	100	1
Ductwork	Circular	224	7.50
Ductwork	Circular	250	3.40
Ductwork	Circular	150	1.36

Project Data

<b>Component type</b>	<b>Description</b>	<b>Size mm</b>	<b>Quantity</b>
Ductwork	Circular	140	2.11
Ductwork	Circular	100	18.31

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Supply duct sizing : Data input - Basement Exhaust**

Section no.	Duct type	End fitting	Upstream duct no.	Length (m)	Size limit	Additional loss	Maximum velocity	Fittings
1	Circular	Tee : Std	-	7.5	-	PD=63	-	2xATT, 2x1LG
2	Circular	Tee : Std	1	3.4	250	-	-	1LG
3	Circular	Diffuser	1	1.36	150	PD=10	-	DMN, 1LG
4	Circular	Tee : Std	2	2.11	-	-	-	
5	Circular	Diffuser	2	2.15	100	PD=10	-	DMN, 2x1LG
6	Circular	Tee : Std	4	9.8	100	-	-	1LG
7	Circular	Diffuser	4	1.51	100	PD=10	-	DMN, 1LG
8	Circular	Diffuser	6	3.35	100	PD=10	-	DMN, 1LG
9	Circular	Diffuser	6	1.51	100	PD=10	-	DMN, 1LG



*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

### Supply duct sizing - Basement Supply

Section	Duct type	Flow rate (m <sup>3</sup> /s)	Size (mm)	Velocity (m/s)	Length (m)	Pressure drop (N/m <sup>2</sup> )
1	Circular	0.05	200	1.59	3.91	41.48
2	Circular	0.04	125	3.26	1.05	22.76
3	Circular	0.01	125	0.81	7.17	13.22

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

**Duct system FAI : index run**

System resistance 64.24 N/m<sup>2</sup>  
Total flow rate 0.05 m<sup>3</sup>/s  
Index run to outlet S1  
on floor 0

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

### Supply duct damper losses - Basement Supply

Section	Available pressure	Required pressure	Additional loss required (N/m <sup>2</sup> )	Damper specified
2	22.76	22.76	0	Yes
3	22.76	13.22	9.53	Yes

Project Data  
 Engineer ET Session 0 Checked by  
 File L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\ Project no. -  
 Date checked

**Ductwork quantities, supply system : Basement Supply**

Component type	Description	Size mm	Quantity
Tee	Circular Standard tee	200 : 125 : 125	1
Adaptor	Circular Ceiling diffuser	125	2
Fitting	Circular Attenuator	200	2
Bend 84	Circular 1 piece long	200	1
Bend 81	Circular 1 piece long	200	1
Fitting	Circular Damper	125	2
Bend 90	Circular 1 piece long	125	2
Bend 93	Circular 1 piece long	125	1
Ductwork	Circular	200	3.91
Ductwork	Circular	125	8.22

*Project* Data *Project no.* -  
*Engineer* ET *Session* 0 *Checked by* *Date checked*  
*File* L:\2023\LE0271\_MSC\_Camden Hostels Chester Road\09 Mechanical\01 Calcs\G - Hevacomp & IES\

---

**Supply duct sizing : Data input - Basement Supply**

Section no.	Duct type	End fitting	Upstream duct no.	Length (m)	Size limit	Additional loss	Maximum velocity	Fittings
1	Circular	Tee : Std	-	3.91	200	PD=40	-	2xATT, 2x1LG
2	Circular	Diffuser	1	1.05	125	PD=10	-	DMN, 1LG
3	Circular	Diffuser	1	7.17	125	PD=10	-	2x1LG, DMN