


Block Compliance



Block Reference	08580 Acorn House No PV	Issued on Date	24/04/2024
Block Name	08580 Acorn House		
Calculation Type	New Build (As Designed)		

Assessor Details	Mr. William O'Reilly	Assessor ID	K347-0001
Client			

Block Compliance Report - DER

Block Reference: 08580 Acorn House No PV		Block Name: 08580 Acorn House		
Property-Assessment Reference	Floor area (m ²)	DER (kgCO ₂ /m ²)	TER (kgCO ₂ /m ²)	% DER/TER
1.1 Type C - 1.1 Type C?_Copy_Copy	70.00	4.52	9.85	54.11 %
1.2 Type E - 1.2 Type E_Copy_Copy	95.00	3.93	7.92	50.38 %
1.3 Type A - 1.3 Type A_Copy_Copy	39.00	3.57	9.67	63.08 %
1.4 Type D2 - 1.4 Type D2_Copy_Copy	71.00	4.15	9.87	57.95 %
1.5 Type B2 - 1.5 Type B2_Copy_Copy	54.00	3.72	9.00	58.67 %
2.1 Type C - 2.1 Type C_Copy_Copy	70.00	3.49	10.84	67.80 %
2.2 Type E - 2.2 Type E_Copy_Copy	95.00	2.90	9.03	67.88 %
2.3 Type A - 2.3 Type A_Copy_Copy	39.00	2.55	11.06	76.94 %
2.4 Type D - 2.4 Type D_Copy_Copy	71.00	3.10	10.89	71.53 %
2.5 Type B1 - 2.5 Type B1_Copy_Copy	54.00	2.67	10.20	73.82 %
3.1 Type C - 3.1 Type C_Copy_Copy	71.00	3.45	12.05	71.37 %
3.2 Type E - 3.2 Type E_Copy_Copy	95.00	2.89	10.09	71.36 %
3.3 Type A - 3.3 Type A_Copy_Copy	39.00	2.55	12.13	78.98 %
3.4 Type D - 3.4 Type D_Copy_Copy	71.00	3.09	11.94	74.12 %
3.5 Type B1 - 3.5 Type B1_Copy_Copy	55.00	2.64	11.12	76.26 %
4.1 Type C - 4.1 Type C_Copy_Copy	71.00	3.45	12.59	72.60 %
4.2 Type E - 4.2 Type E_Copy_Copy	95.00	2.89	10.63	72.81 %
4.3 Type A - 4.3 Type A_Copy_Copy	39.00	2.55	12.66	79.86 %
4.4 Type D1 - 4.4 Type D1_Copy_Copy	71.00	3.09	12.47	75.22 %
4.5 Type B1 - 4.5 Type B1_Copy_Copy	55.00	2.64	11.65	77.34 %
5.1 Type F - 5.1 Type F_Copy_Copy	91.00	3.21	12.02	73.29 %
5.2 Type G - 5.2 Type G_Copy_Copy	121.00	2.58	9.50	72.84 %

Block Compliance




5.3 Type D2 - 5.3 Type D2_Copy_Copy	71.00	3.09	12.79	75.84 %
5.4 Type B1 - 5.4 Type B1_Copy_Copy	55.00	2.64	11.97	77.94 %
6.1 Type C - 6.1 Type C_Copy_Copy	71.00	3.45	13.12	73.70 %
6.2 Type B1 - 6.2 Type B1_Copy_Copy	55.00	2.64	12.18	78.33 %
6.3 Type D1 - 6.3 Type D1_Copy_Copy	71.00	3.09	13.00	76.23 %
7.1 Type C - 7.1 Type C_Copy_Copy	71.00	3.45	13.27	74.00 %
7.2 Type B1 - 7.2 Type B1_Copy_Copy	55.00	2.64	12.34	78.61 %
7.3 Type D - 7.3 Type D_Copy_Copy	71.00	3.09	13.15	76.50 %
8.1 Type C - 8.1 Type C_Copy_Copy	71.00	4.25	15.32	72.26 %
8.2 Type B1 - 8.2 Type B1_Copy_Copy	55.00	3.50	14.43	75.74 %
8.3 Type D - 8.3 Type D_Copy_Copy	71.00	3.90	15.17	74.29 %
Totals:	2249.00	105.37	383.92	
Average DER = 3.22 kgCO ₂ /m ²	% DER/TER	PASS		
Average TER = 11.51 kgCO ₂ /m ²	72.06 %			

Block Compliance Report - DFEE


Block Reference: 08580 Acorn House No PV		Block Name: 08580 Acorn House		
Property-Assessment Reference	Floor area (m ²)	DFEE (kWh/m ² /yr)	TFEE (kWh/m ² /yr)	% DFEE/TFEE
1.1 Type C - 1.1 Type C?_Copy_Copy	70.00	64.22	41.71	-53.98 %
1.2 Type E - 1.2 Type E_Copy_Copy	95.00	58.96	39.10	-50.77 %
1.3 Type A - 1.3 Type A_Copy_Copy	39.00	43.03	26.40	-62.99 %
1.4 Type D2 - 1.4 Type D2_Copy_Copy	71.00	60.93	42.27	-44.15 %
1.5 Type B2 - 1.5 Type B2_Copy_Copy	54.00	49.52	32.73	-51.31 %
2.1 Type C - 2.1 Type C_Copy_Copy	70.00	44.09	32.11	-37.32 %
2.2 Type E - 2.2 Type E_Copy_Copy	95.00	38.72	30.05	-28.86 %
2.3 Type A - 2.3 Type A_Copy_Copy	39.00	22.29	18.08	-23.26 %
2.4 Type D - 2.4 Type D_Copy_Copy	71.00	40.20	32.80	-22.54 %

Block Compliance



2.5 Type B1 - 2.5 Type B1_Copy_Copy	54.00	28.66	23.89	-19.98 %
3.1 Type C - 3.1 Type C_Copy_Copy	71.00	44.14	33.07	-33.49 %
3.2 Type E - 3.2 Type E_Copy_Copy	95.00	38.57	30.07	-28.26 %
3.3 Type A - 3.3 Type A_Copy_Copy	39.00	22.29	18.08	-23.26 %
3.4 Type D - 3.4 Type D_Copy_Copy	71.00	39.99	32.61	-22.61 %
3.5 Type B1 - 3.5 Type B1_Copy_Copy	55.00	28.15	23.52	-19.66 %
4.1 Type C - 4.1 Type C_Copy_Copy	71.00	44.14	33.07	-33.49 %
4.2 Type E - 4.2 Type E_Copy_Copy	95.00	38.57	30.07	-28.26 %
4.3 Type A - 4.3 Type A_Copy_Copy	39.00	22.29	18.08	-23.26 %
4.4 Type D1 - 4.4 Type D1_Copy_Copy	71.00	39.99	32.61	-22.61 %
4.5 Type B1 - 4.5 Type B1_Copy_Copy	55.00	28.15	23.52	-19.66 %
5.1 Type F - 5.1 Type F_Copy_Copy	91.00	44.79	34.00	-31.72 %
5.2 Type G - 5.2 Type G_Copy_Copy	121.00	35.08	27.94	-25.59 %
5.3 Type D2 - 5.3 Type D2_Copy_Copy	71.00	39.99	32.61	-22.61 %
5.4 Type B1 - 5.4 Type B1_Copy_Copy	55.00	28.15	23.52	-19.66 %
6.1 Type C - 6.1 Type C_Copy_Copy	71.00	44.14	33.07	-33.49 %
6.2 Type B1 - 6.2 Type B1_Copy_Copy	55.00	28.15	23.52	-19.66 %
6.3 Type D1 - 6.3 Type D1_Copy_Copy	71.00	39.99	32.61	-22.61 %
7.1 Type C - 7.1 Type C_Copy_Copy	71.00	44.14	33.07	-33.49 %
7.2 Type B1 - 7.2 Type B1_Copy_Copy	55.00	28.15	23.52	-19.66 %
7.3 Type D - 7.3 Type D_Copy_Copy	71.00	39.99	32.61	-22.61 %
8.1 Type C - 8.1 Type C_Copy_Copy	71.00	59.55	41.49	-43.50 %
8.2 Type B1 - 8.2 Type B1_Copy_Copy	55.00	44.97	32.04	-40.36 %

Block Compliance



8.3 Type D - 8.3 Type D_Copy_Copy	71.00	55.61	40.92	-35.87 %
Totals:	2249.00	1329.55	1004.78	
Average DFEE = 41.49 kgCO ₂ /m ²	% DFEE/TFEE		FAIL	
Average TFEE = 31.35 kgCO ₂ /m ²	-32.35 %			

Block Compliance Report - DPER

Block Reference: 08580 Acorn House No PV	Block Name: 08580 Acorn House			
Property-Assessment Reference	Floor area (m ²)	DPER (kWh/m ² /yr)	TPER (kWh/m ² /yr)	% DPER/TPER
1.1 Type C - 1.1 Type C?_Copy_Copy	70.00	46.88	52.99	11.53 %
1.2 Type E - 1.2 Type E_Copy_Copy	95.00	40.64	42.94	5.36 %
1.3 Type A - 1.3 Type A_Copy_Copy	39.00	37.31	52.07	28.35 %
1.4 Type D2 - 1.4 Type D2_Copy_Copy	71.00	43.04	53.15	19.02 %
1.5 Type B2 - 1.5 Type B2_Copy_Copy	54.00	38.73	48.42	20.01 %
2.1 Type C - 2.1 Type C_Copy_Copy	70.00	36.35	56.85	36.06 %
2.2 Type E - 2.2 Type E_Copy_Copy	95.00	30.12	47.03	35.96 %
2.3 Type A - 2.3 Type A_Copy_Copy	39.00	26.98	58.72	54.05 %
2.4 Type D - 2.4 Type D_Copy_Copy	71.00	32.29	57.14	43.49 %
2.5 Type B1 - 2.5 Type B1_Copy_Copy	54.00	28.00	53.62	47.78 %
3.1 Type C - 3.1 Type C_Copy_Copy	71.00	35.92	63.74	43.65 %
3.2 Type E - 3.2 Type E_Copy_Copy	95.00	30.05	53.00	43.30 %
3.3 Type A - 3.3 Type A_Copy_Copy	39.00	26.98	65.05	58.52 %
3.4 Type D - 3.4 Type D_Copy_Copy	71.00	32.20	63.12	48.99 %
3.5 Type B1 - 3.5 Type B1_Copy_Copy	55.00	27.69	59.03	53.09 %
4.1 Type C - 4.1 Type C_Copy_Copy	71.00	35.92	67.08	46.45 %
4.2 Type E - 4.2 Type E_Copy_Copy	95.00	30.05	56.25	46.58 %
4.3 Type A - 4.3 Type A_Copy_Copy	39.00	26.98	68.51	60.62 %
4.4 Type D1 - 4.4 Type D1_Copy_Copy	71.00	32.20	66.46	51.55 %
4.5 Type B1 - 4.5 Type B1_Copy_Copy	55.00	27.69	62.41	55.63 %
5.1 Type F - 5.1 Type F_Copy_Copy	91.00	33.28	64.14	48.11 %

Block Compliance



5.2 Type G - 5.2 Type G_Copy_Copy	121.00	26.83	50.39	46.76 %
5.3 Type D2 - 5.3 Type D2_Copy_Copy	71.00	32.20	68.59	53.05 %
5.4 Type B1 - 5.4 Type B1_Copy_Copy	55.00	27.69	64.57	57.12 %
6.1 Type C - 6.1 Type C_Copy_Copy	71.00	35.92	70.69	49.19 %
6.2 Type B1 - 6.2 Type B1_Copy_Copy	55.00	27.69	66.07	58.09 %
6.3 Type D1 - 6.3 Type D1_Copy_Copy	71.00	32.20	70.07	54.05 %
7.1 Type C - 7.1 Type C_Copy_Copy	71.00	35.92	71.79	49.97 %
7.2 Type B1 - 7.2 Type B1_Copy_Copy	55.00	27.69	67.18	58.78 %
7.3 Type D - 7.3 Type D_Copy_Copy	71.00	32.20	71.17	54.76 %
8.1 Type C - 8.1 Type C_Copy_Copy	71.00	44.18	83.04	46.80 %
8.2 Type B1 - 8.2 Type B1_Copy_Copy	55.00	36.54	78.66	53.55 %
8.3 Type D - 8.3 Type D_Copy_Copy	71.00	40.56	82.26	50.69 %
Totals:	2249.00	1098.92	2056.20	
Average DPER = 33.51 kgCO ₂ /m ²	% DPER/TPER	PASS		
Average TPER = 61.60 kgCO ₂ /m ²	45.60 %			