



LEGEND:

	RECTANGULAR DUCTWORK (AT ALL LEVELS)
	FIRE DAMPER
	FLEXIBLE CONNECTION

- NOTES:**
- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER M&E SERVICES DRAWINGS, TOGETHER WITH THE ARCHITECTS & STRUCTURAL DRAWINGS AND ASSOCIATED SPECIFICATIONS.
 - ALL SERVICES PASSING THROUGH FIRE COMPARTMENT WALLS WILL BE IN ACCORDANCE WITH THE RELEVANT SPECIFICATION & BRITISH STANDARDS.
 - FLEXIBLE DUCTWORK LENGTHS SHALL NOT EXCEED 500mm AND SHALL NOT BE USED FOR CHANGES OF DIRECTION.
 - THE RESPONSIBILITY FOR THE SUPPORT OF THE ENTIRE DUCTWORK SYSTEMS AND ASSOCIATED PLANT SHALL BE THAT OF THE MECHANICAL CONTRACTOR.

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION

NO SIGNIFICANT RISK WHICH REQUIRES TO BE COMMUNICATED TO A COMPETENT CONTRACTOR HAS BEEN IDENTIFIED IN RELATION TO THIS DRAWING.

THESE NOTES ARE BASED ON THE USE OF EXPERIENCED AND COMPETENT CONTRACTORS CARRYING OUT THE WORK USING AN APPROVED SAFE METHOD OF WORKING.

No.	Description	Origin	Drawn	Checked	Date
T2	TENDER ISSUE	J.I.	J.I.	J.I.	31/05/24
T1	TENDER ISSUE	J.I.	J.I.	J.I.	09/02/24

Revisions:

Approval Process:

Checked by: _____ Date: _____

A - Approved
 B - Approved with comments
 C - Retained with comments & re-submit
 D - Do not use



Drawing Status:

TENDER ISSUE

Client:
KK4 LTD

Project Title:
BIRD IN HAND WEST END LANE NW6 4NX

Drawing Title:
VENTILATION LAYOUT BASEMENT LEVEL

Scale @ A0:	Originator:	Drawn by:	Checked:
1:50	J.I.	J.I.	J.I.
Project No.:	Date:		
IP23040	JAN 24		
Drawing No.:	Revision:		
IP23040-L-M-210	T2		

DO NOT SCALE FROM THIS DRAWING
 ALL DIMENSIONS TO BE CONFIRMED ON SITE