



**LEGEND:**

RECTANGULAR DUCTWORK (AT ALL LEVELS)

FIRE DAMPER

FLEXIBLE CONNECTION

**NOTES:**

- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER M&E SERVICES DRAWINGS, TOGETHER WITH THE ARCHITECTS & STRUCTURAL DRAWINGS AND ASSOCIATED SPECIFICATIONS.
- ALL SERVICES PASSING THROUGH FIRE COMPARTMENT WALLS WILL BE IN ACCORDANCE WITH THE RELEVANT SPECIFICATION & BRITISH STANDARDS.
- FLEXIBLE DUCTWORK LENGTHS SHALL NOT EXCEED 500mm AND SHALL NOT BE USED FOR CHANGES OF DIRECTION.
- THE RESPONSIBILITY FOR THE SUPPORT OF THE ENTIRE DUCTWORK SYSTEM(S) AND ASSOCIATED PLANT SHALL BE THAT OF THE MECHANICAL CONTRACTOR.

**SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION**

NO SIGNIFICANT RISK WHICH REQUIRES TO BE COMMUNICATED TO A COMPETENT CONTRACTOR HAS BEEN IDENTIFIED IN RELATION TO THIS DRAWING.

THESE NOTES ARE BASED ON THE USE OF EXPERIENCED AND COMPETENT CONTRACTORS CARRYING OUT THE WORK USING AN APPROVED SAFE METHOD OF WORKING.

|  |              |        |       |       |          |
|--|--------------|--------|-------|-------|----------|
| T2                                     | TENDER ISSUE | J.I.   | J.I.  | J.I.  | 31/05/24 |
| T1                                     | TENDER ISSUE | J.I.   | J.I.  | J.I.  | 09/02/24 |
| No.                                    | Description  | Orig'n | Drawn | Chk'd | Date     |
| Revisions:                             |              |        |       |       |          |
| Approval Process:                      |              |        |       |       |          |
| Checked by:                            |              | Date:  |       |       |          |
| A - Approved                           |              |        |       |       |          |
| B - Approved with comments             |              |        |       |       |          |
| C - Rejected with comments & re-submit |              |        |       |       |          |
| D - Do not use                         |              |        |       |       |          |

**IRVINEERING**

Building Services & Built Environment Consulting Engineers

www.irvineering.co.uk | 02038163172

Drawing Status:

**TENDER ISSUE**

Client:

**KK4 LTD**

Project Title:

**BIRD IN HAND WEST END LANE NW6 4NX**

Drawing Title:

**VENTILATION LAYOUT FIRST FLOOR**

|                 |             |           |           |
|-----------------|-------------|-----------|-----------|
| Scale @ A0:     | Originator: | Drawn by: | Checked:  |
| 1:50            | J.I.        | J.I.      | J.I.      |
| Project No:     |             |           | Date:     |
| IP23040         |             |           | JAN 24    |
| Drawing No:     |             |           | Revision: |
| IP23040-L-M-212 |             |           | T2        |

DO NOT SCALE FROM THIS DRAWING  
ALL DIMENSIONS TO BE CONFIRMED ON SITE