


- PROPOSED VMO2 1No. ANTENNA TO BE INSTALLED ON MAIN POLE FIXED TO SCREEN STEELWORK
- PROPOSED VMO2 5No. RRU UNITS TO BE INSTALLED ON OFFSET BRACKETS FIXED TO SCREEN STEELWORK
- PROPOSED VMO2 1No. ANTENNA TO BE INSTALLED ON OFFSET BRACKETS WITH SUPPORT POLE FIXED TO MAIN POLE ON SCREEN STEELWORK
- PROPOSED VMO2 1No. ANTENNA TO BE INSTALLED ON MAIN POLE FIXED TO SCREEN STEELWORK
- PROPOSED 300mm WIDE CABLE TRAY TO BE INSTALLED ON SCREEN STEELWORK
- PROPOSED VF 1No. PSC CABINET TO BE INSTALLED ON CABINET GRILLAGE
- PROPOSED VF 1No. FOOTPRINT FOR HYBRID ERS RACK TO BE INSTALLED ON CABINET GRILLAGE FOR FUTURE USE
- PROPOSED VMO2 1No. ELTEK PSU CABINET TO BE INSTALLED ON CABINET GRILLAGE
- PROPOSED VMO2 2No. PFF RACK TO BE INSTALLED ON CABINET GRILLAGE
- PROPOSED VF/VMO2 300mm WIDE CABLE TRAY TO BE INSTALLED ON ROOF USING RUBBER BLOCKS
- EXISTING HORIZONTAL LADDER
- PROPOSED VF/VMO2 AC DISTRIBUTION BOARD TO BE INSTALLED ON GRILLAGE
- EXISTING HVAC EQUIPMENT
- EXISTING HVAC DUCT
- PROPOSED VF 1No. ANTENNA TO BE INSTALLED ON MAIN POLE FIXED TO SCREEN STEELWORK
- PROPOSED VF 1No. ANTENNA TO BE INSTALLED ON OFFSET BRACKETS WITH SUPPORT POLE FIXED TO MAIN POLE ON SCREEN STEELWORK
- PROPOSED VF 5No. ERS UNITS TO BE INSTALLED ON OFFSET BRACKETS WITH SUPPORT POLE FIXED TO MAIN POLE ON SCREEN STEELWORK
- PROPOSED VF 1No. ANTENNA TO BE INSTALLED ON MAIN POLE FIXED TO SCREEN STEELWORK

ALL DIMENSIONS ARE IN mm UNLESS NOTED OTHERWISE

N.G.R | E: 529574 N: 183820

NOTES:

REV	MODIFICATION	BY	CH	DATE
A	Issued for Construction	ASE	FD	22.03.24



Cell Name		Opt.
TRIBECA – THE APEX		A
Cell ID No		
CORNERSTONE	VF	VMO2
305482_00	20207	95827

Site Address / Contact Details
 2-6 ST PANCRAS WAY
 CAMDEN
 NW1 0TB

Drawing Title:		PROPOSED SITE PLAN	
Purpose of Issue:		CONSTRUCTION	
Drawing Number:		201	
Surveyed By:	FD	Original Sheet Size:	A3
Drawn:	ASE	Checked:	FD
Date:	22.03.24	Date:	22.03.24
Pack Issue:		A	

These drawings comply with VF & VMO2 Standard ICNIRP guidelines, under configuration VM7F
 Designed in accordance with Cornerstone documents: SDN0007 & SDN0009 v6.0

PROPOSED SITE PLAN
 (1:200)

