

## Part G Water Calculation

House 1, 95 Avenue Road, London, NW8 6HY

Total Water Consumption for 17.K Compliance Building Regulations Part G:

**109.32** litres per person per day

**This dwelling is within the target maximum of potable water (125 Litres per person per day)**

Installation Type	Unit of Measure	Capacity/ Flow Rate	Use Factor	Fixed Use	Litres/Pers on/Day
<b>WC's</b> (single Flush)	Flush Volume (litres)	0.00	4.42	0.00	0.00
<b>WC's</b> (Dual Flush)	(Full Flush)	6.00	1.46	0.00	8.76
	(Part Flush)	3.00	2.96	0.00	8.88
<b>Taps</b> (excl. kitchen/utility room)	Flow rate (litres / minute)	6.00	1.58	1.58	11.06
<b>Bath (Shower Present)</b>	Capacity to overflow (litres)	0.00	0.11	0.00	0.00
<b>Shower Only</b>	Flow rate (litres / minute)	9.00	5.60	0.00	50.40
<b>Kitchen/Utility Taps</b>	Flow rate (litres / minute)	8.00	0.44	10.36	13.88
<b>Washing Machine*</b>	Litres / kg dry load	8.17	2.10	0.00	17.16
<b>Dishwasher</b>	Litres / place setting	1.25	3.60	0.00	4.50
<b>Waste Disposal Unit*</b>	Litres / use	0.00	3.08	0.00	0.00
<b>Water Softener*</b>	Litres / person / day	0.00	1.00	0.00	0.00
<b>Contribution from Grey Water</b>					N/A
<b>Contribution from Rain Water</b>					N/A

\*Not specified, so default values used

<b>Calculated Water Usage</b>	114.637
<b>Normalisation Factor</b>	$\Sigma \times 0.91$
<b>External Water Usage</b>	5
<b>Total Part G Water Consumption</b>	<b>109.32</b>

**Usage is less than 110 l/p/d, dwelling is compliant With London Plan Policy SI 5**

The specification above has been based on fittings installed by the developer

Where sanitaryware is unknown an appropriate value has been used, flow rates will be achieved by installing restrictors in the pipework