

Full SAP Calculation Printout



Property Reference	Plot 1		Issued on Date	21/12/2023	
Assessment Reference	Plot 1 Be Green	Prop Type Ref	Plot 1 Be Green		
Property	Plot 1, 95, Avenue Road, London, NW8 6HY				
SAP Rating	53 E	DER	9.64	TER	11.18
Environmental	90 B	% DER < TER			13.77
CO ₂ Emissions (t/year)	1.28	DFEE	88.51	TFEE	50.08
Compliance Check	See BREL	% DFEE < TFEE			-76.75
% DPER < TPER	-69.20	DPER	99.67	TPER	58.91
Assessor Details	Mr. Graham Suttill			Assessor ID	P035-0001
Client	Carnell Warren Associates Ltd, Wendy Warren				

SAP 10 WORKSHEET FOR New Build (As Designed) (Version 10.2, February 2022)
 CALCULATION OF DWELLING EMISSIONS FOR REGULATIONS COMPLIANCE

1. Overall dwelling characteristics

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	83.9900 (1b)	x 2.8000 (2b)	= 235.1720 (1b) - (3b)
First floor	71.7100 (1c)	x 3.2200 (2c)	= 230.9062 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	155.7000		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n) =	466.0782 (5)

2. Ventilation rate

	m ³ per hour
Number of open chimneys	0 * 80 = 0.0000 (6a)
Number of open flues	0 * 20 = 0.0000 (6b)
Number of chimneys / flues attached to closed fire	0 * 10 = 0.0000 (6c)
Number of flues attached to solid fuel boiler	0 * 20 = 0.0000 (6d)
Number of flues attached to other heater	0 * 35 = 0.0000 (6e)
Number of blocked chimneys	0 * 20 = 0.0000 (6f)
Number of intermittent extract fans	0 * 10 = 0.0000 (7a)
Number of passive vents	0 * 10 = 0.0000 (7b)
Number of flueless gas fires	0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(6c)+(6d)+(6e)+(6f)+(6g)+(7a)+(7b)+(7c) =	0.0000 / (5) = 0.0000 (8)
Pressure test	Yes
Pressure Test Method	Blower Door
Measured/design AP50	6.0000 (17)
Infiltration rate	0.3000 (18)
Number of sides sheltered	3 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] = 0.7750 (20)
Infiltration rate adjusted to include shelter factor	(21) = (18) x (20) = 0.2325 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.2964	0.2906	0.2848	0.2557	0.2499	0.2209	0.2209	0.2151	0.2325	0.2499	0.2616	0.2732 (22b)
Balanced mechanical ventilation with heat recovery												
If mechanical ventilation												0.5000 (23a)
If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)), otherwise (23b) = (23a)												0.5000 (23b)
If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =												75.6000 (23c)
Effective ac	0.4184	0.4126	0.4068	0.3777	0.3719	0.3429	0.3429	0.3371	0.3545	0.3719	0.3836	0.3952 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Entrance Door			2.8800	1.4000	4.0320		(26)
Windows (Uw = 1.40)			31.7400	1.3258	42.0795		(27)
Glazed Doors (Uw = 1.40)			6.0200	1.3258	7.9811		(27)
Glazed Wall (Uw = 1.40)			27.6900	1.3258	36.7102		(27)
GF RL			4.1000	1.2357	5.0665		(27a)
1F RL			7.1700	1.2357	8.8603		(27a)
Basement Floor			83.9900	0.2500	20.9975	110.0000	9238.9000 (28)
Retaining Wall	69.0000		69.0000	0.3000	20.7000	9.0000	621.0000 (29a)
Existing External Wall	59.0100		59.0100	0.3000	17.7030	9.0000	531.0900 (29a)
New External Wall	94.0100	68.3300	25.6800	0.1800	4.6224	150.0000	3852.0000 (29a)
Flat Roof GF	12.3600	4.1000	8.2600	0.1500	1.2390	9.0000	74.3400 (30)
Flat Roof First Floor	71.7100	7.1700	64.5400	0.1500	9.6810	9.0000	580.8600 (30)
Total net area of external elements Aum(A, m ²)			390.0800				(31)
Fabric heat loss, W/K = Sum (A x U)					(26)...(30) + (32) =	179.6725	(33)

Full SAP Calculation Printout



Party Wall 1	54.5700	0.0000	0.0000	70.0000	3819.9000 (32)
Internal Wall 1	235.2600			75.0000	17644.5000 (32c)
Internal Floor 1	70.4800			18.0000	1268.6400 (32d)
Internal Ceiling 1	70.4800			9.0000	634.3200 (32e)

Heat capacity Cm = Sum(A x k)
 Thermal mass parameter (TMP = Cm / TFA) in kJ/m2K (28)...(30) + (32) + (32a)...(32e) = 38265.5500 (34)
 Thermal bridges (Default value 0.200 * total exposed area) 245.7646 (35)
 Point Thermal bridges 78.0160 (36)
 Total fabric heat loss (33) + (36) + (36a) = 257.6885 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

(38)m	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Heat transfer coeff	64.3581	63.4641	62.5701	58.1001	57.2061	52.7362	52.7362	51.8422	54.5242	57.2061	58.9941	60.7821 (38)
Average = Sum(39)m / 12 =	322.0467	321.1527	320.2587	315.7887	314.8947	310.4247	310.4247	309.5307	312.2127	314.8947	316.6827	318.4707 (39)

HLP (average)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP (average)	2.0684	2.0626	2.0569	2.0282	2.0224	1.9937	1.9937	1.9880	2.0052	2.0224	2.0339	2.0454 (40)
Days in mont	31	28	31	30	31	30	31	31	30	31	30	31

4. Water heating energy requirements (kWh/year)

Assumed occupancy 2.9428 (42)

Hot water usage for mixer showers 82.7553 81.5117 79.6994 76.2320 73.6732 70.8196 69.1976 70.9961 72.9676 76.0315 79.5734 82.4383 (42a)

Hot water usage for baths 31.7566 31.2849 30.6208 29.3962 28.4792 27.4625 26.9133 27.5728 28.2909 29.3788 30.6286 31.6492 (42b)

Hot water usage for other uses 44.7668 43.1389 41.5111 39.8832 38.2553 36.6274 36.6274 38.2553 39.8832 41.5111 43.1389 44.7668 (42c)

Average daily hot water use (litres/day) 146.4381 (43)

Daily hot water use

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Energy conte	159.2787	155.9356	151.8313	145.5114	140.4077	134.9095	132.7383	136.8242	141.1417	146.9215	153.3410	158.8543 (44)
Energy content (annual)	252.2586	222.0502	233.3590	199.1979	189.0158	165.8869	160.5355	169.4169	174.0418	199.3710	218.4624	248.7275 (45)
Distribution loss (46)m = 0.15 x (45)m	37.8388	33.3075	35.0039	29.8797	28.3524	24.8830	24.0803	25.4125	26.1063	29.9057	32.7694	37.3091 (46)
Water storage loss:												300.0000 (47)
Store volume												1.8000 (48)
a) If manufacturer declared loss factor is known (kWh/day):												0.6000 (49)
Temperature factor from Table 2b												1.0800 (55)
Enter (49) or (54) in (55)												1.0800 (55)
Total storage loss	33.4800	30.2400	33.4800	32.4000	33.4800	32.4000	33.4800	33.4800	32.4000	33.4800	32.4000	33.4800 (56)
If cylinder contains dedicated solar storage	33.4800	30.2400	33.4800	32.4000	33.4800	32.4000	33.4800	33.4800	32.4000	33.4800	32.4000	33.4800 (57)
Primary loss	23.2624	21.0112	23.2624	22.5120	23.2624	22.5120	23.2624	23.2624	22.5120	23.2624	22.5120	23.2624 (59)
Combi loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (61)
Total heat required for water heating calculated for each month	309.0010	273.3014	290.1014	254.1099	245.7582	220.7989	217.2779	226.1593	228.9538	256.1134	273.3744	305.4699 (62)
WWHRS	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63a)
PV diverter	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63b)
Solar input	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63c)
FGHRS	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63d)
Output from w/h	309.0010	273.3014	290.1014	254.1099	245.7582	220.7989	217.2779	226.1593	228.9538	256.1134	273.3744	305.4699 (64)
Total per year (kWh/year)												3100.4195 (64)
Electric shower(s)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (64a)
Total Energy used by instantaneous electric shower(s) (kWh/year) = Sum(64a)m =												0.0000 (64a)
Heat gains from water heating, kWh/month	102.4859	90.6406	96.2018	84.2429	81.4577	73.1670	71.9880	74.9411	75.8785	84.9008	90.6483	101.3118 (65)

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts

(66)m	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381 (66)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	164.7608	182.4137	164.7608	170.2528	164.7608	170.2528	164.7608	164.7608	170.2528	164.7608	170.2528	164.7608 (67)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	326.6567	330.0464	321.5045	303.3199	280.3650	258.7907	244.3778	240.9881	249.5300	267.7146	290.6694	312.2437 (68)
Pumps, fans	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138 (69)
Losses e.g. evaporation (negative values) (Table 5)	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000 (70)
Water heating gains (Table 5)	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105 (71)
Total internal gains	137.7499	134.8819	129.3035	117.0040	109.4861	101.6208	96.7580	100.7272	105.3868	114.1140	125.9005	136.1718 (72)
Total internal gains	699.3088	717.4834	685.7102	660.7181	624.7534	597.8058	573.0380	573.6175	592.3110	616.7308	656.9642	683.3177 (73)

6. Solar gains

[Jan]	Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d	Gains W
East	17.3900	19.6403	0.4000	0.7000	0.5400	46.4773 (76)
South	7.8500	46.7521	0.4000	0.7000	0.5400	49.9419 (78)
West	6.5000	19.6403	0.4000	0.7000	0.5400	17.3722 (80)
South	6.0200	46.7521	0.4000	0.7000	0.5400	38.2994 (78)
South	20.2300	46.7521	0.4000	0.7000	0.5400	128.7037 (78)
West	7.4600	19.6403	0.4000	0.7000	0.5400	19.9379 (80)
East	7.1700	26.0000	0.4000	0.7000	1.0000	46.9778 (82)
West	4.1000	26.0000	0.4000	0.7000	1.0000	26.8632 (82)

Full SAP Calculation Printout



Solar gains	374.5734	672.5681	995.1628	1331.2066	1560.7929	1574.8755	1508.1812	1336.5287	1113.3270	765.1553	455.3482	316.0040 (83)
Total gains	1073.8822	1390.0516	1680.8731	1991.9248	2185.5462	2172.6813	2081.2192	1910.1462	1705.6380	1381.8861	1112.3123	999.3217 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
tau	33.0055	33.0974	33.1898	33.6596	33.7552	34.2412	34.2412	34.3401	34.0451	33.7552	33.5646	33.3761
alpha	3.2004	3.2065	3.2127	3.2440	3.2503	3.2827	3.2827	3.2893	3.2697	3.2503	3.2376	3.2251
util living area	0.9954	0.9891	0.9753	0.9383	0.8623	0.7311	0.5885	0.6446	0.8462	0.9641	0.9913	0.9964 (86)
MIT	18.9755	19.2040	19.5574	20.0260	20.4348	20.7260	20.8424	20.8192	20.5846	20.0297	19.4205	18.9489 (87)
Th 2	19.2881	19.2919	19.2957	19.3146	19.3184	19.3375	19.3375	19.3413	19.3299	19.3184	19.3108	19.3032 (88)
util rest of house	0.9937	0.9851	0.9655	0.9120	0.7990	0.6021	0.3953	0.4539	0.7488	0.9436	0.9873	0.9950 (89)
MIT 2	17.0059	17.2994	17.7490	18.3422	18.8195	19.1228	19.2015	19.1961	19.0029	18.3632	17.5903	16.9819 (90)
Living area fraction	fLA = Living area / (4) =											0.1776 (91)
MIT	17.3558	17.6377	18.0703	18.6413	19.1064	19.4076	19.4930	19.4844	19.2839	18.6593	17.9155	17.3313 (92)
Temperature adjustment												0.0000
adjusted MIT	17.3558	17.6377	18.0703	18.6413	19.1064	19.4076	19.4930	19.4844	19.2839	18.6593	17.9155	17.3313 (93)

8. Space heating requirement

Utilisation	0.9905	0.9790	0.9553	0.8978	0.7889	0.6085	0.4155	0.4729	0.7453	0.9317	0.9821	0.9925 (94)
Useful gains	1063.7146	1360.9278	1605.7241	1788.2790	1724.2489	1322.1320	864.8041	903.3110	1271.2466	1287.4838	1092.4514	991.7847 (95)
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000 (96)
Heat loss rate W	4204.5674	4090.7520	3705.4857	3076.1976	2332.2438	1492.4031	898.0561	954.7216	1618.4663	2537.8253	3425.0702	4181.9354 (97)
Space heating kWh	2336.7945	1834.4418	1562.2226	927.3014	452.3483	0.0000	0.0000	0.0000	0.0000	930.2541	1679.4856	2373.4722 (98a)
Space heating requirement - total per year (kWh/year)												12096.3205
Solar heating kWh	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (98b)
Solar heating contribution - total per year (kWh/year)												0.0000
Space heating kWh	2336.7945	1834.4418	1562.2226	927.3014	452.3483	0.0000	0.0000	0.0000	0.0000	930.2541	1679.4856	2373.4722 (98c)
Space heating requirement after solar contribution - total per year (kWh/year)												12096.3205
Space heating requirement per m2												(98c) / (4) = 77.6899 (99)

8c. Space cooling requirement

Calculated for June, July and August. See Table 10b												
Ext. temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000
Heat loss rate W	0.0000	0.0000	0.0000	0.0000	0.0000	2917.9922	2297.1428	2352.4334	0.0000	0.0000	0.0000	0.0000 (100)
Utilisation	0.0000	0.0000	0.0000	0.0000	0.0000	0.7027	0.7813	0.7401	0.0000	0.0000	0.0000	0.0000 (101)
Useful loss	0.0000	0.0000	0.0000	0.0000	0.0000	2050.5745	1794.7837	1741.0337	0.0000	0.0000	0.0000	0.0000 (102)
Total gains	0.0000	0.0000	0.0000	0.0000	0.0000	2491.3619	2389.0625	2197.5149	0.0000	0.0000	0.0000	0.0000 (103)
Space cooling kWh	0.0000	0.0000	0.0000	0.0000	0.0000	317.3669	442.1435	339.6220	0.0000	0.0000	0.0000	0.0000 (104)
Cooled fraction	fC = cooled area / (4) =											0.6101 (105)
Intermittency factor (Table 10b)	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500 (106)
Space cooling kWh	0.0000	0.0000	0.0000	0.0000	0.0000	48.4102	67.4432	51.8049	0.0000	0.0000	0.0000	0.0000 (107)
Space cooling requirement												167.6583 (107)

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)												0.0000 (201)
Fraction of space heat from main system(s)												1.0000 (202)
Efficiency of main space heating system 1 (in %)												170.0000 (206)
Efficiency of main space heating system 2 (in %)												0.0000 (207)
Efficiency of secondary/supplementary heating system, %												0.0000 (208)
Cooling System Energy Efficiency Ratio (see Table 10c)												5.6000 (209)
Space heating requirement	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2336.7945	1834.4418	1562.2226	927.3014	452.3483	0.0000	0.0000	0.0000	0.0000	0.0000	930.2541	1679.4856	2373.4722 (98)
Space heating efficiency (main heating system 1)	170.0000	170.0000	170.0000	170.0000	170.0000	0.0000	0.0000	0.0000	0.0000	170.0000	170.0000	170.0000 (210)
Space heating fuel (main heating system)	1374.5850	1079.0834	918.9545	545.4714	266.0872	0.0000	0.0000	0.0000	0.0000	547.2083	987.9327	1396.1601 (211)
Space heating efficiency (main heating system 2)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (212)
Space heating fuel (main heating system 2)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (213)
Space heating fuel (secondary)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (215)
Water heating												
Water heating requirement	309.0010	273.3014	290.1014	254.1099	245.7582	220.7989	217.2779	226.1593	228.9538	256.1134	273.3744	305.4699 (64)
Efficiency of water heater (217)m	170.0000	170.0000	170.0000	170.0000	170.0000	170.0000	170.0000	170.0000	170.0000	170.0000	170.0000	170.0000 (216)
Fuel for water heating, kWh/month	181.7653	160.7655	170.6479	149.4764	144.5636	129.8817	127.8105	133.0349	134.6787	150.6550	160.8085	179.6881 (219)
Space cooling fuel requirement (221)m	0.0000	0.0000	0.0000	0.0000	0.0000	8.6447	12.0434	9.2509	0.0000	0.0000	0.0000	0.0000 (221)
Pumps and Fa	56.7930	51.2969	56.7930	54.9610	56.7930	54.9610	56.7930	56.7930	54.9610	56.7930	54.9610	56.7930 (231)
Lighting	40.1373	32.1996	28.9922	21.2409	16.4071	13.4047	14.9671	19.4548	25.2699	33.1554	37.4490	41.2528 (232)
Electricity generated by PVs (Appendix M) (negative quantity) (233a)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (233a)

Full SAP Calculation Printout



Electricity generated by wind turbines (Appendix M) (negative quantity) (234a)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(234a)
Electricity generated by hydro-electric generators (Appendix M) (negative quantity) (235a)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(235a)
Electricity used or net electricity generated by micro-CHP (Appendix N) (negative if net generation) (235c)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(235c)
Electricity generated by PVs (Appendix M) (negative quantity) (233b)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(233b)
Electricity generated by wind turbines (Appendix M) (negative quantity) (234b)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(234b)
Electricity generated by hydro-electric generators (Appendix M) (negative quantity) (235b)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(235b)
Electricity used or net electricity generated by micro-CHP (Appendix N) (negative if net generation) (235d)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(235d)
Annual totals kWh/year													
Space heating fuel - main system 1													7115.4826 (211)
Space heating fuel - main system 2													0.0000 (213)
Space heating fuel - secondary													0.0000 (215)
Efficiency of water heater													170.0000
Water heating fuel used													1823.7761 (219)
Space cooling fuel													29.9390 (221)
Electricity for pumps and fans: (BalancedWithHeatRecovery, Database: in-use factor = 1.4000, SFP = 1.1760) mechanical ventilation fans (SFP = 1.1760)													668.6917 (230a)
Total electricity for the above, kWh/year													668.6917 (231)
Electricity for lighting (calculated in Appendix L)													323.9310 (232)
Energy saving/generation technologies (Appendices M ,N and Q)													
PV generation													0.0000 (233)
Wind generation													0.0000 (234)
Hydro-electric generation (Appendix N)													0.0000 (235a)
Electricity generated - Micro CHP (Appendix N)													0.0000 (235)
Appendix Q - special features													
Energy saved or generated													-0.0000 (236)
Energy used													0.0000 (237)
Total delivered energy for all uses													9961.8204 (238)

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year	
Space heating - main system 1	7115.4826	0.1548	1101.6089	(261)
Total CO2 associated with community systems			0.0000	(373)
Water heating (other fuel)	1823.7761	0.1410	257.0807	(264)
Space and water heating			1358.6896	(265)
Space cooling	29.9390	0.1139	3.4103	(266)
Pumps, fans and electric keep-hot	668.6917	0.1387	92.7558	(267)
Energy for lighting	323.9310	0.1443	46.7532	(268)
Total CO2, kg/year			1501.6089	(272)
EPC Dwelling Carbon Dioxide Emission Rate (DER)			9.6400	(273)

13a. Primary energy - Individual heating systems including micro-CHP

	Energy kWh/year	Primary energy factor kg CO2/kWh	Primary energy kWh/year	
Space heating - main system 1	7115.4826	1.5732	11193.8699	(275)
Total CO2 associated with community systems			0.0000	(473)
Water heating (other fuel)	1823.7761	1.5212	2774.3730	(278)
Space and water heating			13968.2429	(279)
Space cooling	29.9390	1.4199	42.5097	(280)
Pumps, fans and electric keep-hot	668.6917	1.5128	1011.5968	(281)
Energy for lighting	323.9310	1.5338	496.8561	(282)
Total Primary energy kWh/year			15519.2055	(286)
Dwelling Primary energy Rate (DPER)			99.6700	(287)

SAP 10 WORKSHEET FOR New Build (As Designed) (Version 10.2, February 2022) CALCULATION OF TARGET EMISSIONS

1. Overall dwelling characteristics

	Area (m ²)	Storey height (m)	Volume (m ³)	
Ground floor	83.9900 (1b)	x 2.8000 (2b)	= 235.1720 (1b) - (3b)	
First floor	71.7100 (1c)	x 3.2200 (2c)	= 230.9062 (1c) - (3c)	
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	155.7000		(4)	
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 466.0782 (5)	

2. Ventilation rate

	m ³ per hour	
Number of open chimneys	0 * 80 =	0.0000 (6a)
Number of open flues	0 * 20 =	0.0000 (6b)
Number of chimneys / flues attached to closed fire	0 * 10 =	0.0000 (6c)
Number of flues attached to solid fuel boiler	0 * 20 =	0.0000 (6d)
Number of flues attached to other heater	0 * 35 =	0.0000 (6e)
Number of blocked chimneys	0 * 20 =	0.0000 (6f)
Number of intermittent extract fans	4 * 10 =	40.0000 (7a)
Number of passive vents	0 * 10 =	0.0000 (7b)

Full SAP Calculation Printout



Number of flueless gas fires													0 * 40 =	0.0000 (7c)	
Infiltration due to chimneys, flues and fans	= (6a)+(6b)+(6c)+(6d)+(6e)+(6f)+(6g)+(7a)+(7b)+(7c) =												Air changes per hour	40.0000 / (5) =	0.0858 (8)
Pressure test													Yes		
Pressure Test Method													Blower Door		
Measured/design AP50													5.0000	(17)	
Infiltration rate													0.3358	(18)	
Number of sides sheltered													3	(19)	
Shelter factor													(20) = 1 - [0.075 x (19)] =	0.7750 (20)	
Infiltration rate adjusted to include shelter factor													(21) = (18) x (20) =	0.2603 (21)	

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000	(22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750	(22a)
Adj infilt rate													
Effective ac	0.3318	0.3253	0.3188	0.2863	0.2798	0.2472	0.2472	0.2407	0.2603	0.2798	0.2928	0.3058	(22b)
	0.5551	0.5529	0.5508	0.5410	0.5391	0.5306	0.5306	0.5290	0.5339	0.5391	0.5429	0.5468	(25)

3. Heat losses and heat loss parameter

Element	Gross m2	Openings m2	NetArea m2	U-value W/m2K	A x U W/K	K-value kJ/m2K	A x K kJ/K	
TER Opaque door			2.8800	1.0000	2.8800			(26)
TER Opening Type (Uw = 1.20)			30.7400	1.1450	35.1985			(27)
GF RL			1.9300	2.0221	3.9026			(27a)
1F RL			3.3700	2.0221	6.8143			(27a)
Basement Floor			83.9900	0.1300	10.9187			(28)
Retaining Wall	69.0000		69.0000	0.1800	12.4200			(29a)
Existing External Wall	59.0100		59.0100	0.1800	10.6218			(29a)
New External Wall	94.0100	33.6200	60.3900	0.1800	10.8702			(29a)
Flat Roof GF	12.3600	1.9300	10.4300	0.1100	1.1473			(30)
Flat Roof First Floor	71.7100	3.3700	68.3400	0.1100	7.5174			(30)
Total net area of external elements Aum(A, m2)			390.0800					(31)
Fabric heat loss, W/K = Sum (A x U)					(26)...(30) + (32) =	102.2908		(33)
Party Wall 1			54.5700	0.0000	0.0000			(32)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m2K								245.7646 (35)
Thermal bridges (User defined value 0.050 * total exposed area)								19.5040 (36)
Point Thermal bridges								0.0000 (36a)
Total fabric heat loss							(33) + (36) + (36a) =	121.7948 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)													
(38)m	85.3710	85.0422	84.7199	83.2060	82.9227	81.6041	81.6041	81.3600	82.1120	82.9227	83.4957	84.0948	(38)
Heat transfer coeff	207.1658	206.8370	206.5146	205.0007	204.7175	203.3989	203.3989	203.1548	203.9068	204.7175	205.2905	205.8896	(39)
Average = Sum(39)m / 12 =													204.9994

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
HLP	1.3305	1.3284	1.3264	1.3166	1.3148	1.3064	1.3064	1.3048	1.3096	1.3148	1.3185	1.3223	(40)
HLP (average)													1.3166
Days in mont	31	28	31	30	31	30	31	31	30	31	30	31	

4. Water heating energy requirements (kWh/year)

Assumed occupancy														2.9428 (42)
Hot water usage for mixer showers														73.2785 (42a)
Hot water usage for baths														31.6492 (42b)
Hot water usage for other uses														44.7668 (42c)
Average daily hot water use (litres/day)														137.9606 (43)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Daily hot water use	150.0837	146.8787	142.9758	137.0412	132.2218	127.0406	125.0497	128.9357	133.0342	138.4735	144.4995	149.6945	(44)
Energy conte	237.6959	209.1533	219.7485	187.6025	177.9960	156.2113	151.2367	159.6494	164.0444	187.9072	205.8661	234.3854	(45)
Energy content (annual)													2291.4968
Distribution loss (46)m = 0.15 x (45)m													
Water storage loss:	35.6544	31.3730	32.9623	28.1404	26.6994	23.4317	22.6855	23.9474	24.6067	28.1861	30.8799	35.1578	(46)
Store volume													300.0000 (47)
a) If manufacturer declared loss factor is known (kWh/day):													2.1127 (48)
Temperature factor from Table 2b													0.5400 (49)
Enter (49) or (54) in (55)													1.1409 (55)
Total storage loss	35.3664	31.9439	35.3664	34.2256	35.3664	34.2256	35.3664	35.3664	34.2256	35.3664	34.2256	35.3664	(56)
If cylinder contains dedicated solar storage	35.3664	31.9439	35.3664	34.2256	35.3664	34.2256	35.3664	35.3664	34.2256	35.3664	34.2256	35.3664	(57)
Primary loss	23.2624	21.0112	23.2624	22.5120	23.2624	22.5120	23.2624	23.2624	22.5120	23.2624	22.5120	23.2624	(59)
Combi loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(61)
Total heat required for water heating calculated for each month	296.3247	262.1084	278.3773	244.3401	236.6248	212.9488	209.8655	218.2782	220.7820	246.5361	262.6036	293.0142	(62)
WWHRS	-33.6287	-29.7415	-31.1436	-25.7881	-24.0336	-20.5657	-19.2771	-20.4992	-21.2781	-25.0845	-28.4177	-33.0059	(63a)
PV diverter	-0.0000	-0.0000	-0.0000	-0.0000	-0.0000	-0.0000	-0.0000	-0.0000	-0.0000	-0.0000	-0.0000	-0.0000	(63b)
Solar input	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(63c)
FGHRS	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(63d)
Output from w/h	262.6960	232.3669	247.2337	218.5520	212.5912	192.3831	190.5885	197.7790	199.5039	221.4515	234.1859	260.0083	(64)
12Total per year (kWh/year)													2669.3399 (64)
Electric shower(s)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	2669 (64)
Total Energy used by instantaneous electric shower(s) (kWh/year) = Sum(64a)m =													0.0000 (64a)
Heat gains from water heating, kWh/month	125.9369	111.9075	119.9694	107.7679	106.0867	97.3303	97.1893	99.9865	99.9348	109.3822	113.8405	124.8362	(65)

Full SAP Calculation Printout



5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	147.1381	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	165.8884	183.6621	165.8884	171.4180	165.8884	171.4180	165.8884	165.8884	171.4180	165.8884	171.4180	165.8884	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	326.6567	330.0464	321.5045	303.3199	280.3650	258.7907	244.3778	240.9881	249.5300	267.7146	290.6694	312.2437	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	37.7138	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	0.0000	0.0000	0.0000	0.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	-117.7105	(71)
Water heating gains (Table 5)	169.2701	166.5291	161.2492	149.6776	142.5897	135.1810	130.6307	134.3904	138.7984	147.0191	158.1118	167.7906	(72)
Total internal gains	731.9566	750.3790	718.7835	694.5569	658.9845	632.5312	608.0383	608.4084	626.8878	650.7635	690.3407	716.0642	(73)

6. Solar gains

[Jan]	Area m ²	Solar flux Table 6a W/m ²	Specific data or Table 6b	Specific data or Table 6c	FF	Access Factor Table 6d	Gains W						
East	8.1700	19.6403	0.6300	0.7000	0.5400	34.3910	(76)						
South	16.0200	46.7521	0.6300	0.7000	0.5400	160.5233	(78)						
West	6.5500	19.6403	0.6300	0.7000	0.5400	27.5717	(80)						
East	3.3700	26.0000	0.6300	0.7000	1.0000	34.7764	(82)						
West	1.9300	26.0000	0.6300	0.7000	1.0000	19.9164	(82)						
Solar gains	277.1788	497.7007	736.4445	985.1581	1155.0893	1165.5220	1116.1591	989.1069	823.9003	566.2218	336.9528	233.8370	(83)
Total gains	1009.1354	1248.0797	1455.2280	1679.7150	1814.0739	1798.0532	1724.1974	1597.5153	1450.7880	1216.9853	1027.2935	949.9011	(84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000	(85)
Utilisation factor for gains for living area, nil,m (see Table 9a)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
tau	51.3083	51.3898	51.4701	51.8502	51.9219	52.2585	52.2585	52.3213	52.1283	51.9219	51.7770	51.6263	
alpha	4.4206	4.4260	4.4313	4.4567	4.4615	4.4839	4.4839	4.4881	4.4752	4.4615	4.4518	4.4418	
util living area	0.9969	0.9918	0.9786	0.9355	0.8361	0.6674	0.5055	0.5619	0.8046	0.9629	0.9932	0.9977	(86)
MIT	19.3430	19.5866	19.9387	20.3845	20.7378	20.9310	20.9841	20.9750	20.8376	20.3518	19.7593	19.3016	(87)
Th 2	19.8170	19.8186	19.8202	19.8278	19.8292	19.8359	19.8359	19.8371	19.8333	19.8292	19.8264	19.8234	(88)
util rest of house	0.9959	0.9891	0.9711	0.9125	0.7800	0.5678	0.3786	0.4310	0.7199	0.9450	0.9904	0.9969	(89)
MIT 2	17.9022	18.2138	18.6602	19.2132	19.6127	19.7976	19.8311	19.8287	19.7249	19.1868	18.4411	17.8536	(90)
Living area fraction	fLA = Living area / (4) =											0.1776	(91)
MIT	18.1582	18.4577	18.8873	19.4213	19.8126	19.9989	20.0360	20.0323	19.9226	19.3937	18.6753	18.1108	(92)
Temperature adjustment												0.0000	
adjusted MIT	18.1582	18.4577	18.8873	19.4213	19.8126	19.9989	20.0360	20.0323	19.9226	19.3937	18.6753	18.1108	(93)

8. Space heating requirement

Utilisation	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
Useful gains	1002.6773	1228.5885	1401.1945	1515.9241	1413.3766	1047.9312	691.5708	725.3383	1055.2914	1139.0697	1013.2023	945.1721	(95)	
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.4000	14.1000	14.1000	10.6000	7.1000	4.2000	(96)	
Heat loss rate W	2870.9425	2804.2241	2558.1567	2156.8697	1660.7884	1098.1406	698.8688	737.9189	1187.2676	1800.2315	2376.2942	2864.0948	(97)	
Space heating kWh	1389.9893	1058.8271	860.7798	461.4809	184.0744	0.0000	0.0000	0.0000	0.0000	491.9044	981.4261	1427.6785	(98a)	
Space heating requirement - total per year (kWh/year)												6856.1605		
Solar heating kWh	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(98b)	
Solar heating contribution - total per year (kWh/year)												0.0000		
Space heating kWh	1389.9893	1058.8271	860.7798	461.4809	184.0744	0.0000	0.0000	0.0000	0.0000	491.9044	981.4261	1427.6785	(98c)	
Space heating requirement after solar contribution - total per year (kWh/year)												6856.1605		
Space heating per m ²												(98c) / (4) =	44.0344	(99)

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)												0.0000	(201)
Fraction of space heat from main system(s)												1.0000	(202)
Efficiency of main space heating system 1 (in %)												92.3000	(206)
Efficiency of main space heating system 2 (in %)												0.0000	(207)
Efficiency of secondary/supplementary heating system, %												0.0000	(208)
Space heating requirement	1389.9893	1058.8271	860.7798	461.4809	184.0744	0.0000	0.0000	0.0000	0.0000	491.9044	981.4261	1427.6785	(98)
Space heating efficiency (main heating system 1)	92.3000	92.3000	92.3000	92.3000	92.3000	0.0000	0.0000	0.0000	0.0000	92.3000	92.3000	92.3000	(210)
Space heating fuel (main heating system)	1505.9472	1147.1583	932.5892	499.9793	199.4305	0.0000	0.0000	0.0000	0.0000	532.9408	1063.3003	1546.7807	(211)
Space heating efficiency (main heating system 2)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(212)
Space heating fuel (main heating system 2)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(213)
Space heating fuel (secondary)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(215)

Water heating
Water heating requirement

Full SAP Calculation Printout



Efficiency of water heater (217)m	262.6960	232.3669	247.2337	218.5520	212.5912	192.3831	190.5885	197.7790	199.5039	221.4515	234.1859	260.0083 (64)
Fuel for water heating, kWh/month	87.2361	87.0335	86.6202	85.6939	83.7384	79.8000	79.8000	79.8000	79.8000	85.7961	86.9116	79.8000 (216)
Space cooling fuel requirement (221)m	301.1321	266.9855	285.4228	255.0380	253.8753	241.0816	238.8327	247.8433	250.0049	258.1136	269.4529	297.8897 (219)
Pumps and Fa (233a)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (221)
Lighting (234a)m	7.3041	6.5973	7.3041	7.0685	7.3041	7.0685	7.3041	7.0685	7.3041	7.0685	7.3041	7.0685 (231)
Electricity generated by PVs (Appendix M) (negative quantity) (233a)m	34.4683	27.6518	24.8974	18.2409	14.0898	11.5115	12.8532	16.7070	21.7008	28.4726	32.1597	35.4263 (232)
Electricity generated by wind turbines (Appendix M) (negative quantity) (234a)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (234a)
Electricity generated by hydro-electric generators (Appendix M) (negative quantity) (235a)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (235a)
Electricity used or net electricity generated by micro-CHP (Appendix N) (negative if net generation) (235c)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (235c)
Electricity generated by PVs (Appendix M) (negative quantity) (233b)m	-71.2204	-96.8715	-134.3562	-145.5179	-152.2831	-140.3641	-138.4393	-132.7890	-122.3767	-107.8863	-76.9485	-61.9807 (233a)
Electricity generated by wind turbines (Appendix M) (negative quantity) (234b)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (234b)
Electricity generated by hydro-electric generators (Appendix M) (negative quantity) (235b)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (235b)
Electricity used or net electricity generated by micro-CHP (Appendix N) (negative if net generation) (235d)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (235d)
Annual totals kWh/year												
Space heating fuel - main system 1												7428.1262 (211)
Space heating fuel - main system 2												0.0000 (213)
Space heating fuel - secondary												0.0000 (215)
Efficiency of water heater												79.8000
Water heating fuel used												3165.6723 (219)
Space cooling fuel												0.0000 (221)
Electricity for pumps and fans:												
Total electricity for the above, kWh/year												86.0000 (231)
Electricity for lighting (calculated in Appendix L)												278.1792 (232)
Energy saving/generation technologies (Appendices M ,N and Q)												
PV generation												-4151.4162 (233)
Wind generation												0.0000 (234)
Hydro-electric generation (Appendix N)												0.0000 (235a)
Electricity generated - Micro CHP (Appendix N)												0.0000 (235)
Appendix Q - special features												
Energy saved or generated												-0.0000 (236)
Energy used												0.0000 (237)
Total delivered energy for all uses												6806.5615 (238)

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating - main system 1	7428.1262	0.2100	1559.9065 (261)
Total CO2 associated with community systems			0.0000 (373)
Water heating (other fuel)	3165.6723	0.2100	664.7912 (264)
Space and water heating			2224.6977 (265)
Pumps, fans and electric keep-hot	86.0000	0.1387	11.9293 (267)
Energy for lighting	278.1792	0.1443	40.1499 (268)
Energy saving/generation technologies			
PV Unit electricity used in dwelling	-1381.0338	0.1354	-186.9827
PV Unit electricity exported	-2770.3824	0.1262	-349.7574
Total			-536.7401 (269)
Total CO2, kg/year			1740.0367 (272)
EPC Target Carbon Dioxide Emission Rate (TER)			11.1800 (273)

13a. Primary energy - Individual heating systems including micro-CHP

	Energy kWh/year	Primary energy factor kg CO2/kWh	Primary energy kWh/year
Space heating - main system 1	7428.1262	1.1300	8393.7826 (275)
Total CO2 associated with community systems			0.0000 (473)
Water heating (other fuel)	3165.6723	1.1300	3577.2096 (278)
Space and water heating			11970.9923 (279)
Pumps, fans and electric keep-hot	86.0000	1.5128	130.1008 (281)
Energy for lighting	278.1792	1.5338	426.6805 (282)
Energy saving/generation technologies			
PV Unit electricity used in dwelling	-1381.0338	1.5004	-2072.1520
PV Unit electricity exported	-2770.3824	0.4634	-1283.8921
Total			-3356.0441 (283)
Total Primary energy kWh/year			9171.7295 (286)
Target Primary Energy Rate (TPER)			58.9100 (287)