

Basement Impact  
Assessment Audit

161 Arlington Road, London  
NW1 7ET

For  
London Borough of Camden

Project No.  
14006-79

Date  
July 2024

Campbell Reith Hill LLP  
15 Bermondsey Square  
London  
SE1 3UN

T: +44 (0)20 7340 1700  
E: london@campbellreith.com  
W: www.campbellreith.com

## DOCUMENT HISTORY AND STATUS

Revision	Date	Purpose/ Status	File Ref	Author	Check	Review
D1	03/07/2024	For comment	SSemb14006-79- 030724- 161 Arlington Road_D1	SS	EMB	EMB
F1	29/07/2024	For Planning	KBemb14006-79- 290724- 161 Arlington Road_F1.docx	KB	EMB	EMB

This document has been prepared in accordance with the scope of Campbell Reith Hill LLP's (CampbellReith) appointment with its client and is subject to the terms of the appointment. It is addressed to and for the sole use and reliance of CampbellReith's client. CampbellReith accepts no liability for any use of this document other than by its client and only for the purposes, stated in the document, for which it was prepared and provided. No person other than the client may copy (in whole or in part) use or rely on the contents of this document, without the prior written permission of Campbell Reith Hill LLP. Any advice, opinions, or recommendations within this document should be read and relied upon only in the context of the document as a whole. The contents of this document are not to be construed as providing legal, business or tax advice or opinion.

© Campbell Reith Hill LLP 2024

### Document Details

Last Saved	29/07/2024 12:36
Author	Sam Savery, BSc MSc CGeol FGS and K Barker, MSci CGeol FGS
Project Partner	E M Brown, BSc MSc CGeol FGS
Project Number	14006-79
Project Name	Basement Impact Assessment Audit
Revision	F1
Planning Reference	2024/1376/P
File Ref	KBemb14006-79-290724- 161 Arlington Road_F1.docx

CONTENTS

1.0 NON-TECHNICAL SUMMARY ..... 4  
2.0 INTRODUCTION ..... 5  
3.0 BASEMENT IMPACT ASSESSMENT AUDIT CHECK LIST ..... 7  
4.0 DISCUSSION ..... 10  
5.0 CONCLUSIONS ..... 12

APPENDICES

- Appendix 1 Consultation Responses
- Appendix 2 Audit Query Tracker
- Appendix 3 Supplementary Supporting Documents

## 1.0 NON-TECHNICAL SUMMARY

- 1.1 CampbellReith was instructed by London Borough of Camden, (LBC) to carry out an audit on the Basement Impact Assessment submitted as part of the Planning Submission documentation for 161 Arlington Road, London NW1 7ET (planning application 2024/1376/P and Listed Building Consent application 2024/1821/L). The basement is considered to fall within Category A as defined by the Terms of Reference.
- 1.2 The Audit reviewed the Basement Impact Assessment for potential impact on land stability and local ground and surface water conditions arising from basement development in accordance with LBC's policies and technical procedures.
- 1.3 CampbellReith was able to access LBC's Planning Portal and gain access to the latest revision of submitted documentation and reviewed it against an agreed audit check list.
- 1.4 The BIA has been prepared by Cochrane Construction Consultants. The authors' qualifications do not comply with the requirements of CPG: Basements.
- 1.5 The BIA has confirmed that the proposed basement will be founded within the London Clay Formation. The BIA outlines the construction methodology and recommends temporary propping is installed for the existing basement walls during the site preparation stage.
- 1.6 It is unlikely that the groundwater table will be encountered during basement foundation excavation. However, water ingress was noted in a foundation exposure pit and therefore mitigation measures for water ingress during construction should be presented.
- 1.7 It is accepted that the development will not impact on the local and wider hydrogeology of the area.
- 1.8 It is accepted the basement will not impact the hydrology.
- 1.9 The existing foundation depths were identified during the site-specific ground investigation and the BIA identifies that there is no significant increase in differential depths between existing foundations and the new basement. The basement is remote from public highways and the site and its surroundings are level.
- 1.10 The BIA recommends movement monitoring is undertaken during excavation and construction as a mitigation measure.
- 1.11 It cannot be confirmed that the BIA complies with the requirements of CPG: Basements and the Principles for Audit set out in the Basement Impact Assessment (BIA) Audit Service Terms of Reference & Audit Process. Queries and comments on the BIA are described in Section 4 and Appendix 2.

## 2.0 INTRODUCTION

2.1 CampbellReith was instructed by London Borough of Camden (LBC) on 4<sup>th</sup> June to carry out a Category A audit on the Basement Impact Assessment (BIA) submitted as part of the Planning Submission documentation for 161 Arlington Road, London NW1 7ET (planning application 2024/1376/P and Listed Building Consent application 2024/1821/L).

2.2 The audit was carried out in accordance with the Terms of Reference set by LBC. It reviewed the Basement Impact Assessment for potential impact on land stability and local ground and surface water conditions arising from basement development.

2.3 A BIA is required for all planning applications with basements in Camden in general accordance with policies and technical procedures contained within

- Camden Local Plan 2017 - Policy A5 Basements.
- Camden Planning Guidance (CPG): Basements. January 2021.
- Guidance for Subterranean Development (GSD). Issue 01. November 2010. Ove Arup & Partners.

2.4 The BIA should demonstrate that schemes:

- a) maintain the structural stability of the building and neighbouring properties;
- b) avoid adversely affecting drainage and run off or causing other damage to the water environment;
- c) avoid cumulative impacts upon structural stability or the water environment in the local area;

and evaluate the impacts of the proposed basement considering the issues of hydrology, hydrogeology and land stability via the process described by the GSD and to make recommendations for the detailed design.

2.5 LBC's Audit Instruction described the planning proposal as "Removal of existing rear conservatory and erection of a two-storey rear extension at basement and ground floor levels (with a basement lightwell). See also Listed Building Consent application 2024/1821/L for associated internal works."

2.6 The Audit Instruction confirmed 161 Arlington Road involved, or was a neighbour to, listed buildings.

2.7 CampbellReith accessed LBC's Planning Portal on 11<sup>th</sup> June 2024 and gained access to the following relevant documents for audit purposes:

- Desk Study Report by Cochrane Construction Consultants, ref. S2930, Rev. 00, dated 8<sup>th</sup> April 2024.

- Screening and Scoping Report by Cochrane Construction Consultants, ref. S2930, Rev. 00, dated 8<sup>th</sup> April 2024.
- Basement Impact Assessment Report by Cochrane Construction Consultants, ref. S2930, Rev. 00, dated 8<sup>th</sup> April 2024.

### 3.0 BASEMENT IMPACT ASSESSMENT AUDIT CHECK LIST

Item	Yes/No/NA	Comment
Are BIA Author(s) credentials satisfactory?	No	Qualifications do not comply with CPG basements
Is data required by Cl.233 of the GSD presented?	No	Mitigation measures for water ingress into the excavation should be provided
Does the description of the proposed development include all aspects of temporary and permanent works which might impact upon geology, hydrogeology and hydrology?	Yes	BIA report
Are suitable plan/maps included?	Yes	BIA desk study report, Appendix A
Do the plans/maps show the whole of the relevant area of study and do they show it in sufficient detail?	Yes	BIA desk study report, Appendix A
Land Stability Screening: Have appropriate data sources been consulted? Is justification provided for 'No' answers?	Yes	BIA screening and scoping report, Section 4.2
Hydrogeology Screening: Have appropriate data sources been consulted? Is justification provided for 'No' answers?	Yes	BIA screening and scoping report, Section 4.1
Hydrology Screening: Have appropriate data sources been consulted? Is justification provided for 'No' answers?	Yes	BIA screening and scoping report, Section 4.3
Is a conceptual model presented?	Yes	BIA report, Section 7.2
Land Stability Scoping Provided? Is scoping consistent with screening outcome?	Yes	BIA screening and scoping report, Section 5

Item	Yes/No/NA	Comment
Hydrogeology Scoping Provided? Is scoping consistent with screening outcome?	Yes	None
Hydrology Scoping Provided? Is scoping consistent with screening outcome?	Yes	None
Is factual ground investigation data provided?	Yes	BIA Appendix E
Is monitoring data presented?	No	
Is the ground investigation informed by a desk study?	Yes	BIA desk study report
Has a site walkover been undertaken?	Yes	
Is the presence/absence of adjacent or nearby basements confirmed?	Yes	BIA report, Section 4.6 d)
Is a geotechnical interpretation presented?	Yes	BIA report, Section 7.2
Does the geotechnical interpretation include information on retaining wall design?	Yes	BIA report, Section 7.2
Are reports on other investigations required by screening and scoping presented?	N/A	
Are the baseline conditions described, based on the GSD?	Yes	BIA report, Section 6.0
Do the baseline conditions consider adjacent or nearby basements?	Yes	BIA report, Section 4.6 d)
Is an Impact Assessment provided?	Yes	BIA report, Section 8.0
Are estimates of ground movement and structural impact presented?	Yes	BIA report, Section 7.6. However, this has not been audited.

Item	Yes/No/NA	Comment
Is the Impact Assessment appropriate to the matters identified by screening and scoping?	Yes	BIA report, Section 8.0
Has the need for mitigation been considered and are appropriate mitigation methods incorporated in the scheme?	No	Mitigation measures for water ingress into the excavation should be provided
Has the need for monitoring during construction been considered?	Yes	BIA report, Section 7.8
Have the residual (after mitigation) impacts been clearly identified?	Yes	
Has the scheme demonstrated that the structural stability of the building and neighbouring properties and infrastructure will be maintained?	Yes	BIA report, Section 8.0
Has the scheme avoided adversely affecting drainage and run-off or causing other damage to the water environment?	Yes	BIA screening and scoping report, Section 4.1
Has the scheme avoided cumulative impacts upon structural stability or the water environment in the local area?	Yes	
Does report state that damage to surrounding buildings will be no worse than Burland Category 1?	Yes	BIA report, Section 7.6. However, this has not been audited.
Are non-technical summaries provided?	Yes	BIA report

## 4.0 DISCUSSION

- 4.1 The Basement Impact Assessment (BIA) has been carried out by engineering consultants Cochrane Construction Consultants (CCC). The author is a chartered structural engineer but no proof of expertise in surface water, hydrogeology or engineering geology has been provided and the authors' qualifications do not comply with CPG Basements.
- 4.2 The LBC Instruction to proceed with the audit identified that the basement proposal either involved a listed building or was adjacent to listed buildings but gave no details. The Desk Study report identifies that 161 Arlington Road is in the Camden Town Conservation Area. Numbers 161, 157 and 159, are Grade II listed buildings although the BIA states the listings appears to relate only to the streetscape. The Lady of Hal Church is located on the northern boundary and the church link block borders the plant room in the existing basement.
- 4.3 The existing and proposed comparison drawing show the proposals comprise demolition of the rear extension and extending the existing basement into the rear garden by c.3.20m to form a new lightwell. Proposals involve lowering the ground floor by c.0.50m and rebuilding the rear extension as a 2-storey structure.
- 4.4 The intended method of construction is underpinning the existing foundations in a hit-and-miss sequence and forming a reinforced concrete basement. The BIA states temporary propping should be used as required.
- 4.5 The BIA has been informed by a desk study and site-specific ground investigation including a borehole and four trial pits. The ground conditions encountered comprise made ground over weathered brown clay of the London Clay Formation.
- 4.6 Water was encountered in foundation exposure pit TP2 that was assumed to be from a leaking drain. Groundwater was encountered in BH1 at 4.90m bgl although Section 6.3 of the BIA states no groundwater was encountered. Groundwater should be reported consistently. Noting the observation of water in the foundation exposure pit, mitigation measures for potential water ingress into the excavation should be provided within the construction sequence.
- 4.7 The BIA states the existing No 161 foundations are between 0.36 and 0.48m depth below existing basement floor level and comprise shallow strip footings on the London Clay Formation. The BIA states the basement flank wall adjacent to the church has been previously underpinned to 1.00m below existing basement floor level.
- 4.8 The BIA includes a screening and scoping assessment. Groundwater screening confirms the site is not mapped in a groundwater flood risk area and there are no water features within 100m distance. The London Clay Formation aquifer status is unproductive strata. It is accepted the development will not impact the hydrogeology.

- 4.9 Surface water screening notes the development will not change the proportion of hard surface/paved areas and surface water will be discharged into the sewer as existing. The surface water and flooding screening states there will no change to the existing run off, the site is in flood zone 1 and does not lie in a critical drainage area nor a local flood risk zone. It is accepted the development will not impact the hydrology.
- 4.10 The BIA indicates the site and wider area are level and will generally remain as existing.
- 4.11 The BIA states the London Clay Formation is the shallowest natural strata on-site and includes laboratory test results that indicate medium-high volume change potential soil is present. No trees will be removed and there was no evidence of subsidence or ground movement identified at the property or others nearby.
- 4.12 The BIA states the maximum increase in differential depth between the existing and new foundations is approximately 0.50m, therefore a ground movement assessment is not required.
- 4.13 The BIA states the rear basement extension is located 8.50m distance from the Arlington Road pavement so the proposed works will not affect the pavement or public highway. It is accepted the development will not impact the stability of the road.
- 4.14 On the basis of the above, and we accept there is no impact to stability and the ground movement/building damage assessment has not been audited.
- 4.15 The BIA recommends structural visual inspection and monitoring is undertaken on the adjacent buildings during the demolition, excavation and basement construction phases to mitigate any potential structural damage. Final monitoring requirements will be confirmed with the Contractor and adjoining owner's Surveyor prior to works.

## 5.0 CONCLUSIONS

- 5.1 The Basement Impact Assessment (BIA) has been carried out by engineering consultants Cochrane Construction Consultants (CCC) however the authors' qualifications do not comply with CPG Basements.
- 5.2 The BIA has confirmed that the proposed basement will be founded within the London Clay Formation. Site-specific ground investigation identifies the existing foundation depths to inform basement design.
- 5.3 The BIA outlines the construction methodology and sequencing. It recommends temporary propping is installed for the existing basement walls during the site preparation stage.
- 5.4 Groundwater was encountered during the investigation at depth. Water was also encountered in a foundation exposure pit.
- 5.5 It is accepted that the development will not impact on the local and wider hydrogeology of the area and is not in an area subject to flooding. However, mitigation measures for potential water ingress into the excavation should be presented.
- 5.6 It is accepted the development will not impact the hydrology.
- 5.7 It is accepted the basement, provided good workmanship is employed, will not impact the stability of the neighbouring properties and public highway.
- 5.8 The BIA recommends a movement monitoring strategy during excavation and construction as mitigation measures.
- 5.9 It cannot be confirmed that the BIA complies with the requirements of CPG: Basements and the Principles for Audit set out in the Basement Impact Assessment (BIA) Audit Service Terms of Reference & Audit Process, specifically:
- The person(s) undertaking the BIA do not hold qualifications relevant to the matters being considered, in accordance with the requirements set out in CPG: Basements.
  - The conclusions are not accompanied by sufficiently detailed amelioration/mitigation measures to support the grant of planning permission in accordance with Policy A5 of the Local Plan, in respect of:
    - maintaining the structural stability of the building, the ground and any neighbouring properties to within limits set out in the policy/guidance
    - avoiding cumulative impacts on ground and structural stability or the water environment in the local area.
- 5.10 Queries and comments on the BIA are described in Section 4 and Appendix 2

## Appendix 1

### Consultation Responses

None

Basement Impact Assessment Audit  
161 Arlington Road, London NW1 7ET

CampbellReith  
consulting engineers

## Appendix 2

### Audit Query Tracker

Audit Query Tracker

Query No	Subject	Query	Status	Date closed out
1	BIA	Authors' qualifications do not comply with CPG basements	Open – see 4.1	
2	Stability	Mitigation measures for water ingress into the excavation should be provided	Open – see 4.6	

## Appendix 3

### Supplementary Supporting Documents

None

---

## London

15 Bermondsey Square  
London  
SE1 3UN

T: +44 (0)20 7340 1700  
E: london@campbellreith.com

## Birmingham

Chantry House  
High Street, Coleshill  
Birmingham B46 3BP

T: +44 (0)1675 467 484  
E: birmingham@campbellreith.com

## Bristol

Unit 5.03  
HERE  
470 Bath Road  
Bristol BS4 3AP

T: +44 (0)117 916 1066  
E: bristol@campbellreith.com

## Manchester

10 Chapel Walks  
Manchester  
M2 1HL

T: +44 (0)161 819 3060  
E: manchester@campbellreith.com

Campbell Reith Hill LLP. Registered in England & Wales. Limited Liability Partnership No OC300082  
A list of Members is available at our Registered Office at: 15 Bermondsey Square, London, SE1 3UN  
VAT No 974 8892 43