

10 Lyndhurst Road, Hampstead



**Planning Compliance Report
Report 29006.PCR.01**

**John Fitzpatrick
26 Lyndhurst Road,
London NW3 5PB**

Report 29006.PCR.01			
Revision History			
First Issue Date: 06/08/2024			
A		D	
B		E	
C		F	
Written by:		Checked by:	
Prabath Alagiyawanna		Daniel Stuart MIOA	
Assistant Acoustic Consultant		Senior Consultant	
		Approved by:	
		Gonçalo Lemos MIEEnvSc MIOA	
		Principal Consultant	
Disclaimer KP Acoustics Ltd. has used reasonable skill and care to complete this technical document, within the terms of its brief and contract with the resources devoted to it by agreement with the client. We disclaim any responsibility to the client and others in respect of any matters outside the stated scope. This report is confidential to the client and we accept no responsibility to third parties to whom this report, or any part thereof, is made known. KP Acoustics Ltd. accepts no responsibility for data provided by other bodies and no legal liability arising from the use by other persons of data or opinions contained in this report. KP Acoustics Ltd. 2024			

Contents

1.0	INTRODUCTION	1
2.0	SITE SURVEYS	1
2.1	Site Description	1
2.2	Environmental Noise Survey Procedure	2
2.3	Equipment.....	3
3.0	RESULTS.....	4
4.0	NOISE ASSESSMENT GUIDANCE.....	4
4.1	BS4142: 2014 ‘Methods for rating and assessing industrial and commercial sound’	4
4.2	Local Authority Guidance.....	6
4.3	Descriptions of criterion	6
5.0	NOISE IMPACT ASSESSMENT	7
5.1	Proposed Plant Installations	7
5.2	Calculations	8
6.0	CONCLUSION.....	8

List of Attachments

29006.TH1	Environmental Noise Time History
29006.Daytime L90.TH1	Statistical analysis for representative daytime L_{A90}
29006.Night-time L90.TH1	Statistical analysis for representative night-time L_{A90}
Appendix A	Glossary of Acoustics Terminology
Appendix B	Acoustic Calculations

1.0 INTRODUCTION

KP Acoustics Ltd has been commissioned by Mary Duggan Architects, Royle Studios, Unit 2, 23-41 Wenlock Road, London, N1 7SG, to undertake a noise impact assessment of a proposed plant unit installation serving the building at The Cottage 10, Lyndhurst Road, NW3 5PB.

A 24-hour environmental noise survey has been undertaken on site in order to prepare a noise impact assessment in accordance with BS4142:2014 '*Method for rating and assessing industrial and commercial sound*' as part of the planning requirements of The London Borough of Camden.

This report presents the methodology and results from the environmental survey, followed by calculations in accordance with BS4142 to provide an indication as to the likelihood of the noise emissions from the proposed plant unit installation having an adverse impact on the closest noise sensitive receiver. Mitigation measures will be outlined as appropriate.

2.0 SITE SURVEYS

2.1 Site Description

As shown in Figure 2.1, the site is bounded by Lyndhurst Road to the south and residential area to the north, west and east.



Figure 2.1 Site Location Plan and Noise Measurement Position (Image Source: Google Maps)

Initial inspection of the site revealed that the dominant source at the monitoring location was typical of an urban cityscape environment, with the dominant source being road traffic noise from the surrounding roads.

2.2 Environmental Noise Survey Procedure

Continuous automated monitoring was undertaken for the duration of the noise survey between 11:15 on 31/07/2024 and 10:30 01/08/2024.

The environmental noise measurement position, proposed plant installation locations, and the closest noise sensitive receivers relative to the plant installations are described within Table 2.1 and shown within Figure 2.2 and Figure 2.3.





Icon	Descriptor	Location Description
	Noise Measurement Position 1	The microphone was installed on a tripod in the rear garden, as shown in Figure 2.2. The microphone was positioned within free-field conditions at least approx. 1.5 metres from the nearest surface.
	Nearest noise sensitive receptor NSR 01	Rear garden used for main amenity. Residential house to the west.
	Nearest noise sensitive receptor NSR 02	Rear façade. First Floor window. Residential house to the west.
	Proposed plant installation location	Proposed plant installations are outlined in Section 5.1.

Table 2.1 Measurement positions and descriptions



Figure 2.2 Site measurement position, proposed plant location and nearest noise sensitive receptors (Image Source: Google Maps)




Figure 2.3 Proposed plant location (Image Source: Mary Duggan Architects)

The choice of the position was based both on accessibility and on collecting representative noise data in relation to the nearest noise sensitive receivers and the proposed plant installation.

Weather conditions were generally dry with light winds and therefore suitable for the measurement of environmental noise. The measurement procedure complied with ISO 1996-2:2017 Acoustics '*Description, measurement and assessment of environmental noise - Part 2: Determination of environmental noise levels*'.

2.3 Equipment

The equipment calibration was verified before and after use and no abnormalities were observed. The equipment used is described within Table 2.2.

Measurement instrumentation		Serial no.	Date	Cert no.
Noise Kit 26	NTI Audio XL2 Class 1 Sound Level Meter	A2A-21130-E0	23/07/2024	TCRT24/1572
	Free-field microphone NTI Acoustics MC230A	A25902		
	Preamp NTI Acoustics MA220	5522		
	NTI Audio External Weatherproof Shroud	-	-	-
B&K Type 4231 Class 1 Calibrator		2147411	14/06/2024	UKAS24/06438

Table 2.2 Measurement instrumentation

3.0 RESULTS

The $L_{Aeq: 5min}$, $L_{Amax: 5min}$, $L_{A10: 5min}$ and $L_{A90: 5min}$ acoustic parameters were measured throughout the duration of the survey. Measured levels are shown as a time history in Figure 29006.TH1.

Representative background noise levels are shown in Table 3.1 for daytime and night-time.

It should be noted that the representative background noise level has been derived based on the guidance of BS4142 Section 8.1.4 from the $L_{A90, 5min}$ levels measured during the environmental noise survey undertaken on site, as shown in 29006.Daytime L90.TH1 and 29006.Night-time L90.TH1 attached.

Time Period	Representative background noise level L_{A90} dB(A)
Daytime (07:00-23:00)	40
Night-time (23:00-07:00)	30

Table 3.1 Representative background noise levels

4.0 NOISE ASSESSMENT GUIDANCE

4.1 BS4142: 2014 'Methods for rating and assessing industrial and commercial sound'

British Standard BS4142:2014 '*Methods for rating and assessing industrial and commercial sound*' describes a method for rating and assessing sound of an industrial and/or commercial nature, which includes:

- Sound from industrial and manufacturing processes
- Sound from fixed installations which comprise mechanical and electrical plant and equipment
- Sound from the loading and unloading of goods and materials at industrial and/or commercial premises, and
- Sound from mobile plant and vehicles that is an intrinsic part of the overall sound emanating from premises or processes.

This Standard compares the Rating Level due to the noise source/s under assessment for a one-hour period during the daytime (07:00 – 23:00 hours) and a fifteen-minute period during the night-time (23:00 – 07:00 hours) with the existing background noise level in terms of an L_{A90} when the noise source is not operating.

It should be noted that the Rating Level is the Specific Sound Level in question (L_{Aeq, T_T}), including any relevant acoustic feature corrections, as follows:

- **Tonality** – *‘For sound ranging from not tonal to prominently tonal the Joint Nordic Method gives a correction of between 0dB and +6dB for tonality. Subjectively, this can be converted to a penalty of 2dB for a tone which is just perceptible at the noise receptor, 4dB where it is clearly perceptible, and 6dB where it is highly perceptible’*
- **Impulsivity** – *‘A correction of up to +9dB can be applied for sound that is highly impulsive, considering both the rapidity of the change in sound level and the overall change in sound level. Subjectively, this can be converted to a penalty of 3dB for impulsivity which is just perceptible at the noise receptor, 6dB where it is clearly perceptible, and 9dB where it is highly perceptible’*
- **Intermittency** – *‘If the intermittency is readily distinctive against the residual acoustic environment, a penalty of 3dB can be applied’*
- **Other sound characteristics** – *‘Where the specific sound features characteristics that are neither tonal nor impulsive, though otherwise are readily distinctive against the residual acoustic environment, a penalty of 3dB can be applied’*

Once the Rating Level has been obtained, the representative background sound level is subtracted from the Rating Level to obtain an initial estimate of the impact, as follows:

- Typically, the greater this difference, the greater the magnitude of the impact
- A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context
- A difference of around +5 dB could be an indication of an adverse impact, depending on the context
- The lower the rating level is relative to the measured background sound level, the less likely it is that there will be an adverse impact or significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound having a low impact, depending on the context

NOTE: Adverse impacts may include but not be limited to annoyance and sleep disturbance. Not all adverse impacts will lead to complaints and not every complaint is proof of an adverse impact.

The initial estimate of the impact may then be modified by taking consideration of the context in which the sound occurs.

4.2 Local Authority Guidance

The guidance provided by The London Borough of Camden for noise emissions of new plant in this instance is as follows:

The noise criteria, as per the Local Plan 2017 of London Borough of Camden, British Standard 4142:2014 'Methods for rating and assessing industrial and commercial sound' should be considered as the main reference document for the assessment. The resultant 'Rating Level' would be considered as follows:

Period	Assessment Location	Rating Level Acceptability Range		
		Green: noise is considered to be at an acceptable level	Amber: noise is observed to have an adverse effect level, but which may be considered acceptable when assessed in the context of other merits of the development	Red: noise is observed to have a significant adverse effect.
Daytime (7:00-23:00)	Garden used for main amenity (free field) and Outside living or dining or Bedroom window (façade)	10dB below background	9 dB below and 5dB above background	5dB above background
Night-time (23:00-7:00)	Outside bedroom window (façade)	10dB below background and no events exceeding 57dB L_{Amax}	9db below and 5dB above background or noise events between 57dB and 88dB L_{Amax}	5dB above background and/or events exceeding 88dB L_{Amax}

Table 4.1 Camden noise criteria for plant and machinery

4.3 Descriptions of criterion

Based on the London Borough of Camden guidelines, two noise criteria are defined: one for garden use as the main amenity (free field) and another for outside living or dining areas or bedroom windows (façade), as shown in Table 4.2.

Criterion	Receiver
Criterion 01	Rear garden used for main amenity. Residential house No. 09 Lyndhurst Road to the west.
Criterion 02	Rear façade. First floor window. residential house No. 09 Lyndhurst Road to the west.

Table 4.2 Descriptions of criterion

5.0 NOISE IMPACT ASSESSMENT

5.1 Proposed Plant Installations

It is understood that the proposed plant installation is comprised of the following unit:

- 1 No. Daikin Altherma Monobloc EDLA08EV3

The proposed installation location will be located to the rear side of the garden area, as shown in Figure 2.2 and Figure 2.3 above.

The noise emission level as provided by the manufacturer for the unit are shown in Table 5.1.

Unit	Descriptor	Octave Frequency Band (Hz)								Overall (dBA)
		63	125	250	500	1k	2k	4k	8k	
Daikin Altherma Monobloc EDLA08EV3	SPL@1m (dB)	52	54	52	49	44	37	33	23	50

Table 5.1 Plant Units Noise Emission Levels as provided by the manufacturer

The closest noise-sensitive receivers to the proposed installation locations have been identified as follows:

The rear garden, used as the main amenity space for the residential house at No. 09 Lyndhurst Road, located approximately 9 meters from the proposed plant installation location as shown in Figure 2.2.

The rear first-floor window of No. 09 Lyndhurst Road, located approximately 14 meters from the proposed plant installation location, are shown in Figure 2.2.

It should be noted the proposed plant unit would be out of line of sight of the amenity garden area and residential window due to screening from the building envelope.

5.2 Calculations

Taking all acoustic corrections into consideration, the noise level contribution expected at the closest residential window and garden used for main amenity from the proposed plant would be as shown in Table 5.2. Detailed calculations are shown in Appendix B.

Receiver	Criterion	Noise Level at 1m From the Closest Noise Sensitive Window
Rear garden used for main amenity. Residential house No 09 Lyndhurst Road to the west.	Criterion 01 30dB(A)	23dB(A)
Rear façade, first floor window. Residential house No 09 Lyndhurst Road to the west.	Criterion 02 20dB(A)	20dB(A)

Table 5.2 Predicted noise level and criterion at nearest noise sensitive location

As shown in Appendix B and Table 5.2, transmission of noise to the nearest rear garden used for main amenity and sensitive windows due to the effects of the proposed plant unit installation satisfies the emissions criterion of The London Borough of Camden, without the need for additional mitigation measures.

6.0 CONCLUSION

An environmental noise survey has been undertaken at The Cottage 10, Lyndhurst Road, NW3 5PB, by KP Acoustics Ltd between 11.15 on 31/07/2024 and 10.30 01/08/2024. The results of the survey have enabled criteria to be set for noise emissions.

Manufacturer's noise data of proposed plant units has been used to the Noise Level at the nearest noise sensitive receiver in accordance with British Standard BS4142:2014 for compliance with The London Borough of Camden requirements.

The level was compared with the representative background noise level to assess the likelihood of impact considering the environmental noise context of the area.

It has been concluded that noise emissions from the proposed plant units would not have an adverse impact on the nearest residential receivers without providing any mitigation measures.

The Cottage 10, Lyndhurst Road, NW3 5PB - Position 1
Environmental Time History
31/07/2024 to 01/08/2024




Figure 29006.TH1

The Cottage 10, Lyndhurst Road, NW3 5PB - Position 1
Representative Daytime Background Noise Level
31/07/2024 to 01/08/2024




Figure 29006.Daytime L90.TH1

The Cottage 10, Lyndhurst Road, NW3 5PB - Position 1
Representative Night-time Background Noise Level
31/07/2024 to 01/08/2024




Figure 29006.Night-time L90.TH1

GENERAL ACOUSTIC TERMINOLOGY

Decibel scale - dB

In practice, when sound intensity or sound pressure is measured, a logarithmic scale is used in which the unit is the 'decibel', dB. This is derived from the human auditory system, where the dynamic range of human hearing is so large, in the order of 10^{13} units, that only a logarithmic scale is the sensible solution for displaying such a range.

Decibel scale, 'A' weighted - dB(A)

The human ear is less sensitive at frequency extremes, below 125Hz and above 16Khz. A sound level meter models the ears variable sensitivity to sound at different frequencies. This is achieved by building a filter into the Sound Level Meter with a similar frequency response to that of the ear, an A-weighted filter where the unit is dB(A).

L_{eq}

The sound from noise sources often fluctuates widely during a given period of time. An average value can be measured, the equivalent sound pressure level L_{eq} . The L_{eq} is the equivalent sound level which would deliver the same sound energy as the actual fluctuating sound measured in the same time period.

L_{10}

This is the level exceeded for no more than 10% of the time. This parameter is often used as a "not to exceed" criterion for noise.

L_{90}

This is the level exceeded for no more than 90% of the time. This parameter is often used as a descriptor of "background noise" for environmental impact studies.

L_{max}

This is the maximum sound pressure level that has been measured over a period.

Octave Bands

In order to completely determine the composition of a sound it is necessary to determine the sound level at each frequency individually. Usually, values are stated in octave bands. The audible frequency region is divided into 11 such octave bands whose centre frequencies are defined in accordance with international standards. These centre frequencies are: 16, 31.5, 63, 125, 250, 500, 1000, 2000, 4000, 8000 and 16000 Hertz.

Environmental noise terms are defined in BS7445, *Description and Measurement of Environmental Noise*.

APPLIED ACOUSTIC TERMINOLOGY

Addition of noise from several sources

Noise from different sound sources combines to produce a sound level higher than that from any individual source. Two equally intense sound sources operating together produce a sound level which is 3dB higher than a single source and 4 sources produce a 6dB higher sound level.

Attenuation by distance

Sound which propagates from a point source in free air attenuates by 6dB for each doubling of distance from the noise source. Sound energy from line sources (e.g. stream of cars) drops off by 3dB for each doubling of distance.

Subjective impression of noise

Hearing perception is highly individualised. Sensitivity to noise also depends on frequency content, time of occurrence, duration of sound and psychological factors such as emotion and expectations. The following table is a guide to explain increases or decreases in sound levels for many scenarios.

Change in sound level (dB)	Change in perceived loudness
1	Imperceptible
3	Just barely perceptible
6	Clearly noticeable
10	About twice as loud

Transmission path(s)

The transmission path is the path the sound takes from the source to the receiver. Where multiple paths exist in parallel, the reduction in each path should be calculated and summed at the receiving point. Outdoor barriers can block transmission paths, for example traffic noise. The effectiveness of barriers is dependent on factors such as its distance from the noise source and the receiver, its height and construction.

Ground-borne vibration

In addition to airborne noise levels caused by transportation, construction, and industrial sources there is also the generation of ground-borne vibration to consider. This can lead to structure-borne noise, perceptible vibration, or in rare cases, building damage.

Sound insulation - Absorption within porous materials

Upon encountering a porous material, sound energy is absorbed. Porous materials which are intended to absorb sound are known as absorbents, and usually absorb 50 to 90% of the energy and are frequency dependent. Some are designed to absorb low frequencies, some for high frequencies and more exotic designs being able to absorb very wide ranges of frequencies. The energy is converted into both mechanical movement and heat within the material; both the stiffness and mass of panels affect the sound insulation performance.

APPENDIX B

The Cottage 10 Lyndhurst Road NW3 5PB

PLANT NOISE EMISSIONS CALCULATIONS

Source:Daikin Altherma Monobloc EDLA08EV3 Receiver: No 09 Lyndhurst Road aminity garden	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
Daikin Altherma Monobloc EDLA08EV3 (Sound Pressure Level @1m)	52	54	52	49	44	37	33	23	50
Correction due to surface reflections (2), dB	6	6	6	6	6	6	6	6	
Minimum attenuation due to brick wall, dB	-8	-10	-12	-15	-18	-21	-24	-25	
Minimum attenuation provided by distance(9m), dB	-19	-19	-19	-19	-19	-19	-19	-19	
Total Rating Noise Level of all Plant Unit Installations at Receiver	31	31	27	21	13	3	-4	-15	23

Design Criterion 01	30
---------------------	----

Source:Daikin Altherma Monobloc EDLA08EV3 Receiver: No 09 Lyndhurst Road residential window	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
Daikin Altherma Monobloc EDLA08EV3 (Sound Pressure Level @1m)	52	54	52	49	44	37	33	23	50
Correction due to surface reflections (2), dB	6	6	6	6	6	6	6	6	
Minimum attenuation due to brick wall, dB	-6	-8	-11	-14	-17	-18	-20	-20	
Minimum attenuation provided by distance (14m), dB	-23	-23	-23	-23	-23	-23	-23	-23	
Total Rating Noise Level of all Plant Unit Installations at Receiver	29	29	24	18	11	2	-4	-14	20

Design Criterion 02	20
---------------------	----