

Application No:	Consultees Name:	Received:	Comment:	Response:
2024/2749/P	Richard Simpson for Primrose Hill CAAC	08/08/2024 10:45:06	NOBJ	PRIMROSE HILL CONSERVATION AREA ADVISORY COMMITTEE 12A Manley Street, London NW1 8LT

07 August 2024

Flat 1st + 2nd Floor 9 Princess Road NW1 8JN 2024/2749/P

No objection, given the specific location of the ASHP and the mitigation measures proposed.

However we request a condition to ensure that the noise levels are maintained at acceptable levels as set out in the Local Plan, specifically at least 10dBA lower than the background noise level, at all times.

Richard Simpson FSA,
Chair PHCAAC.
