



## MCS 020 noise impact assessment for 18A Frognal Gardens

This assessment was done in relation to the neighbour window most likely to be affected by noise from the heat pump.

This is the result of the assessment:

Step	Instruction	Result
1	Sound power	61
2	Directivity Q	4
3	Distance	12.6
4	dB reduction	-26
5	Solid barrier	-10
6	Sound pressure level	25
7	Background noise	40
8	Difference	15
9	Decibel correction	40.1
<b>10</b>	<b>FINAL RESULT</b>	<b>PASS</b>

Oliver Larsson

Better Planet UK Ltd



*Prepared by Oliver Larsson, Better Planet UK LTD*

*Phone number: 07582 382589*

*Email: [oliver.larsson@betterplanet.co.uk](mailto:oliver.larsson@betterplanet.co.uk)*