

Project name

Chester Road - AG

Date: Mon Jun 17 17:31:26 2024

As designed

Administrative information

Building Details

Address: Chester Road, London,

Certification tool

Calculation engine: SBEM

Calculation engine version: v5.6.b.0

Interface to calculation engine: Virtual Environment

Interface to calculation engine version: v7.0.26

BRUKL compliance check version: v5.6.b.0

Certifier details

Name: Cory Skrzypkowski

Telephone number: 01159 754141

Address: Unit C4, Park Lane Business Centre, Basford, NG6 0DW

Criterion 1: The calculated CO₂ emission rate for the building must not exceed the target

CO ₂ emission rate from the notional building, kgCO ₂ /m ² .annum	10.6
Target CO ₂ emission rate (TER), kgCO ₂ /m ² .annum	10.6
Building CO ₂ emission rate (BER), kgCO ₂ /m ² .annum	2.1
Are emissions from the building less than or equal to the target?	BER <= TER
Are as built details the same as used in the BER calculations?	Separate submission

Criterion 2: The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Values which do not achieve the standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

Element	U _{o-Limit}	U _{o-Calc}	U _{o-Calc}	Surface where the maximum value occurs*
Wall**	0.35	0.14	1	"RV000047_W1_O1"
Floor	0.25	0.11	0.11	"RV00000F_F"
Roof	0.25	0.11	0.11	"RV00000F_C_A0"
Windows***, roof windows, and rooflights	2.2	0.9	0.9	"RV00000F_W3_O0"
Personnel doors	2.2	-	-	"No external personnel doors"
Vehicle access & similar large doors	1.5	-	-	"No external vehicle access doors"
High usage entrance doors	3.5	-	-	"No external high usage entrance doors"
U _{o-Limit} = Limiting area-weighted average U-values [W/(m ² K)] U _{o-Calc} = Calculated area-weighted average U-values [W/(m ² K)] U _{o-Calc} = Calculated maximum individual element U-values [W/(m ² K)]				
* There might be more than one surface where the maximum U-value occurs. ** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows. *** Display windows and similar glazing are excluded from the U-value check. N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.				

Air Permeability	Worst acceptable standard	This building
m ³ /(h.m ²) at 50 Pa	10	4

Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	NO
Whole building electric power factor achieved by power factor correction	>0.95

1- Main - VRF PURY-EM200/250YNW-A1

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	5.8	4.05	-	-	-
Standard value	2.5*	2.6	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					
YES					

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. For types <=12 kW output, refer to EN 14825 for limiting standards.

2- Elec UFH - E

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	1	-	-	-	-
Standard value	N/A	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					
YES					

1- SYST0016-DHW

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	4.3	0.038
Standard value	1	N/A

Local mechanical ventilation, exhaust, and terminal units

ID	System type in Non-domestic Building Services Compliance Guide
A	Local supply or extract ventilation units serving a single area
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal supply and extract ventilation units serving a single room or zone with heating and heat recovery
E	Local supply and extract ventilation system serving a single area with heating and heat recovery
F	Other local ventilation units
G	Fan-assisted terminal VAV unit
H	Fan coil units
I	Zonal extract system where the fan is remote from the zone with grease filter

Zone name	ID of system type	SFP [W/(l/s)]										HR efficiency	
		A	B	C	D	E	F	G	H	I			
	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard	
A0 - Common Room	-	-	-	-	1.6	-	-	-	-	-	0.8	0.5	
A0 - Interview Room	-	-	-	-	1.6	-	-	-	-	-	0.8	0.5	
A0 - Office	-	-	-	-	1.6	-	-	-	-	-	0.8	0.5	
A0 - Reception	-	-	1.6	-	-	-	-	-	-	-	-	N/A	
B0 - Circulation	-	-	1.6	-	-	-	-	-	-	-	-	N/A	
B0 - Staff Room	-	-	-	-	1.6	-	-	-	-	-	0.8	0.5	
Stairs	-	-	1.6	-	-	-	-	-	-	-	-	N/A	
A0 - WC	-	-	-	0.3	-	-	-	-	-	-	-	N/A	
B0 - Changing Room	-	-	-	0.3	-	-	-	-	-	-	-	N/A	

Zone name	ID of system type	SFP [W/(l/s)]									HR efficiency	
		A	B	C	D	E	F	G	H	I	Zone	Standard
B0 - Staff Bathroom	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
		-	-	0.3	-	-	-	-	-	-	-	N/A

General lighting and display lighting

General lighting and display lighting		Luminous efficacy [lm/W]				
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]	
		60	60	22		
00 - Refuse Store Block C		128	-	-	16	
00 - Stairwell		-	109	-	22	
00 - Store		128	-	-	6	
01 - Stairwell		-	109	-	22	
01 - Stairwell		-	109	-	19	
01 - Store		128	-	-	6	
02 - Store		128	-	-	6	
02- Stairwell		-	109	-	22	
02- Stairwell		-	109	-	19	
03 - Stairwell		-	109	-	22	
B0 - Cleaner Cupboard		128	-	-	6	
B0 - Cleaner Cupboard		128	-	-	7	
B0 - Electric Meter Room		128	-	-	4	
B0 - Electric Meter Room		128	-	-	5	
B0 - Electrical Intake Room		128	-	-	6	
B0 - Furniture Store		128	-	-	13	
B0 - Furniture Store		128	-	-	10	
B0 - Hot Water Store Plant Room		128	-	-	8	
B0 - Refuse Store Block C		128	-	-	17	
B0 - Stairwell		-	109	-	21	
B0 - Water Tank Plant Room		128	-	-	15	
Store		128	-	-	6	
A0 - Common Room		134	-	-	101	
A0 - Interview Room		100	-	-	72	
A0 - Office		100	-	-	72	
A0 - Reception		-	83	83	135	
B0 - Circulation		-	109	-	64	
B0 - Staff Room		134	-	-	149	
Stairs		-	109	-	19	
A0 - WC		-	106	-	24	
B0 - Changing Room		-	102	-	27	
B0 - Staff Bathroom		-	70	-	39	

Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
A0 - Common Room	NO (-53.5%)	NO
A0 - Interview Room	NO (-83.3%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
A0 - Office	NO (-83.2%)	NO
A0 - Reception	NO (-48.8%)	NO
B0 - Circulation	N/A	N/A
B0 - Staff Room	NO (-92.1%)	NO
Stairs	N/A	N/A

Criterion 4: The performance of the building, as built, should be consistent with the calculated BER

Separate submission

Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

EPBD (Recast): Consideration of alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	YES
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	YES

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

Building Use

		% Area Building Type	
Area [m²]	Actual	Notional	
External area [m²]	407.9	407.9	A1/A2 Retail/Financial and Professional services A3/A4/AS Restaurants and Cafes/Drinking Est./Takeaways
Weather	1906.6	1906.6	
	LON	LON	
Infiltration [m³/hm²@ 50Pa]	4	3	B1 Offices and Workshop businesses
Average conductance [W/K]	256.51	657.93	B2 to B7 General Industrial and Special Industrial Groups B8 Storage or Distribution
Average U-value [W/m²K]	0.13	0.35	C1 Hotels
Alpha value* [%]	20.65	15.34	C2 Residential Institutions: Hospitals and Care Homes C2 Residential Institutions: Residential schools C2 Residential Institutions: Universities and colleges C2A Secure Residential Institutions

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Residential spaces
D1 Non-residential Institutions: Community/Day Centre
D1 Non-residential Institutions: Libraries, Museums, and Galleries
D1 Non-residential Institutions: Education
D1 Non-residential Institutions: Primary Health Care Building
D2 General Assembly and Leisure, Night Clubs, and Theatres
Others: Passenger terminals
Others: Emergency services
Others: Miscellaneous 24hr activities
Others: Car Parks 24 hrs
Others: Stand alone utility block

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	3.12	8.5
Cooling	0.8	2.61
Auxiliary	2.44	1.5
Lighting	7.28	9.35
Hot water	0.53	0.56
Equipment*	10.48	10.48
TOTAL**	14.17	22.52

* Energy used by equipment, does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	8.97	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m²]	185.03	297.96
Primary energy* [kWh/m²]	39.96	62.09
Total emissions [kg/m²]	2.1	10.6

* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

HVAC Systems Performance

System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Aux con kWh/m2	Heat SSEEF	Heat gen SEFF	Cool gen SEER
[ST] No Heating or Cooling							
Actual	194.2	1.6	0	0	0	0	0
Notional	264.1	65.1	0	0	0	---	---
[ST] Split or multi-split system, [HS] Heat pump (electric), air source, [HFT] Electricity, [CFT] Electricity							
Actual	103.3	71.1	5	6.3	5.69	5.8	11.37
Notional	155.1	98.3	17.7	2.7	2.43	---	---
[ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Natural Gas, [CFT] Electricity							
Actual	103	9.5	34	7	0.84	1	0
Notional	173.9	29.3	59	14.1	0.82	---	---

Key to terms

Heat dem [MJ/m2] = Heating energy demand
Cool dem [MJ/m2] = Cooling energy demand
Heat con [kWh/m2] = Heating energy consumption
Cool con [kWh/m2] = Cooling energy consumption
Aux con [kWh/m2] = Auxiliary energy consumption
Heat SSEFF = Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER = Cooling system seasonal energy efficiency ratio
Heat gen SSEFF = Heating generator seasonal efficiency
Cool gen SSEER = Cooling generator seasonal energy efficiency ratio
ST = System type
HS = Heat source
HFT = Heating fuel type
CFT = Cooling fuel type

Key Features

The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected.

Building fabric

Element	U _{typ}	U _{min}	Surface where the minimum value occurs*
Wall	0.23	0.13	"RV00000F_W1"
Floor	0.2	0.11	"RV000047_F_A0"
Roof	0.15	0.11	"RV00000F_C_A0"
Windows, roof windows, and rooflights	1.5	0.9	"RV00000F_W3_O0"
Personnel doors	1.5	-	"No external personnel doors"
Vehicle access & similar large doors	1.5	-	"No external vehicle access doors"
High usage entrance doors	1.5	-	"No external high usage entrance doors"
U _{typ} = Typical individual element U-values [W/(m²K)]			U _{min} = Minimum individual element U-values [W/(m²K)]
* There might be more than one surface where the minimum U-value occurs.			

Air Permeability	Typical value	This building
m³/(h.m²) at 50 Pa	5	4